

By Email & Post

RInfra-D/MERC/SOP Report FY 14-15/Q2/01
February 23, 2015

The Principal Secretary,
Maharashtra Electricity Regulatory Commission,
13th Floor, Centre No. 1, World Trade Centre,
Cuffe Parade, Colaba,
Mumbai – 400005.



Dear Sir,

Sub: Submission of revised SOP Report for Second Quarter of FY 2014-15.

Ref: RInfra-D/MERC/SOP Report FY 14-15/Q2, dated 2nd February, 2015.

RInfra hereby submits the revised SOP report for the 2nd quarter of FY 2014-15 in the specified format as per MERC (Standards of Performance of Distribution Licensees, Period of Giving Supply and Determination of Compensation) Regulations, 2014. Further RInfra requests the Hon'ble Commission to ignore the SOP report for 2nd quarter of FY 2014-15, submitted vide reference above.

Thanking You,

Yours faithfully,

(Kishor Patil)

Regulatory Affairs.

Encl: As above.

Annexure-I
Standards of Performance Level by the Distribution Licensee
Format for Quarterly Return to be submitted to the Commission by the Distribution Licensee
(July 2014 - September 2014)

Sr.No.	SOP Regulation No.	Parameters	Area	Pending complaint Nos. (previous Quarter)	Complaints in current Qtr.	Total complaints	No. of complaints addressed			Analysis/Reasons
							Within Standards of performance	More than stipulated time	Total complaints redressed	
a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i	
1	4.3	New connection - inspection of premises	Class-I Cities/Urban	188	10708	10896	0	10623	273	
2	4.4	Intimation of charges where supply from existing lines	Class-I Cities/Urban	141	8390	8501	0	8355	145	
3	4.5 & 4.6	Intimation of charges where supply to dedicated or after extension / augmentation	Class-I Cities/Urban	179	2318	2497	0	2255	242	
4	4.7	New connection/ add. load where supply from existing line	Class-I Cities/Urban	407	8390	8797	0	8283	514	
5	4.8	New connection/ add. load where supply after extension / augmentation	Class-I Cities/Urban	402	2318	2720	0	2351	369	
6	4.9	New connection/ add. load where supply after commissioning of sub-station	Class-I Cities/Urban	525	0	525	0	525	0	
7	4.12	Shifting of Meter / service line	Class-I Cities/Urban	15	2293	2308	0	2270	38	
8	6.10	Reconnection of supply after payment of dues	Class-I Cities/Urban	0	2553	2553	0	2553	0	
9	4.13	Change of Name		0	17254	17254	0	17254	0	
10	4.13	Change of category		137	2024	2161	0	1764	397	
11	5.4 (a)	Complaint of Voltage Variation - Local fault		0	0	0	0	0	0	
12	5.4 (b)	Complaint of Voltage Variation - Net work		0	0	0	0	0	0	
13	5.4 (c)	Complaint of Voltage Variation - Expansion / augmentation required		0	0	0	0	0	0	

Sr.No.	SOP Regulation No.	Parameters	Area	Pending complaint Nos. (previous Quarter)		Complaints in current Qtr.	Total complaints	No. of complaints addressed			Analysis/Reasons
				d	e			g	h	ig+h	
a	b	c	d	e	f=d+e	g	h	ig+h	j=f-i		
14	6.1	Fuse off cell	Class-I Cities/Urban	0	27432	27432	0	27432	0		
15	6.2	Breakdown of Overhead Line	Class-I Cities/Urban	0	0	0	0	0	0		
16	6.3	Underground Cable fault	Class-I Cities/Urban	0	14826	14826	1	14826	0	Multiple fault in same section	
17	6.4	Transformer failure	Class-I Cities/Urban	0	5	5	0	5	0		
18	7.2	Meter Reading	Class-I Cities/Urban	0	7499785	7499785	24*	7499761	0	*: 1. Premises continuously found Locked in 17 cases (includes 5 cases of court matter). 2. Unable to read the meter due to no access in 7 cases	
19	7.3	Replacement of Faulty Meter	Class-I Cities/Urban	0	3308	3308	0	3286	22		
20	7.4	Replacement of Burnt Meter	Class-I Cities/Urban	2	3198	3200	0	3190	10		
21	7.6, 7.7	Billing Complaint	Class-I Cities/Urban	73	8387	8460	0	8316	144		

Annexure-II
Report of individual Complaints where Compensation has been paid

Format for quarterly return to be submitted to the Commission by the Distribution Licensee
(July 2014 - September 2014)

Sr. No.	Complaint No.	Date of filing complaint	Consumer No.	Name and address of Consumer	Nature of Complaint	Reference Standard of Performance	Amount of Compensation (Rs.)	Date of payment of Compensation (DD/MM/YYYY)
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	NA	NA	NA	NA	NA	NA	NA	NA
2								
3								
4								
5								
6								
7								

NOTE - The report shall be prepared as per category of item for which the compensation is paid for non-observance of Standards of Performance.

2/10/14

Annexure-III
Report of action on Faulty Meters (1 Phase/ 3 Phase)

Format for quarterly return to be submitted to the Commission by the Distribution Licensee
(July 2014 - September 2014)

Sr.No.	Name of Distribution Licensee	Reference to Overall Standards	Faulty Meters at the start of the Quarter (Nos.)	Faulty Meters added during Quarter (Nos.)	Total Faulty Meters (Nos.)	Meters rectified / replaced (Nos.)	Faulty Meters pending at end of Quarter (Nos.)
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
1	R Infra	7.3	0	3308	3308	3286	22
2							
3							
4							
5							

214916

Annexure-IV
Performance Report regarding Reliability Indices

Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee

(1) System Average Interruption Duration Index (SAIDI)

Sr.No.	Month	Ni – Number of consumers who experienced a sustained interruption on ith feeder	Ri – Restoration time for each interruption event on ith feeder	Ni – Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI – (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	Jul-14	1	28	2910743	28	0.0000
2	Jul-14	10	22	2910743	220	0.0001
3	Jul-14	65	29	2910743	1885	0.0006
4	Jul-14	551	11	2910743	6061	0.0021
5	Jul-14	357	17	2910743	6069	0.0021
6	Jul-14	772	13	2910743	10037	0.0034
7	Jul-14	1925	7	2910743	13475	0.0046
8	Jul-14	801	17	2910743	13617	0.0047
9	Jul-14	356	40	2910743	14283	0.0049
10	Jul-14	482	31	2910743	14942	0.0051
11	Jul-14	1660	10	2910743	17074	0.0059
12	Jul-14	1249	17	2910743	21484	0.0074
13	Jul-14	922	27	2910743	24451	0.0084
14	Jul-14	930	27	2910743	24730	0.0085
15	Jul-14	1510	17	2910743	25670	0.0088
16	Jul-14	777	35	2910743	27511	0.0095
17	Jul-14	941	30	2910743	27891	0.0096
18	Jul-14	1415	20	2910743	28604	0.0098
19	Jul-14	822	35	2910743	28658	0.0098
20	Jul-14	757	38	2910743	28766	0.0099
21	Jul-14	1987	16	2910743	31465	0.0108
22	Jul-14	1773	19	2910743	33687	0.0116
23	Jul-14	1759	20	2910743	35180	0.0121
24	Jul-14	2058	18	2910743	36268	0.0125
25	Jul-14	1458	27	2910743	39654	0.0136
26	Jul-14	1773	23	2910743	40779	0.0140
27	Jul-14	1620	26	2910743	42120	0.0145
28	Jul-14	5589	8	2910743	42984	0.0148
29	Jul-14	2457	18	2910743	44216	0.0152
30	Jul-14	1802	25	2910743	44784	0.0154
31	Jul-14	1987	31	2910743	62522	0.0215
32	Jul-14	1594	40	2910743	64321	0.0221
33	Jul-14	3789	17	2910743	64413	0.0221
34	Jul-14	2214	31	2910743	69074	0.0237
35	Jul-14	5231	15	2910743	78548	0.0270
36	Jul-14	3044	26	2910743	78949	0.0271
37	Jul-14	6647	14	2910743	95834	0.0329
38	Jul-14	5736	17	2910743	97563	0.0335
39	Jul-14	1837	54	2910743	99113	0.0341
40	Jul-14	4176	24	2910743	99205	0.0341
41	Jul-14	6428	16	2910743	104615	0.0359
42	Jul-14	2300	47	2910743	107575	0.0370
43	Jul-14	4077	30	2910743	120744	0.0415
44	Jul-14	6805	18	2910743	124558	0.0428
45	Jul-14	5495	23	2910743	126950	0.0436
46	Jul-14	2761	46	2910743	126973	0.0436

2/14/16

Annexure-IV
Performance Report regarding Reliability Indices

Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee

(1) System Average Interruption Duration Index (SAIDI)

Sr.No.	Month	Ni – Number of consumers who experienced a sustained interruption on ith feeder	Ri – Restoration time for each interruption event on ith feeder	Nt – Total number of consumers of the distribution licensees area	Sum(Ri * Ni) for all feeders (excluding agri. Feeders)	SAIDI – (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
47	Jul-14	4156	31	2910/43	127690	0.0439
48	Jul-14	7445	18	2910/43	130928	0.0450
49	Jul-14	5978	24	2910/43	141833	0.0487
50	Jul-14	4050	38	2910/43	152469	0.0524
51	Jul-14	6410	24	2910/43	152610	0.0524
52	Jul-14	4386	38	2910/43	166611	0.0572
53	Jul-14	7913	23	2910/43	178205	0.0612
54	Jul-14	5009	38	2910/43	187871	0.0645
55	Jul-14	14433	13	2910/43	190634	0.0655
56	Jul-14	5978	33	2910/43	195694	0.0672
57	Jul-14	6378	34	2910/43	214997	0.0739
58	Jul-14	7055	33	2910/43	232191	0.0798
59	Jul-14	6995	39	2910/43	272805	0.0937
60	Jul-14	6271	50	2910/43	314383	0.1080
61	Jul-14	4237	84	2910/43	357154	0.1227
62	Jul-14	7955	52	2910/43	413468	0.1420
63	Jul-14	26135	19	2910/43	502124	0.1725
64	Jul-14	4424	172	2910/43	761328	0.2616
65	Jul-14	7409	236	2910/43	1750135	0.6013
66	Jul-14	13557	135	2910/43	1830280	0.6288
67	Jul-14	10	31	2910/43	310	0.0001
68	Jul-14	5894	9	2910/43	55590	0.0191
69	Jul-14	7007	30	2910/43	206705	0.0710
70	Jul-14	4829	70	2910/43	338494	0.1163
71	Jul-14	105	6	2910/43	630	0.0002
72	Jul-14	45	22	2910/43	990	0.0003
73	Jul-14	205	29	2910/43	5976	0.0021
74	Jul-14	821	8	2910/43	6568	0.0023
75	Jul-14	802	13	2910/43	10426	0.0036
76	Jul-14	1001	12	2910/43	12012	0.0041
77	Jul-14	2131	6	2910/43	12786	0.0044
78	Jul-14	4335	10	2910/43	43350	0.0149
79	Jul-14	2069	45	2910/43	93198	0.0320
80	Jul-14	1561	69	2910/43	107709	0.0370
81	Jul-14	2531	87	2910/43	220197	0.0756
Total		292220	39.82	2910/43	11635906	3.9976

Remark :

- 1 Customer served by Rinfra are 2910/43 nos.
- 2 Number of feeders are 1019 Nos.

Annexure-IV

Performance Report regarding Reliability Indices

Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee

(1) System Average Interruption Duration Index (SAIDI)

Sr.No.	Month	Ni – Number of consumers who experienced a sustained interruption on ith feeder	Ri – Restoration time for each interruption event on ith feeder	Ni – Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI – (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	Aug-14	1	26	2914485	26	0.0000
2	Aug-14	245	6	2914485	1470	0.0005
3	Aug-14	82	18	2914485	1476	0.0005
4	Aug-14	176	26	2914485	4576	0.0016
5	Aug-14	770	6	2914485	4620	0.0016
6	Aug-14	197	32	2914485	6304	0.0022
7	Aug-14	307	24	2914485	7307	0.0025
8	Aug-14	458	21	2914485	9618	0.0033
9	Aug-14	387	29	2914485	11223	0.0039
10	Aug-14	666	24	2914485	16257	0.0056
11	Aug-14	484	37	2914485	18126	0.0062
12	Aug-14	2088	9	2914485	19398	0.0067
13	Aug-14	930	21	2914485	19781	0.0068
14	Aug-14	892	25	2914485	22032	0.0076
15	Aug-14	703	35	2914485	24605	0.0084
16	Aug-14	2137	14	2914485	28935	0.0099
17	Aug-14	1399	21	2914485	30037	0.0103
18	Aug-14	1820	17	2914485	30540	0.0105
19	Aug-14	1527	21	2914485	32067	0.0110
20	Aug-14	1597	21	2914485	33537	0.0115
21	Aug-14	4130	9	2914485	36385	0.0125
22	Aug-14	1793	21	2914485	37402	0.0128
23	Aug-14	1410	28	2914485	39283	0.0135
24	Aug-14	3815	11	2914485	41698	0.0143
25	Aug-14	3682	14	2914485	51548	0.0177
26	Aug-14	2119	25	2914485	53674	0.0184
27	Aug-14	1458	37	2914485	53946	0.0185
28	Aug-14	2443	24	2914485	57411	0.0197
29	Aug-14	1522	38	2914485	58125	0.0199
30	Aug-14	840	69	2914485	58145	0.0200
31	Aug-14	2484	25	2914485	62100	0.0213
32	Aug-14	3510	18	2914485	63180	0.0217
33	Aug-14	902	76	2914485	68552	0.0235
34	Aug-14	2886	25	2914485	71688	0.0246
35	Aug-14	4104	18	2914485	73913	0.0254
36	Aug-14	4059	21	2914485	85239	0.0292
37	Aug-14	2033	43	2914485	86545	0.0297
38	Aug-14	2829	31	2914485	87699	0.0301
39	Aug-14	1505	62	2914485	92603	0.0318
40	Aug-14	7253	13	2914485	97553	0.0335
41	Aug-14	4528	22	2914485	99616	0.0342
42	Aug-14	2260	47	2914485	105858	0.0363
43	Aug-14	9921	11	2914485	110619	0.0380
44	Aug-14	5231	27	2914485	142336	0.0488
45	Aug-14	5754	26	2914485	146727	0.0503
46	Aug-14	4951	32	2914485	158135	0.0543

Annexure-IV
Performance Report regarding Reliability Indices

Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee
(1) System Average Interruption Duration Index (SAIDI)

Sr.No.	Month	Ni - Number of consumers who experienced a sustained interruption on ith feeder	Ri - Restoration time for each interruption event on ith feeder	Nt - Total number of consumers of the distribution licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI - (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
47	Aug-14	7055	23	2914485	161066	0.0553
48	Aug-14	6394	26	2914485	169249	0.0581
49	Aug-14	7185	24	2914485	172440	0.0592
50	Aug-14	7171	25	2914485	180709	0.0620
51	Aug-14	9921	18	2914485	181157	0.0622
52	Aug-14	4239	43	2914485	182319	0.0626
53	Aug-14	3769	49	2914485	186076	0.0638
54	Aug-14	6835	32	2914485	217285	0.0746
55	Aug-14	6706	38	2914485	251542	0.0863
56	Aug-14	10601	25	2914485	265025	0.0909
57	Aug-14	4973	56	2914485	278339	0.0955
58	Aug-14	11333	26	2914485	296358	0.1017
59	Aug-14	8648	34	2914485	297837	0.1022
60	Aug-14	9087	34	2914485	304596	0.1045
61	Aug-14	8761	36	2914485	314870	0.1080
62	Aug-14	4014	81	2914485	323288	0.1109
63	Aug-14	19454	18	2914485	355036	0.1218
64	Aug-14	8693	60	2914485	523319	0.1796
65	Aug-14	23	22	2914485	511	0.0002
66	Aug-14	175	16	2914485	2800	0.0010
67	Aug-14	161	43	2914485	6923	0.0024
68	Aug-14	480	19	2914485	9120	0.0031
69	Aug-14	703	24	2914485	16872	0.0058
70	Aug-14	1690	26	2914485	43264	0.0148
71	Aug-14	4314	22	2914485	96245	0.0330
72	Aug-14	470	19	2914485	9015	0.0031
73	Aug-14	4127	24	2914485	100286	0.0344
74	Aug-14	3379	31	2914485	104749	0.0359
75	Aug-14	4829	24	2914485	115123	0.0395
76	Aug-14	8796	36	2914485	313401	0.1075
77	Aug-14	1	6	2914485	6	0.0000
78	Aug-14	1250	10	2914485	12500	0.0043
79	Aug-14	1329	18	2914485	23922	0.0082
80	Aug-14	8390	9	2914485	77440	0.0266
Total		289244	2750	2914485	7954600	2.7293

Remark :

1. Customer served by Rinfra are 2914485 nos.
2. Number of feeders are 1021 Nos.

Annexure-IV
Performance Report regarding Reliability Indices

Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee
(1) System Average Interruption Duration Index (SAIDI)

Sr.No.	Month	Ni :- Number of consumers who experienced a sustained interruption on ith feeder	Ri :- Restoration time for each interruption event on ith feeder	NL :- Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. feeders)	SAIDI :- (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	Sep-14	148	9	2914777	1332	0.0005
2	Sep-14	83	26	2914777	2158	0.0007
3	Sep-14	119	24	2914777	2892	0.0010
4	Sep-14	108	47	2914777	5087	0.0017
5	Sep-14	540	11	2914777	6037	0.0021
6	Sep-14	524	14	2914777	7336	0.0025
7	Sep-14	670	15	2914777	10124	0.0035
8	Sep-14	711	18	2914777	12798	0.0044
9	Sep-14	527	31	2914777	16337	0.0056
10	Sep-14	1008	19	2914777	18890	0.0065
11	Sep-14	817	25	2914777	20450	0.0070
12	Sep-14	649	32	2914777	20651	0.0071
13	Sep-14	1399	15	2914777	21419	0.0073
14	Sep-14	1010	22	2914777	22089	0.0076
15	Sep-14	1520	17	2914777	25840	0.0089
16	Sep-14	2894	10	2914777	27725	0.0095
17	Sep-14	2820	10	2914777	28200	0.0097
18	Sep-14	1056	27	2914777	28987	0.0099
19	Sep-14	1039	28	2914777	28998	0.0099
20	Sep-14	1280	26	2914777	33280	0.0114
21	Sep-14	1589	22	2914777	34767	0.0119
22	Sep-14	1836	20	2914777	37087	0.0127
23	Sep-14	3580	13	2914777	46433	0.0159
24	Sep-14	2006	23	2914777	46660	0.0160
25	Sep-14	2178	23	2914777	49637	0.0170
26	Sep-14	2943	18	2914777	52150	0.0179
27	Sep-14	1514	35	2914777	53096	0.0182
28	Sep-14	3983	14	2914777	53771	0.0184
29	Sep-14	7457	7	2914777	54809	0.0188
30	Sep-14	4100	14	2914777	56088	0.0192
31	Sep-14	7646	8	2914777	59486	0.0204
32	Sep-14	3370	18	2914777	59481	0.0204
33	Sep-14	2170	28	2914777	60760	0.0208
34	Sep-14	5389	14	2914777	77979	0.0268
35	Sep-14	2389	36	2914777	86936	0.0298
36	Sep-14	8039	11	2914777	88992	0.0305
37	Sep-14	2464	40	2914777	98708	0.0339
38	Sep-14	7095	14	2914777	99330	0.0341
39	Sep-14	5635	18	2914777	102951	0.0353
40	Sep-14	6681	16	2914777	106896	0.0367
41	Sep-14	4827	23	2914777	110152	0.0378
42	Sep-14	7577	15	2914777	110776	0.0380
43	Sep-14	3928	28	2914777	111673	0.0383
44	Sep-14	2430	46	2914777	112509	0.0386
45	Sep-14	7037	18	2914777	125047	0.0429
46	Sep-14	5550	23	2914777	125208	0.0430

Annexure-IV
Performance Report regarding Reliability Indices

Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee
(1) System Average Interruption Duration Index (SAIDI)

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
47	Sep-14	17214	8	2914///	137712	0.0472
48	Sep-14	4839	30	2914///	143380	0.0492
49	Sep-14	4827	31	2914///	148913	0.0511
50	Sep-14	793	188	2914///	148981	0.0511
51	Sep-14	7103	25	2914///	178569	0.0613
52	Sep-14	4909	41	2914///	201269	0.0693
53	Sep-14	6838	31	2914///	210884	0.0723
54	Sep-14	12192	17	2914///	212872	0.0730
55	Sep-14	7621	30	2914///	226267	0.0776
56	Sep-14	7283	34	2914///	250025	0.0858
57	Sep-14	10459	24	2914///	252062	0.0865
58	Sep-14	7203	36	2914///	262477	0.0901
59	Sep-14	949	284	2914///	269516	0.0925
60	Sep-14	10200	33	2914///	333846	0.1145
61	Sep-14	9294	42	2914///	394902	0.1355
62	Sep-14	11604	43	2914///	503962	0.1729
63	Sep-14	5915	1033	2914///	6110195	2.0963
64	Sep-14	51	50	2914///	2550	0.0009
65	Sep-14	1747	30	2914///	51537	0.0177
66	Sep-14	4784	17	2914///	79414	0.0272
67	Sep-14	3222	57	2914///	182784	0.0627
68	Sep-14	5092	46	2914///	233876	0.0802
69	Sep-14	648	6	2914///	3888	0.0013
70	Sep-14	626	16	2914///	10016	0.0034
71	Sep-14	1557	12	2914///	18217	0.0062
72	Sep-14	4630	14	2914///	66163	0.0227
73	Sep-14	4647	23	2914///	108693	0.0373
74	Sep-14	55	6	2914///	330	0.0001
75	Sep-14	1658	9	2914///	14922	0.0051
76	Sep-14	2464	7	2914///	17248	0.0059
77	Sep-14	2586	9	2914///	23274	0.0080
78	Sep-14	7744	9	2914///	69696	0.0239
79	Sep-14	3221	24	2914///	78238	0.0268
Total		306310	43.45	2914///	13308687	4.5659

Remark :

- 1 Customer served by Rinfra are 2914/// nos.
- 2 Number of feeders are 1022 Nos.

Annexure-V
Performance Report regarding Reliability Indices
Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee

(2) System Average Interruption Frequency Index (SAIFI)

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
1	Jul-14	1	1	2910743	0.0000
2	Jul-14	10	10	2910743	0.0000
3	Jul-14	65	65	2910743	0.0000
4	Jul-14	551	551	2910743	0.0002
5	Jul-14	357	357	2910743	0.0001
6	Jul-14	172	172	2910743	0.0003
7	Jul-14	1925	1925	2910743	0.0007
8	Jul-14	801	801	2910743	0.0003
9	Jul-14	356	356	2910743	0.0001
10	Jul-14	482	482	2910743	0.0002
11	Jul-14	1660	1660	2910743	0.0006
12	Jul-14	1249	1249	2910743	0.0004
13	Jul-14	922	922	2910743	0.0003
14	Jul-14	930	930	2910743	0.0003
15	Jul-14	1510	1510	2910743	0.0005
16	Jul-14	177	177	2910743	0.0003
17	Jul-14	941	941	2910743	0.0003
18	Jul-14	1415	1415	2910743	0.0005
19	Jul-14	822	822	2910743	0.0003
20	Jul-14	757	757	2910743	0.0003
21	Jul-14	1987	1987	2910743	0.0007
22	Jul-14	1773	1773	2910743	0.0006
23	Jul-14	1759	1759	2910743	0.0006
24	Jul-14	2058	2058	2910743	0.0007
25	Jul-14	1458	1458	2910743	0.0005
26	Jul-14	1773	1773	2910743	0.0006
27	Jul-14	1620	1620	2910743	0.0006
28	Jul-14	5589	5589	2910743	0.0019
29	Jul-14	2457	2457	2910743	0.0008
30	Jul-14	1802	1802	2910743	0.0006
31	Jul-14	1987	1987	2910743	0.0007
32	Jul-14	1594	1594	2910743	0.0005
33	Jul-14	3789	3789	2910743	0.0013
34	Jul-14	2214	2214	2910743	0.0008
35	Jul-14	5231	5231	2910743	0.0018
36	Jul-14	3044	3044	2910743	0.0010
37	Jul-14	6647	6647	2910743	0.0023
38	Jul-14	5736	5736	2910743	0.0020
39	Jul-14	1837	1837	2910743	0.0006
40	Jul-14	4176	4176	2910743	0.0014
41	Jul-14	6428	6428	2910743	0.0022
42	Jul-14	2300	2300	2910743	0.0008

Annexure-V

Performance Report regarding Reliability Indices

Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee

(2) System Average Interruption Frequency Index (SAIFI)

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (events)
(1)	(2)	(3)	(4)	(5)	(6)
43	Jul-14	4077	4077	2910743	0.0014
44	Jul-14	6805	6805	2910743	0.0023
45	Jul-14	5495	5495	2910743	0.0019
46	Jul-14	2761	2761	2910743	0.0009
47	Jul-14	4156	4156	2910743	0.0014
48	Jul-14	7445	7445	2910743	0.0026
49	Jul-14	5978	5978	2910743	0.0021
50	Jul-14	4050	4050	2910743	0.0014
51	Jul-14	6410	6410	2910743	0.0022
52	Jul-14	4386	4386	2910743	0.0015
53	Jul-14	7913	7913	2910743	0.0027
54	Jul-14	5009	5009	2910743	0.0017
55	Jul-14	14433	14433	2910743	0.0050
56	Jul-14	5978	5978	2910743	0.0021
57	Jul-14	6378	6378	2910743	0.0022
58	Jul-14	7055	7055	2910743	0.0024
59	Jul-14	6995	6995	2910743	0.0024
60	Jul-14	6271	6271	2910743	0.0022
61	Jul-14	4237	4237	2910743	0.0015
62	Jul-14	7955	7955	2910743	0.0027
63	Jul-14	26135	26135	2910743	0.0090
64	Jul-14	4424	4424	2910743	0.0015
65	Jul-14	7409	7409	2910743	0.0025
66	Jul-14	13557	13557	2910743	0.0047
67	Jul-14	10	10	2910743	0.0000
68	Jul-14	5894	5894	2910743	0.0020
69	Jul-14	7007	7007	2910743	0.0024
70	Jul-14	4829	4829	2910743	0.0017
71	Jul-14	105	105	2910743	0.0000
72	Jul-14	45	45	2910743	0.0000
73	Jul-14	205	205	2910743	0.0001
74	Jul-14	821	821	2910743	0.0003
75	Jul-14	802	802	2910743	0.0003
76	Jul-14	1001	1001	2910743	0.0003
77	Jul-14	2131	2131	2910743	0.0007
78	Jul-14	4335	4335	2910743	0.0015
79	Jul-14	2069	2069	2910743	0.0007
80	Jul-14	1561	1561	2910743	0.0005
81	Jul-14	2531	2531	2910743	0.0009
Total		292220	292220	2910743	0.1004

Remark :

- 1 Customer served by Rinra are 2910743 nos.
- 2 Number of feeders are 1019 Nos.

2181/0

Annexure-V

Performance Report regarding Reliability Indices

Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee

(2) System Average Interruption Frequency Index (SAIFI)

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
1	Aug-14	1	1	2914485	0.0000
2	Aug-14	245	245	2914485	0.0001
3	Aug-14	82	82	2914485	0.0000
4	Aug-14	176	176	2914485	0.0001
5	Aug-14	770	770	2914485	0.0003
6	Aug-14	197	197	2914485	0.0001
7	Aug-14	307	307	2914485	0.0001
8	Aug-14	458	458	2914485	0.0002
9	Aug-14	387	387	2914485	0.0001
10	Aug-14	666	666	2914485	0.0002
11	Aug-14	484	484	2914485	0.0002
12	Aug-14	2088	2088	2914485	0.0007
13	Aug-14	930	930	2914485	0.0003
14	Aug-14	892	892	2914485	0.0003
15	Aug-14	703	703	2914485	0.0002
16	Aug-14	2137	2137	2914485	0.0007
17	Aug-14	1399	1399	2914485	0.0005
18	Aug-14	1820	1820	2914485	0.0006
19	Aug-14	1527	1527	2914485	0.0005
20	Aug-14	1597	1597	2914485	0.0005
21	Aug-14	4130	4130	2914485	0.0014
22	Aug-14	1793	1793	2914485	0.0006
23	Aug-14	1410	1410	2914485	0.0005
24	Aug-14	3815	3815	2914485	0.0013
25	Aug-14	3682	3682	2914485	0.0013
26	Aug-14	2119	2119	2914485	0.0007
27	Aug-14	1458	1458	2914485	0.0005
28	Aug-14	2443	2443	2914485	0.0008
29	Aug-14	1522	1522	2914485	0.0005
30	Aug-14	840	840	2914485	0.0003
31	Aug-14	2484	2484	2914485	0.0009
32	Aug-14	3510	3510	2914485	0.0012
33	Aug-14	902	902	2914485	0.0003
34	Aug-14	2886	2886	2914485	0.0010
35	Aug-14	4104	4104	2914485	0.0014
36	Aug-14	4059	4059	2914485	0.0014
37	Aug-14	2033	2033	2914485	0.0007
38	Aug-14	2829	2829	2914485	0.0010
39	Aug-14	1505	1505	2914485	0.0005
40	Aug-14	7253	7253	2914485	0.0025
41	Aug-14	4528	4528	2914485	0.0016
42	Aug-14	2260	2260	2914485	0.0008

Annexure-V
Performance Report regarding Reliability Indices
Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee
(2) System Average Interruption Frequency Index (SAIFI)

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = $\sum Ni$	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
43	Aug-14	9921	9921	2914485	0.0034
44	Aug-14	5231	5231	2914485	0.0018
45	Aug-14	5754	5754	2914485	0.0020
46	Aug-14	4951	4951	2914485	0.0017
47	Aug-14	7055	7055	2914485	0.0024
48	Aug-14	6394	6394	2914485	0.0022
49	Aug-14	7185	7185	2914485	0.0025
50	Aug-14	7171	7171	2914485	0.0025
51	Aug-14	9921	9921	2914485	0.0034
52	Aug-14	4239	4239	2914485	0.0015
53	Aug-14	3769	3769	2914485	0.0013
54	Aug-14	6835	6835	2914485	0.0023
55	Aug-14	6706	6706	2914485	0.0023
56	Aug-14	10601	10601	2914485	0.0036
57	Aug-14	4973	4973	2914485	0.0017
58	Aug-14	11333	11333	2914485	0.0039
59	Aug-14	8648	8648	2914485	0.0030
60	Aug-14	9087	9087	2914485	0.0031
61	Aug-14	8761	8761	2914485	0.0030
62	Aug-14	4014	4014	2914485	0.0014
63	Aug-14	19454	19454	2914485	0.0067
64	Aug-14	8693	8693	2914485	0.0030
65	Aug-14	23	23	2914485	0.0000
66	Aug-14	175	175	2914485	0.0001
67	Aug-14	161	161	2914485	0.0001
68	Aug-14	480	480	2914485	0.0002
69	Aug-14	703	703	2914485	0.0002
70	Aug-14	1690	1690	2914485	0.0006
71	Aug-14	4314	4314	2914485	0.0015
72	Aug-14	470	470	2914485	0.0002
73	Aug-14	4127	4127	2914485	0.0014
74	Aug-14	3379	3379	2914485	0.0012
75	Aug-14	4829	4829	2914485	0.0017
76	Aug-14	8796	8796	2914485	0.0030
77	Aug-14	1	1	2914485	0.0000
78	Aug-14	1250	1250	2914485	0.0004
79	Aug-14	1329	1329	2914485	0.0005
80	Aug-14	8390	8390	2914485	0.0029
Total		289244	289244	2914485	0.0992

Remark :
 1 Customer served by Rinfra are 2914485 nos.
 2 Number of feeders are 1021 Nos.

Annexure-V
 Performance Report regarding Reliability Indices
 Formats for Quarterly returns to be submitted to the Commission by the
 Distribution Licensee
 (2) System Average Interruption Frequency Index (SAIFI)

Sr.No.	Month	N _i Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions Sum N _i	Nt Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
1	Sep-14	148	148	2914777	0.0001
2	Sep-14	83	83	2914777	0.0000
3	Sep-14	119	119	2914777	0.0000
4	Sep-14	108	108	2914777	0.0000
5	Sep-14	540	540	2914777	0.0002
6	Sep-14	524	524	2914777	0.0002
7	Sep-14	670	670	2914777	0.0002
8	Sep-14	711	711	2914777	0.0002
9	Sep-14	527	527	2914777	0.0002
10	Sep-14	1008	1008	2914777	0.0003
11	Sep-14	817	817	2914777	0.0003
12	Sep-14	649	649	2914777	0.0002
13	Sep-14	1399	1399	2914777	0.0005
14	Sep-14	1010	1010	2914777	0.0003
15	Sep-14	1520	1520	2914777	0.0005
16	Sep-14	2894	2894	2914777	0.0010
17	Sep-14	2820	2820	2914777	0.0010
18	Sep-14	1056	1056	2914777	0.0004
19	Sep-14	1039	1039	2914777	0.0004
20	Sep-14	1280	1280	2914777	0.0004
21	Sep-14	1589	1589	2914777	0.0005
22	Sep-14	1836	1836	2914777	0.0006
23	Sep-14	3580	3580	2914777	0.0012
24	Sep-14	2006	2006	2914777	0.0007
25	Sep-14	2178	2178	2914777	0.0007
26	Sep-14	2943	2943	2914777	0.0010
27	Sep-14	1514	1514	2914777	0.0005
28	Sep-14	3983	3983	2914777	0.0014
29	Sep-14	7457	7457	2914777	0.0026
30	Sep-14	4100	4100	2914777	0.0014
31	Sep-14	7646	7646	2914777	0.0026
32	Sep-14	3370	3370	2914777	0.0012
33	Sep-14	2170	2170	2914777	0.0007
34	Sep-14	5389	5389	2914777	0.0018
35	Sep-14	2389	2389	2914777	0.0008
36	Sep-14	8039	8039	2914777	0.0028
37	Sep-14	2464	2464	2914777	0.0008
38	Sep-14	7095	7095	2914777	0.0024
39	Sep-14	5635	5635	2914777	0.0019
40	Sep-14	6681	6681	2914777	0.0023
41	Sep-14	4827	4827	2914777	0.0017
42	Sep-14	7577	7577	2914777	0.0026

Annexure-V
 Performance Report regarding Reliability Indices
 Formats for Quarterly returns to be submitted to the Commission by the
 Distribution Licensee
 (2) System Average Interruption Frequency Index (SAIFI)

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Ni = Total number of consumers of the distribution licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
43	Sep-14	3928	3928	2914777	0.0013
44	Sep-14	2430	2430	2914777	0.0008
45	Sep-14	7037	7037	2914777	0.0024
46	Sep-14	5550	5550	2914777	0.0019
47	Sep-14	17214	17214	2914777	0.0059
48	Sep-14	4839	4839	2914777	0.0017
49	Sep-14	4827	4827	2914777	0.0017
50	Sep-14	793	793	2914777	0.0003
51	Sep-14	7103	7103	2914777	0.0024
52	Sep-14	4909	4909	2914777	0.0017
53	Sep-14	6838	6838	2914777	0.0023
54	Sep-14	12192	12192	2914777	0.0042
55	Sep-14	7621	7621	2914777	0.0026
56	Sep-14	7283	7283	2914777	0.0025
57	Sep-14	10459	10459	2914777	0.0036
58	Sep-14	7203	7203	2914777	0.0025
59	Sep-14	949	949	2914777	0.0003
60	Sep-14	10200	10200	2914777	0.0035
61	Sep-14	9294	9294	2914777	0.0032
62	Sep-14	11604	11604	2914777	0.0040
63	Sep-14	5915	5915	2914777	0.0020
64	Sep-14	51	51	2914777	0.0000
65	Sep-14	1747	1747	2914777	0.0006
66	Sep-14	4784	4784	2914777	0.0016
67	Sep-14	3222	3222	2914777	0.0011
68	Sep-14	5092	5092	2914777	0.0017
69	Sep-14	648	648	2914777	0.0002
70	Sep-14	626	626	2914777	0.0002
71	Sep-14	1557	1557	2914777	0.0005
72	Sep-14	4630	4630	2914777	0.0016
73	Sep-14	4647	4647	2914777	0.0016
74	Sep-14	55	55	2914777	0.0000
75	Sep-14	1658	1658	2914777	0.0006
76	Sep-14	2464	2464	2914777	0.0008
77	Sep-14	2586	2586	2914777	0.0009
78	Sep-14	7744	7744	2914777	0.0027
79	Sep-14	3221	3221	2914777	0.0011
Total		306310	306310	2914777	0.1051

Remark :
 1. Customer served by Rinfra are 2914777 nos.
 2. Number of feeders are 1022 Nos.

2/23/16

Annexure-VI
 Performance Report regarding Reliability Indices
 Formats for Quarterly returns to be submitted to the
 Commission by the Distribution Licensee

(3) Customer Average Interruption Duration Index (CAIDI)

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
1	Jul-14	0.0000	0.0000	28.2000
2	Jul-14	0.0001	0.0000	22.0200
3	Jul-14	0.0006	0.0000	29.0031
4	Jul-14	0.0021	0.0002	11.0004
5	Jul-14	0.0021	0.0001	17.0000
6	Jul-14	0.0034	0.0003	13.0010
7	Jul-14	0.0046	0.0007	6.9999
8	Jul-14	0.0047	0.0003	17.0000
9	Jul-14	0.0049	0.0001	40.1208
10	Jul-14	0.0051	0.0002	30.9996
11	Jul-14	0.0059	0.0006	10.2857
12	Jul-14	0.0074	0.0004	17.2011
13	Jul-14	0.0084	0.0003	26.5197
14	Jul-14	0.0085	0.0003	26.5916
15	Jul-14	0.0088	0.0005	16.9999
16	Jul-14	0.0095	0.0003	35.4069
17	Jul-14	0.0096	0.0003	29.6397
18	Jul-14	0.0098	0.0005	20.2147
19	Jul-14	0.0098	0.0003	34.8635
20	Jul-14	0.0099	0.0003	37.9997
21	Jul-14	0.0108	0.0007	15.8355
22	Jul-14	0.0116	0.0006	19.0000
23	Jul-14	0.0121	0.0006	19.9999
24	Jul-14	0.0125	0.0007	17.6230
25	Jul-14	0.0136	0.0005	27.1975
26	Jul-14	0.0140	0.0006	23.0000
27	Jul-14	0.0145	0.0006	26.0000
28	Jul-14	0.0148	0.0019	7.6908
29	Jul-14	0.0152	0.0008	17.9958
30	Jul-14	0.0154	0.0006	24.8524
31	Jul-14	0.0215	0.0007	31.4654
32	Jul-14	0.0221	0.0005	40.3521
33	Jul-14	0.0221	0.0013	17.0000
34	Jul-14	0.0237	0.0008	31.1986
35	Jul-14	0.0270	0.0018	15.0158
36	Jul-14	0.0271	0.0010	25.9360
37	Jul-14	0.0329	0.0023	14.4177
38	Jul-14	0.0335	0.0020	17.0089
39	Jul-14	0.0341	0.0006	53.9536
40	Jul-14	0.0341	0.0014	23.7560
41	Jul-14	0.0359	0.0022	16.2750
42	Jul-14	0.0370	0.0008	46.7718
43	Jul-14	0.0415	0.0014	29.6159
44	Jul-14	0.0428	0.0023	18.3039
45	Jul-14	0.0436	0.0019	23.1029
46	Jul-14	0.0436	0.0009	45.9881

012/16

Annexure-VI
Performance Report regarding Reliability Indices
Formats for Quarterly returns to be submitted to the
Commission by the Distribution Licensee

(3) Customer Average Interruption Duration Index (CAIDI)

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
47	Jul-14	0.0439	0.0014	30.7243
48	Jul-14	0.0450	0.0026	17.5861
49	Jul-14	0.0487	0.0021	23.7258
50	Jul-14	0.0524	0.0014	37.6467
51	Jul-14	0.0524	0.0022	23.8081
52	Jul-14	0.0572	0.0015	37.9870
53	Jul-14	0.0612	0.0027	22.5205
54	Jul-14	0.0645	0.0017	37.5066
55	Jul-14	0.0655	0.0050	13.2082
56	Jul-14	0.0672	0.0021	32.7357
57	Jul-14	0.0739	0.0022	33.7091
58	Jul-14	0.0798	0.0024	32.9116
59	Jul-14	0.0937	0.0024	39.0000
60	Jul-14	0.1080	0.0022	50.1329
61	Jul-14	0.1227	0.0015	84.2941
62	Jul-14	0.1420	0.0027	51.9759
63	Jul-14	0.1725	0.0090	19.2127
64	Jul-14	0.2616	0.0015	172.0904
65	Jul-14	0.6013	0.0025	236.2175
66	Jul-14	0.6288	0.0047	135.0063
67	Jul-14	0.0001	0.0000	31.0200
68	Jul-14	0.0191	0.0020	9.4316
69	Jul-14	0.0710	0.0024	29.4998
70	Jul-14	0.1163	0.0017	70.0961
71	Jul-14	0.0002	0.0000	6.0000
72	Jul-14	0.0003	0.0000	22.0000
73	Jul-14	0.0021	0.0001	29.1512
74	Jul-14	0.0023	0.0003	8.0002
75	Jul-14	0.0036	0.0003	13.0002
76	Jul-14	0.0041	0.0003	12.0000
77	Jul-14	0.0044	0.0007	6.0000
78	Jul-14	0.0149	0.0015	10.0000
79	Jul-14	0.0320	0.0007	45.0449
80	Jul-14	0.0370	0.0005	69.0000
81	Jul-14	0.0756	0.0009	87.0000
Total		3.9976	0.1004	39.8190

Remark :

1. Customer served by Rinfra are 2910/43 nos.
2. Number of feeders are 1019 Nos.

21/9/16

Annexure-VI
Performance Report regarding Reliability Indices
Formats for Quarterly returns to be submitted to the Commission
by the Distribution Licensee

(3) Customer Average Interruption Duration Index (CAIDI)

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
1	Aug-14	0.0000	0.0000	25.8000
2	Aug-14	0.0005	0.0001	6.0000
3	Aug-14	0.0005	0.0000	18.0000
4	Aug-14	0.0016	0.0001	26.0000
5	Aug-14	0.0016	0.0003	6.0000
6	Aug-14	0.0022	0.0001	32.0000
7	Aug-14	0.0025	0.0001	23.8000
8	Aug-14	0.0033	0.0002	21.0000
9	Aug-14	0.0039	0.0001	29.0000
10	Aug-14	0.0056	0.0002	24.4100
11	Aug-14	0.0062	0.0002	37.4500
12	Aug-14	0.0067	0.0007	9.2900
13	Aug-14	0.0068	0.0003	21.2700
14	Aug-14	0.0076	0.0003	24.7000
15	Aug-14	0.0084	0.0002	35.0000
16	Aug-14	0.0099	0.0007	13.5400
17	Aug-14	0.0103	0.0005	21.4700
18	Aug-14	0.0105	0.0006	16.7800
19	Aug-14	0.0110	0.0005	21.0000
20	Aug-14	0.0115	0.0005	21.0000
21	Aug-14	0.0125	0.0014	8.8100
22	Aug-14	0.0128	0.0006	20.8600
23	Aug-14	0.0135	0.0005	27.8600
24	Aug-14	0.0143	0.0013	10.9300
25	Aug-14	0.0177	0.0013	14.0000
26	Aug-14	0.0184	0.0007	25.3300
27	Aug-14	0.0185	0.0005	37.0000
28	Aug-14	0.0197	0.0008	23.5000
29	Aug-14	0.0199	0.0005	38.1900
30	Aug-14	0.0200	0.0003	69.2200
31	Aug-14	0.0213	0.0009	25.0000
32	Aug-14	0.0217	0.0012	18.0000
33	Aug-14	0.0235	0.0003	76.0000
34	Aug-14	0.0246	0.0010	24.8400
35	Aug-14	0.0254	0.0014	18.0100
36	Aug-14	0.0292	0.0014	21.0000
37	Aug-14	0.0297	0.0007	42.5700
38	Aug-14	0.0301	0.0010	31.0000
39	Aug-14	0.0318	0.0005	61.5300
40	Aug-14	0.0335	0.0025	13.4500
41	Aug-14	0.0342	0.0016	22.0000
42	Aug-14	0.0363	0.0008	46.8400
43	Aug-14	0.0380	0.0034	11.1500
44	Aug-14	0.0488	0.0018	27.2100
45	Aug-14	0.0503	0.0020	25.5000
46	Aug-14	0.0543	0.0017	31.9400

Annexure-VI
Performance Report regarding Reliability Indices
Formats for Quarterly returns to be submitted to the Commission
by the Distribution Licensee

(3) Customer Average Interruption Duration Index (CAIDI)

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
47	Aug 14	0.0553	0.0024	22.8300
48	Aug 14	0.0581	0.0022	26.4700
49	Aug 14	0.0592	0.0025	24.0000
50	Aug 14	0.0620	0.0025	25.2000
51	Aug 14	0.0622	0.0034	18.2600
52	Aug 14	0.0626	0.0015	43.0100
53	Aug 14	0.0638	0.0013	49.3700
54	Aug 14	0.0746	0.0023	31.7900
55	Aug 14	0.0863	0.0023	37.5100
56	Aug 14	0.0909	0.0036	25.0000
57	Aug 14	0.0955	0.0017	55.9700
58	Aug 14	0.1017	0.0039	26.1500
59	Aug 14	0.1022	0.0030	34.4400
60	Aug 14	0.1045	0.0031	33.5200
61	Aug 14	0.1080	0.0030	35.9400
62	Aug 14	0.1109	0.0014	80.5400
63	Aug 14	0.1218	0.0067	18.2500
64	Aug 14	0.1796	0.0030	60.2000
65	Aug 14	0.0002	0.0000	22.2000
66	Aug 14	0.0010	0.0001	16.0000
67	Aug 14	0.0024	0.0001	43.0000
68	Aug 14	0.0031	0.0002	19.0000
69	Aug 14	0.0058	0.0002	24.0000
70	Aug 14	0.0148	0.0006	25.6000
71	Aug 14	0.0330	0.0015	22.3100
72	Aug 14	0.0031	0.0002	19.1800
73	Aug 14	0.0344	0.0014	24.3000
74	Aug 14	0.0359	0.0012	31.0000
75	Aug 14	0.0395	0.0017	23.8400
76	Aug 14	0.1075	0.0030	35.6300
77	Aug 14	0.0000	0.0000	6.0000
78	Aug 14	0.0043	0.0004	10.0000
79	Aug 14	0.0082	0.0005	18.0000
80	Aug 14	0.0266	0.0029	9.2300
Total		2.7293	0.0992	27.5013

Remark :

1. Customer served by Rinfra are 2914485 nos.
2. Number of feeders are 1021 Nos.

2115/6

Annexure-VI
Performance Report regarding Reliability Indices
Formats for Quarterly returns to be submitted to the
Commission by the Distribution Licensee

(3) Customer Average Interruption Duration Index (CAIDI)

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
1	Sep 14	0.0005	0.0001	9.0000
2	Sep 14	0.0007	0.0000	26.0000
3	Sep 14	0.0010	0.0000	24.3000
4	Sep 14	0.0017	0.0000	47.1000
5	Sep 14	0.0021	0.0002	11.1800
6	Sep 14	0.0025	0.0002	14.0000
7	Sep 14	0.0035	0.0002	15.1100
8	Sep 14	0.0044	0.0002	18.0000
9	Sep 14	0.0056	0.0002	31.0000
10	Sep 14	0.0065	0.0003	18.7400
11	Sep 14	0.0070	0.0003	25.0300
12	Sep 14	0.0071	0.0002	31.8200
13	Sep 14	0.0073	0.0005	15.3100
14	Sep 14	0.0076	0.0003	21.8700
15	Sep 14	0.0089	0.0005	17.0000
16	Sep 14	0.0095	0.0010	9.5800
17	Sep 14	0.0097	0.0010	10.0000
18	Sep 14	0.0099	0.0004	27.4500
19	Sep 14	0.0099	0.0004	27.9100
20	Sep 14	0.0114	0.0004	26.0000
21	Sep 14	0.0119	0.0005	21.8800
22	Sep 14	0.0127	0.0006	20.2000
23	Sep 14	0.0159	0.0012	12.9700
24	Sep 14	0.0160	0.0007	23.2600
25	Sep 14	0.0170	0.0007	22.7900
26	Sep 14	0.0179	0.0010	17.7200
27	Sep 14	0.0182	0.0005	35.0700
28	Sep 14	0.0184	0.0014	13.5000
29	Sep 14	0.0188	0.0026	7.3500
30	Sep 14	0.0192	0.0014	13.6800
31	Sep 14	0.0204	0.0026	7.7800
32	Sep 14	0.0204	0.0012	17.6500
33	Sep 14	0.0208	0.0007	28.0000
34	Sep 14	0.0268	0.0018	14.4700
35	Sep 14	0.0298	0.0008	36.3900
36	Sep 14	0.0305	0.0028	11.0700
37	Sep 14	0.0339	0.0008	40.0600
38	Sep 14	0.0341	0.0024	14.0000
39	Sep 14	0.0353	0.0019	18.2700
40	Sep 14	0.0367	0.0023	16.0000
41	Sep 14	0.0378	0.0017	22.8200
42	Sep 14	0.0380	0.0026	14.6200
43	Sep 14	0.0383	0.0013	28.4300
44	Sep 14	0.0386	0.0008	46.3000
45	Sep 14	0.0429	0.0024	17.7700
46	Sep 14	0.0430	0.0019	22.5600

Annexure-VI
Performance Report regarding Reliability Indices
Formats for Quarterly returns to be submitted to the
Commission by the Distribution Licensee

(3) Customer Average Interruption Duration Index (CAIDI)

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
47	Sep-14	0.0472	0.0059	8.0000
48	Sep-14	0.0492	0.0017	29.6300
49	Sep-14	0.0511	0.0017	30.8500
50	Sep-14	0.0511	0.0003	187.8700
51	Sep-14	0.0613	0.0024	25.1400
52	Sep-14	0.0691	0.0017	41.0000
53	Sep-14	0.0723	0.0023	30.8400
54	Sep-14	0.0730	0.0042	17.4600
55	Sep-14	0.0776	0.0026	29.6900
56	Sep-14	0.0858	0.0025	34.3300
57	Sep-14	0.0865	0.0036	24.1000
58	Sep-14	0.0901	0.0025	36.4400
59	Sep-14	0.0925	0.0003	284.0000
60	Sep-14	0.1145	0.0035	32.7300
61	Sep-14	0.1355	0.0032	42.4900
62	Sep-14	0.1729	0.0040	43.4300
63	Sep-14	2.0963	0.0020	1033.0000
64	Sep-14	0.0009	0.0000	50.0000
65	Sep-14	0.0177	0.0006	29.5000
66	Sep-14	0.0272	0.0016	16.6000
67	Sep-14	0.0627	0.0011	56.7300
68	Sep-14	0.0802	0.0017	45.9300
69	Sep-14	0.0013	0.0002	6.0000
70	Sep-14	0.0034	0.0002	16.0000
71	Sep-14	0.0062	0.0005	11.7000
72	Sep-14	0.0227	0.0016	14.2900
73	Sep-14	0.0373	0.0016	23.3900
74	Sep-14	0.0001	0.0000	6.0000
75	Sep-14	0.0051	0.0006	9.0000
76	Sep-14	0.0059	0.0008	7.0000
77	Sep-14	0.0080	0.0009	9.0000
78	Sep-14	0.0239	0.0027	9.0000
79	Sep-14	0.0268	0.0011	24.2900
Total		4.5659	0.1051	43.4484

Remark :

- 1 Customer served by Rinfra are 2914777 nos.
- 2 Number of feeders are 1022 Nos.