

Date: 05<sup>th</sup> July, 2017

To,

Secretary, Maharashtra electricity regulatory commission

13<sup>th</sup> Floor, centre no.1, World trade centre,

Cuff parade Colaba,

Mumbai-400005

Subject: Response to Verification and compliance for renewable purchase obligation notice (MERC/case no 101 of 2017-18/3612) dated 23<sup>rd</sup> June, 2017 is received on 30<sup>th</sup> June-2017.

Dear Sir,

We hereby received your notice MERC/case no 101 of 2017-18/3612) dated 23<sup>rd</sup> June, 2017, in regard to Renewable purchase obligation (RPO).

AkzoNobel India ltd is formerly known as ICI India limited.

We receive power from Maharashtra state electricity distribution co. ltd. And consumer no 000110920166. We have 1010 KVA diesel generator registration no E/TH/1354(ii) - 05/03/2008 is installed as stand by in case of emergency.

We are not entitled to pay for RPO regulatory charges as 1010 KVA Diesel generator is standby and used as emergency back up in event of power failure only. To support we are hereby attaching following documents,

Annexure 1 DG plan approval from MSEB and electrical inspector

Annexure 2 Application for DG installation

Annexure 3 DG returns challan for energy generated for the quarter.

Annexure 4 Electricity Bill for the quarter

We have furnished all relevant documents for your kind perusal.

Regards,

Damodar Patro

*Damodar Patro*

MERC	
Date	6/7/17
No.	6747

*6/7/17*





ICI India Limited  
Plot No. 1/1, TTC Indl. Area,  
Thane Belapur Road, P. O. Box 12,  
Koparkhairne, Navi Mumbai - 400 709.  
Telephone : (022) 2776 0000 - 04  
(022) 2778 0029

**APPLICATION FOR INSTALLATION OF D. G. SET**

1. Name of Owner/Occupier: **ICI India Limited, Mr. R. L. Jain (Managing Director)**
2. Location: **Plot No. 1/1, TTC Indl Area, Thane Belapur Road, Koparkhairne, Navi Mumbai.**
3. Capacity in KVA: **1010 kVA.**
4. Type of fuel & consumption rating in Ltr/Hr: **High Speed Diesel.  
203.8 Ltr/Hr.**
5. Arrangement proposed to be provided for Noise Control: **Acoustic Enclosure.**
6. Height of building in which D. G. Set is to be installed: **6.5Mtrs.**
7. Maximum height of building in 100M. Periphery: **20Mtrs.**
8. Are there any Educational Institute, Health Institute, and Court etc. in 100M. Periphery if yes, gives details of such institutions: **NO.**
9. In case of D. G. Set being installed in a building not fully owned by the Owner/Occupier of the D. G. Set, NOC from Owner/Chairman of the society of the building: **Not Applicable.**
10. Expected period when D. G. Set will be operated-
  - a) **[REDACTED]**
  - b) **During Power (MSEB) failure only:**
11. Stack details- Diameter:- **10 Inch.** Height:- **30Mtrs.**
12. Capital investment of D. G. Set: **6300000/- (Rs. Sixty Three Lakhs Only)**
13. Attended units: **10.9 Units (During testing at suppliers end)**

**DECLARATION**

Date: **12/03/2008**

Place: **Navi Mumbai.**

- D. A.: 1. Location Map.  
2. Noise pollution control measurements.  
3. NOC from MSEB/Competent authority as may be required.  
4. Any other information.  
5. Manufacturers specifications about pollution- Air, Noise, Vibration etc.

for   
Signature of Occupier  
12/03/08  


  
Jr. Clerk  
Region office  
Mumbai

महाराष्ट्र राज्य  
उद्योग उर्जा व कामगार विभाग

जा.क्र.विनि.टा./स्वोम./२०७

100/105

विद्युत निरीक्षक यांचे कार्यालय  
निरीक्षण विभाग क. टाणे  
उद्योग उर्जा व कामगार विभाग  
११ वा मंजूर, वागाडे इन्स्ट.  
टाणे - ४००१०१ फो. २२८२२६६६  
E-Mail-eithane1@mini.net.in  
दिनांक २२/१०/०८

प्रति

M/s ICI India Limited,  
Plot No 1/1 TTC Indl. Area,  
Thane Belapur Road, Koparkhane,  
Navi Mumbai


विषय : 1010 कॅपॅसिटर क्षमतेची जनित्र संचमांडणी कार्यान्वित करणाऱ्याची कार्यमदवकूपी परवानगी देण्याबाबत.

संदर्भ : १) नकाशा मंजूरी क्रमांक EIT-1/673/4863 दि.27.12.2007  
२) पत्र क्रमांक ICI/TPW/DG/1003 दि.Nil

या उल्लेखलेल्या ठिकाणाच्या जनित्र संचमांडणीचे निरीक्षण ह्या कार्यालयामार्फत दि.6.2.2008 रोजी करण्यात आले. त्याच भा.वि.नि.१९५६ मधील नियम क्रमांक ४३ अ अन्वये कार्यान्वित करणाऱ्याची कार्यमदवकूपी परवानगी याद्वारे खालील अटीवर देण्यात येत आहे.

- भा.वि.नि.१९५६ मधील तरतुदीचे सुगमतेनेच दृष्टीने पालन करावे.
- जनित्र संचमांडणीतील बदल, देखभाल व दुरुस्ती भा.वि.नि.१९५६ मधील नियम क्रमांक ६ व ८ अन्वये परवानग्याधारक / प्राधिकृत व्यक्तीमार्फतच करण्यात यावी. त्यात दुर्लक्ष केल्यास आढळल्यास त्याच आणकळ घडवणीत जबाबदार राहिल्याची नोंद घ्यावी.
- जनित्र निर्मित वीज उत्पादनाची सीदवही ठेवावी.
- निर्दिष्ट परतणे व वीज का मूल्यांत भरणे जनित्र धारकास बंधनकारक आहे.
- जनित्र वापर : औद्योगिक  
जनित्र क्षमता : 1010 कॅपॅसिटर  
इंधन : डिझेल  
बनावट : Stamford अ.क्र. 07100644  
इंजिन क्षमता : 1180 अश्वशक्ती  
बनावट : Cummins (I) अ.क्र. 25325344  
कोणट्या : ४१५ खोला  
अ.क्र. 07818400 मिमी रूपा 2000/5 अंमल
- फोन : श्री फोन्स  
एनर्जी मिटर बनावट : L & T Ltd  
मूळातील मिटर रिडींग : 000010.9
- मिटर गुणक : 400

मुंबई विद्युत का १९५० नियम क्रमांक ४ पुढील सदा जनित्रधारकाचा औद्योगिक वापर करणाऱ्या मुंबई विद्युत का कायदा १९५८ च्या अनुसूचीतील भाग "ब" जनित्र जोडणी करून घ्या बंधनकारक आहे. मुंबई विद्युत निरीक्षक निरीक्षण विभाग क. टाणे व का. विभाग, वागाडे इन्स्ट. टाणे या कार्यालयामार्फत याबाबत निरीक्षण शुल्क रु.6300/- पावती क्रमांक 0295787 दिनांक 5/3/08 अन्वये प्राप्त झाले आहे.



विद्युत निरीक्षक  
निरीक्षण विभाग क. टाणे

- पत्र : मुख्य अधिकारी, विद्युत, मा.क्र.विभाग चेम्बूर मुंबई-४० यांना माहितीसाठी संविधान सभेत  
पत्र : विद्युत का निरीक्षक, निरीक्षण विभाग क. टाणे यांना माहिती व वापर या कार्यालयामार्फत  
पत्र : कार्यालयीन मूळ नसतील.