

Cosmo/Waluj/16-17/MSEB/MERC/001

25th Jul 2017

To,
The Secretary
Maharashtra Electricity Regulatory Commission
13th Floor, Centre No.1, World Trade Centre, Cuffe Parade,
Colaba, Mumbai – 400 005

Sub: Suo-Motu proceedings for verification & compliance of RPO targets for FY 2010-11 to FY 2013-14 by obligated entities. (Case No. 101 of 2017)

Ref: 1. Your notice No. MERC/Case No. 101 of 2017/2017-18/3294 Dt. 23rd Jun 2017
2. Your notice No. MERC/Case No. 101 of 2017/2017-18/3759 Dt. 23rd Jun 2017

Dear Sir,


This is with reference to your notice vide under reference, we would like to inform you that there was no any interconnection between grid & our Captive Power Plant so being an **OFF GRID CAPTIVE POWER PLANT ENTITY**, this **RPO compliance** is not applicable to us.

Also we would like to bring your kind notice that it was also intimated to MEDA office earlier through letter & E-mail with copy of NOC from concerned Distribution Licensee vide Letter no. Cosmo/Waluj/13-14 / MSB / MEDA /001 Dt. 10th Jun 2013 and accordingly MEDA have considered us as **RPO Exempted CPP entity**. It is being confirmed from report downloaded from MEDA website. Pl. refer Sr.no. 145 highlighted with yellow mark text of the report. This report & our MEDA submitted letter are attached herewith for your reference.

This is for your kind information & official record pl.

Thanking you.

Regards,



(For COSMO FILMS LTD)



Cosmo Films Limited

B-14/8-9, MIDC Indl. Area, P.B. No. 964, P.O. Bajaj Nagar, Waluj, Aurangabad - 431136 (MS) India.

Phone : (240) 2554611-14, 2552582, Fax : (0240) 2554416, E-mail : info@cosmofilms.com

Cosmo/Waluj/13-14/MSB/MEDA/001

10th Jun 2013

To,
The General Manager(REC,R&D)
Maharashtra Energy Development Agency (MEDA)
Phase-1,MHADA Commercial Complex,2ND Floor,
Opp. Tridal Nagar, Yerwada, Pune-411 006


Ref: Your Letter BP/RPO-STSTUS/2013/2272 Dt. 23 May 2013

Dear Sir,

This is with reference to above letter & a meeting conducted Dt. 04.06.2013 at MEDA Office,
As per your directives given in the meeting, pl. find enclosed herewith the photocopy of NOC given by
MSEB Office. In this NOC, It is clearly mention that there is no interconnection between MSEB & CPP
installed at our premises.

This is for your kind information & official record pl.

Regards,
For Cosmo Films Ltd.


(Authorized Signatory)

08/01/2004

OFFICE NOTE

Sub :- Joint Inspection report of CPP Installed at M/S
Cosmo Films B-14/8 & 9 MIDC Waluj.

Ref :- 1. CE/AZ/IA/7073 dtd. 27 Nov 2003.
2. Co.Ord.Cell/Cosmo/000168 dtd. 2 Jan-2004.

As per the letter under reference No. 2 of CE(Comm) H.O. Mumbai. The Joint inspection was carried out on 07.01.04 regarding the Interconnection between MSEB & C.P.P. jointly with S.E. (Urban) O&M Circle & S.E. (Rural) O&M A'bad & Ex.Engineer Testing Division A'bad & Ex Engineer Urban Dn.No.I A'bad. It is observed that there is no interconnection between M.S.E.B. & C.P.P. Installed at M/S Cosmo films B-14/8 & 9 MIDC Waluj.

Hence, as per comm (Circular) No. 663 dtd. 05.10.2001, so long as the Industrial Units including its CPP & stand by generating sets is permitted to operate on stand alone basis & is not connected with M.S.E.B. grid. No demand charges will be payable to M.S.E.B. Hence additional demand charges should not be charged to M/S Cosmo Films.

Assistant Engineer (Comm)


1. Ex.Engr. (Adm), Urban Circle, A'bad. *He was not present for joint inspection*

Ex.Engr.(Testing), A'bad. *above*

3. Ex.Engr. (O&M) Urban Dn.No.I, A'bad. *2/1/04*

4. S.E. Rural Circle, A'bad.

5. S.E. Urban Circle, A'bad. *2/1/04*



MAHARASHTRA STATE ELECTRICITY BOARD

COMMERCIAL SECTION, 5TH FLOOR, PRAKASHGAD
BANDRA (EAST) MUMBAI 400 051.

Ph No. (P) 26474753, (O) 26474211, 26472131 FAX NO. 26472366

Ref. No. Co. Ord. Cell/Cosmo/ 0 0 0 1 6 8

- 2 JAN 2004

To:

The Superintending Engineer,
MSEB, Urban Circle,
AURANGABAD.

Sub: Regarding not paying 10% MD charges of existing CPP capacity.

- Ref: 1) CPP permission letter from CE (Commercial), Mumbai Ref. No. Co. Ord. Cell/CPP/Cosmo/3541 dated 01.02.2003.
2) Departmental Circular (Commercial) No. 663 dated 05.10.2001.
3) M/s. Cosmo Films Ltd.'s letter No. CFU/CPP/SRH/03/7291 dated 23.12.2003.

In this connection, copy of the letter under reference (3) is enclosed herewith.

You are requested to refer this office Departmental Circular (Commercial) No. 663 dated 5th October 2001 in which condition No. 4 is applied for application of 10% additional demand charges to CPP holders commissioned after the date of the said circular. Please visit the site, confirm the SLD and interconnection between MSEB and CPP jointly with SE TCC Nagpur and EE (I) Aurangabad and take the decision at your end accordingly as per the guidelines given in D.C. (Comm.) Circular No. 663 dated 05.10.2001.

Encl: as above.

Chief Engineer (Commercial)

Copy to:

- 1) The S.E., TCC, MSEB, Nagpur
- 2) The E.E. (T), MSEB, Aurangabad.
- 3) The E.E. (Urban) Dn. I, MSEB, Aurangabad.

} Alongwith enclosure.
} For information and
} necessary action please.

Copy f.w. to:

M/s. Cosmo Films Limited,
B-14/8&9, MIDC Industrial Area,
Bajaj Nagar,
P.O. Box No. 964,
Waluj, Aurangabad - 431 136.

For information. He is requested to contact our SE (Urban Circle) A'bad in this regard.
Deo/cosmo