

08/01/2004

**OFFICE NOTE**

Sub :- Joint Inspection report of CPP Installed at M/S  
Cosmo Films B-14/8 & 9 MIDC Waluj.

Ref :- 1. CE/AZ/IA/7073 dtd. 27 Nov 2003.  
2. Co.Ord.Cell/Cosmo/000168 dtd. 2 Jan-2004.

As per the letter under reference No. 2 of CE(Comm) H.O. Mumbai. The Joint inspection was carried out on 07.01.04 regarding the Interconnection between MSEB & C.P.P. jointly with S.E. (Urban) O&M Circle & S.E. (Rural) O&M A'bad & Ex.Engineer Testing Division A'bad & Ex Engineer Urban Dn.No.I A'bad. It is observed that there is no interconnection between M.S.E.B. & C.P.P. Installed at M/S Cosmo films B-14/8 & 9 MIDC Waluj.

Hence, as per comm (Circular) No. 663 dtd. 05.10.2001, so long as the Industrial Units including its CPP & stand by generating sets is permitted to operate on stand alone basis & is not connected with M.S.E.B. grid. No demand charges will be payable to M.S.E.B. Hence additional demand charges should not be charged to M/S Cosmo Films.

*(Signature)*  
Assistant Engineer (Comm)


*I was not present for Joint inspection  
on 07.01.04 with authority of CE*  
1. Ex.Engr. (Adm), Urban Circle, A'bad. *(Signature)*

Ex.Engr.(Testing), A'bad. *(Signature)*

3. Ex.Engr. (O&M) Urban Dn.No.I, A'bad. *(Signature)*

4. S.E. Rural Circle, A'bad.

5. S.E. Urban Circle, A'bad. *(Signature)*



# MAHARASHTRA STATE ELECTRICITY BOARD

COMMERCIAL SECTION, 5TH FLOOR, PRAKASHGAD  
BANDRA (EAST) MUMBAI 400 051.

Ph No. (P) 26474753, (O) 26474211, 26472131 FAX NO. 26472366

Ref. No. Co. Ord. Cell/Cosmo/ 000168

- 2 JAN 2004

To:

The Superintending Engineer,  
MSEB, Urban Circle,  
AURANGABAD.


Sub: Regarding not paying 10% MD charges of existing CPP capacity.

- Ref: 1) CPP permission letter from CE (Commercial), Mumbai Ref. No. Co. Ord. Cell/CPP/Cosmo/3541 dated 01.02.2003.  
2) Departmental Circular (Commercial) No. 663 dated 05.10.2001.  
3) M/s. Cosmo Films Ltd.'s letter No. CFL/CPP/SRH/03/7291 dated 23.12.2003.

In this connection, copy of the letter under reference (3) is enclosed herewith.

You are requested to refer this office Departmental Circular (Commercial) No. 663 dated 5<sup>th</sup> October 2001 in which condition No. 4 is applied for application of 10% additional demand charges to CPP holders commissioned after the date of the said circular. Please visit the site, confirm the SLD and interconnection between MSEB and CPP jointly with SE TCC Nagpur and EE (T) Aurangabad and take the decision at your end accordingly as per the guidelines given in D.C. (Comm.) Circular No. 663 dated 05.10.2001.

Encl: as above.

  
Chief Engineer (Commercial)

Copy to:

- 1) The S.E., TCC, MSEB, Nagpur
- 2) The E.E. (T), MSEB, Aurangabad.
- 3) The E.E. (Urban) Dn. I, MSEB, Aurangabad.

} Alongwith enclosure.  
} For information and  
} necessary action please.

Copy f.w. to:

M/s. Cosmo Films Limited,  
B-14/8&9, MIDC Industrial Area,  
Bajaj Nagar,  
P.O. Box No. 964,  
Waluj, Aurangabad - 431 136.

For information. He is requested to contact our SE (Urban Circle) A'bad in this regard.  
Deo/cosmo