



SHRADDHA HOUSE

CTS No. 1206/IIA, Plot No.887-A

Shirole Road, Off J. M. Road, Pune-411004

TEL.: (OFF) 30909913, 30947144, 30947145. FAX: (020) 25437960

REF.

DATE:

Date: 10-07-2017

MERC
Date 26/7/17
No. 7286

27/7/17

To,
Hon'ble Secretary
Maharashtra Electricity Regulatory Commission
World Trade Centre, Centre No.1,
13th Floor, Cuffe Parade,
Colaba, Mumbai-400005

Sub: Submission in Case No 101 of 2017

Ref : MERC Notice vide No MERC/Case No 101 of 2017/2017-18/3511 dtd 23rd June 2017

Dear Sir,

We, Sai Prem Developers has received the MERC notice as referred above in matter "Sou Mouto proceedings for Verification and Compliance of Renewable Purchase Obligations targets for FY 2010-11 to FY 2013-14 by obligated entities (Other than Distribution licensees)

We would like to submit that we have installed 2 X 0.8 MW = 1.6 MW wind mill at Rautwadi, Tal. Koregaon, Dist. Satara and Degaon, Tal. Wai., Dist. Satara which is renewable Energy Project. Being the Renewable Energy generator we do not fall under the definition of "Obligated Entities".

Maharashtra Energy Development Agency (MEDA) is the nodal agency for promotion of Renewable Energy in the state of Maharashtra. MEDA is well aware about the installation and list of RE projects in Maharashtra as they themselves gives permission for commissioning of the RE project. We are enclosing herewith the Commissioning Certificate issued by Maharashtra State Electricity Distribution Co Ltd (MSEDCL) wherein it is mentioned that our is a Wind Turbine Generator i.e Renewable Energy Generator.

Moreover the as per the data submitted by Maharashtra Energy Development Agency (MEDA) we have been shown as OA Consumer wherein our contract demand (which is related to consumer) of 2 MW is shown

Hence it is kindly requested to delete/remove our name from the list

For Sai Prem Developers

Partner

Documents Enclosed:

1. Commissioning certificate



MAHARASHTRA STATE ELECTRICITY DISTRIBUTION COMPANY LTD
O & M CIRCLE, SATARA

NO - SE/STRC/T - WM/ **12177**

Date: **7 OCT 2010**

To,
M/S Sai Prem Developers.
Shraddha House, CTS No - 1206/I/A,
Plot No - 887 - A,
Shirole Road, Off J.M. Road, Pune - 411004.

Sub : - Commissioning of your 2 X 800 KW Wind Turbine Generators

Ref : - 1) CE/STU/10546 DT 13-08-2008,
2) PGN-1/IC/ Sai Prem Developers /1.60 MW/10-11/3796 / 28-09-2010
3) PGN-1/CC/ Sai Prem Developers /1.60 MW/10-11/3847 / 29-09-2010
4) EI Satara/ 368 & 371 DT 08-09-2010
5) EE/TEST/STR/WM-NEW/1031 DT07-10-2010

2 X 800 KW Wind Turbine Generators in respect of M/S Sai Prem Developers are commissioned on 30-09-2010 in the presence of Ex.Engr-Testing Dn-Satara, representatives Executive Engineer Satara, & the representative of M/S Enercon & started supplying power to MSEDCL/MSETCL Grid as detailed under.

Sr. No.:	Make	Location	Type of Land/Gat No.	Village / Tal
91/8733 & 91/8746	Enercon	104	Forest(Comp)163 / 162	Rautwadi / Koregaon
			Forest(Comp) 160 / 959	Degaon / Wai
		107	Forest(Comp)160 / 895	Degaon / Wai
			Forest(Comp) 159 / 162	Rautwadi / Koregaon
Capacity	800 KW	Each		
Voltage :	433 V			
Frequency	50 C/S			
Feeder :	132/33 KV Chavaneshwar Feeder No - I			

The Details of common 33 KV O/H line & the common group Metering equipments already charged are as detailed here under :-

1) 33 KV over Head Line :- 28.80 kms. With Isolator & Circuit Breaker.

2) 33Kv Current Transformer :- For Metering [Main & Check Meter]

Main Meter

Check Meter

CT Ratio: 400/1 Amp

CT Ratio: 400/1 Amp

Make - Gyro Laboratories Pvt. Ltd.

Sr. No.: R = B - 01/10/1594/27-75

R = B - 01/10/1594/24-75

Y = B - 01/10/1594/26-75

Y = B - 01/10/1594/23-75

B = B - 01/10/1594/25-75

B = B - 01/10/1594/22-75

Cl. Accu : 0.2 S

Ownership : Consumer

Burden : 15 VA



For SAI PREM DEVELOPERS

[Signature]

PARTNER

3) 33KV Voltage Transformer :- For Metering [Main & Check Meter]
Main Meter Check Meter

Make - Gyro Laboratories Pvt. Ltd.
Sr. No.: R = B - 01/10/1594/60-75
Y = B - 01/10/1594/59-75
B = B - 01/10/1594/58-75

R = B - 01/10/1594/63-75
Y = B - 01/10/1594/62-75
B = B - 01/10/1594/61-75

PT Ratio : 33KV $\sqrt{3}$ /110Volts/ $\sqrt{3}$ /
Burden/Phase : 30 VA
Cl. Accu : 0.2 S Ownership : Consumer


Main Meter & Check Meter Details & Readings

TVS Meter : -

	<u>Main Meter</u>	<u>Check Meter</u>
Make	: Elster	Elster
Sr. No.	: 05117669	05117664
Type	: TOD - TVM	TOD - TVM
Cl. Accu.	: 0.2	0.2
M.F.	: 1000	

The initial Readings were taken before commissioning of above m/c & are shown as given below:

<u>Main Meter</u>	Parameters	<u>Check Meter</u>
2790.15060	Imp KWH	2792.52000
2880.09120	Imp KVAH	2882.52240
426.08460	I RKVAH G	425.84880
19.56660	I RKVAH D	19.76700
35.14440	Exp KWH	35.14200
39.76800	Exp KVAH	39.75840
18.69840	E RKVAH D	18.79560
12.32100	E RKVAH G	12.31560


Superintending Engineer (STRC)
MSEDCL Circle Office, Satara.

Copy s.w.r.To:

- 1) The Director (Operation) H.O. Bandra (E) Mumbai.
- 2) The Director General MEDA, Pune.
- 3) The Chief Engineer (BMT) Baramati.

Copy To:

- 1) The Ex. Engineer O & M Dn Satara
- 2) The Ex. Engineer Testing Dn Satara.
- 3) The Dy Exe. Engineer WM Sub. Dn Satara.
- 4) M/S Enercon (I) Ltd. Satara.



For SAI PREM DEVELOPERS


PARTNER