



Office of the Chief Engineer (Commercial)  
Maharashtra State Electricity Distribution Co. Ltd.  
"Prakashgad", 6th Floor, Station Road, Bandra (E), Mumbai -400 051.  
Tel.: (P) 26474753, (O) 26474211, Fax: (022) 26472368  
Email: cecomm@mahadiscom.in, Website: www.mahadiscom.com

CP/WIND/OA/ Self Use/

No 17993

Date : 28 JUN 2012

To  
M/s Uni Deritend Limited,  
Liberty Building, 3rd floor, New Marine Lines,  
Mumbai-400 020

Sub : Open Access Permission for Self Use of Wind Energy.

Ref : Application from M/s Uni Deritend Limited dated 15.01.12.

Dear Sir,

With reference to the above subject, this office is in receipt of your office application for grant of Open Access Permission for Self use of 2.4 MW power.

In this regard, this is to inform that the competent authority has granted open access permission for a period as detailed below:

1. Name of RE Generator & Address (Injection point) Location / Metering Point No. : Voltage level : Name of Sub-station and Feeder :	Uni Deritend Limited Varekarwadi, satara 6183 33kV Varekarwadi
2. Capacity applied for Open Access ( MW):	2.4 MW
3. Period for Open Access :	01.02.12 to 31.01.13
4. Name of User / OA Consumer and Address (Drawl point): Consumer No: Voltage level: Contract Demand:	Uni Deritend Limited, G. no. 496 Shinde, Tal-Nasik, Dist. Nasik 049019017220 33 kV 1600 KVA
5. Date on which present agreement for supply is to be terminated:	N.A.
6. Non-refundable Processing Fee : Paid vide Demand Draft No. & Date : Bank Name / Branch :	Rs. 15000 /- 086503 dated 09.12.11 Axis bank

NOTE:- This Open Access Permission is granted from the next billing month from the date of receipt of your Open Access application to this office.

This open access permission will be subject to the terms and conditions which are enclosed. This is for your information please.

Thanking you,

Yours faithfully,

Chief Engineer [Commercial]

Copy s.w.r. to :

The Executive Director [Commercial], MSEDCL, Mumbai.

Copy s.w.r.to:

The Chief Engineer, O&M Zone, MSEDCL, Baramati/ Nasik

Copy to: The Superintending Engineer, O&M Circle, MSEDCL, Satara/ Nasik Urban

### Open Access Permission for Self Use of Wind Energy

#### Terms and Conditions:

- 1) The Superintending Engineer, MSEDCL O & M Circle, Satara / Sangli / Ahmednagar/ Beed /Dhule /Nandurbar / Kudal / Amaravati / Nashik etc., where the wind mill is situated, shall be the Nodal Officer.
- 2) The Nodal Officer shall co-ordinate with all concerned i.e. with MSEDCL/MSETCL authorities and the consumer in order to ensure smooth techno-commercial operation of the system and will issue credit note.
- 3) The RE Generator is permitted for Self Use of Renewable Power for the period specified in the permission subject to the provisions laid down in Electricity Act 2003 , MERC Distribution & Transmission Open Access Regulation 2005 & relevant MERC Orders.
- 4) This permission for Open Access will be for a period of maximum one year or as per your request whichever is earlier. If you want to continue the option for further period or change the option, you will have to apply again as per MSEDCL procedure for Open Access in the prescribed format viz. the Application Format for Open Access available on MSEDCL website: [www.mahadiscom.in](http://www.mahadiscom.in).
- 5) The RE Generator shall pay Open Access Charges as per MERC (Distribution & Transmission Open Access) Regulations, 2005 and further MERC tariff orders issued from time to time.
- 6) The units offered for wheeling shall be as under :
  - i) The power utilized (MSEDCL Power) for Restart up (Auxiliary consumption) of Generator i.e. Export Power (Supplied by MSEDCL) shall be billed as per Temporary Tariff applicable from time to time.
  - ii) Wind Generation units delivered into the grid i.e. Import Power [Received at MSEDCL Grid] shall be considered as units offered for wheeling and thereafter the applicable wheeling Losses and transmission losses will be deducted from these import units. Balance units will be considered as units for credit.
- 7) The credit notes shall be released only after payment of applicable Wheeling Charges and Transmission Charges and after deducting applicable losses (Wheeling Loss and Transmission loss) for giving credit adjustment in accordance with the MERC Tariff Orders for MSEDCL & MSETCL issued from time to time.
- 8) After recovering Wheeling charges and transmission charges and deducting applicable Wheeling loss and transmission loss, the Nodal Officer will send credit notes to the respective O&M Circle offices where the self use consumer is located, for giving necessary TOD slot wise credit adjustment in the monthly energy bill.
- 9) The RE Generator shall pay Additional surcharge on wheeling charges on case to case basis as may be applicable from time to time.
- 10) The RE Generator shall pay following charges to MSEDCL :
  - i) Administrative Charges : Rs. 50000/- per annum in lump-sum shall be paid within a month from date of receipt of this NOC or date of commencement of Open Access Period
  - ii) Operating Charges: Upto 5 MW - Rs. 10000/- and  
More than 5 MW upto 20MW -- Rs. 20000/-

#### 11) Metering:

As provided under Regulation No. 7.1 of the MERC (Distribution Open Access) Regulations, 2005, every consumer, person who so ever has been granted Open Access or Generating Company or Licensee shall have to install "Special Energy Meter" at both the ends, i. e. at injection point & drawal point.

As provided under Regulation 2 (n) of the MERC (Distribution Open Access) Regulations, 2005, such "Special Energy Meter" shall have facility of active energy recording of every fifteen minute time block

and storage of data for not less than 45 days and shall have communication facility online and/or real time.

Till installation of Special Energy Meter, the energy accounting and billing will be carried out on the basis of existing TOD time slots.

12) **Reduction In Contract Demand:**

As provided under Regulation 4.2.1 & 4.2.2 of MERC (Distribution Open Access) Regulations, 2005, the Contract Demand of the consumer who so ever may opt for the Distribution Open Access shall deemed to be reduced to the extent (in MW terms) such consumer has been granted permission to wheel energy under Open Access from the date of commencement of open access.

13) In the event of termination of contracted demand as per Reg. 4.2.1, the Self Use consumer will be charged at Temporary tariff to the extent he uses MSEDCL supply.

14) **Connection and use of distribution system agreement:**

The RE Generator / Supplier and the Open Access consumer shall execute a Connection and Use of Distribution System Agreement with MSEDCL as per Regulation No. 5 of MERC (Distribution Open Access) Regulations, 2005.

15) **Incentives And Penalties:-**

a) Whenever a consumer opts for Distribution Open Access for his entire requirement of load such consumer shall not be eligible for Incentive like Load Factor Incentive, Power Factor Incentive, Early Payment Incentive or any such other incentive applicable as per MERC tariff order for MSEDCL consumers, as it ceases to be a MSEDCL consumer.

b) Whenever a consumer opts for Distribution Open Access for his partial requirement of load, such consumer shall be eligible for incentives, which may be applicable as per MERC tariff order for MSEDCL consumers, only to the extent it uses MSEDCL supply.

c) The RE Generator/OA Consumer shall maintain the average power factor of his load at levels prescribed by the Indian Electricity Rules, 1956 with such variations, if any, adopted by MSEDCL in accordance with Rule 27 of the Indian Electricity Rules, 1956 and in accordance with the relevant orders of the Commission (MERC).

d) The RE Generator/OA Consumer shall be liable to pay the penalty charges which may be applicable as per MERC tariff order, amended from time to time, if the power factor is not maintained at required level as per State Grid Code


e) The RE Generator/OA Consumer shall control harmonics of his load at levels prescribed by the IEEE STD 519-1992, and in accordance with the relevant orders of the Commission (MERC). Penalty for harmonics will be charged in accordance with relevant orders of the Commission (MERC).

16) The RE Generator/OA Consumer shall provide security if required as per Regulation 9 of MERC (Distribution Open Access) Regulations, 2005.

17) The RE Generator/OA Consumer shall pay all the dues to MSEDCL Field Office. Also, the Generator shall pay all the Charges / Duties, if any, levied by any statutory Authority from time to time at his end.

18) The RE Generator/OA Consumer shall abide by EA - 2003, MERC ( Transmission and Distribution Open Access ) Regulation 2005 and State Grid Code and all terms and conditions / Orders issued by MERC / MSEDCL/ MSETCL/ Chief Engineer (SLDC), Kalwa from time to time.

19) The RE Generator/OA Consumer shall obtain the clearances, if any, from the statutory Authorities such as Government of Maharashtra, Electrical Inspector of the area, Chief Engineer (SLDC) Kalwa and C.E. (STU), MSETCL, etc. at his end.

  
Chief Engineer (Commercial)



**MAHA**

Maharashtra State Electricity Distribution Co. Ltd.

Office of the Chief Engineer (Commercial)  
Maharashtra State Electricity Distribution Co. Ltd.  
"Prakashgad", 5th Floor, Station Road, Bandra (E), Mumbai - 400 050  
Tel.: (P) 26474753, (O) 26474211, Fax: (022) 26472366  
Email: [cecomm@mahadiscom.in](mailto:cecomm@mahadiscom.in), Website: [www.mahadiscom.in](http://www.mahadiscom.in)

Comm/ CP/ Wind

Date: 24 JUL 2012

To  
The Superintending Engineer,  
O&M Circle, MSEDCL,  
Satara.

No 21212 *lu*  
*24*

Sub: Corrigendum to open access Permission for Self Use of Wind Energy in respect of M/s Uni Deritend Limited.

Ref: 1) T. O. L. No. CP/Wind/OA/Self Use/ 17993 dated, 28.06.12  
2) Letter dated 09.07.12 from M/s Uni Deritend Limited.

With respect to above subject, vide letter under reference (1) open access Permission for Self Use of Wind Energy was issued by this office to M/s Uni Deritend Limited, Capacity 2.4 MW at site Varekarwadi, Dist.- Satara, Metering Point No. 6183.

However, vide letter under reference (2) the wind generator submitted that the OA period mentioned in NOC was not correct.

The matter is verified at this office and accordingly, this is to inform that the Period for Open Access in the letter under reference (1) shall be read as 01.01.12 to 31.12.12 instead of 01.02.12 to 31.01.13 for the above said generator.

All other terms and conditions of the NOC will remain unchanged.

This is for your information and further necessary action please.

*5*  
Chief Engineer (Commercial)

Copy s. w. r. to:

The Executive Director (Commercial), MSEDCL, Mumbai.

Copy f.w.c. to:

The Chief Engineer, MSEDCL, O & M Zone, Baramati.

Copy to:

M/s Uni Deritend Limited, Liberty Building, 3rd floor, New Marine Lines,  
Mumbai-400 020