

EE/Shrirampur/Tech/3645

Date: 23/8/13

To,
The Tilak Nagar Industries Ltd
Tal Shrirampur Dist Ahmednagar.

Sub: - Certificate for Non Grid connection

Ref : YOL TI/WKS/ELE/2013/14/1204 Dtd 22/08/2013

With ref to the above sub inspection carried out & it is to certify that following mentioned electric generating plant(CPP) is not connected with MSEDCL grid ,authorized distribution agency MSEDCL .

This certificate is issued as per their above ref application .

List of CPP as mentioned below

- 1)1010 KVA DG set : Sr no 37121, Mk :- Cummins India Ltd
Model:-KTA-38-G5
- 2)1010 KVA DG set:- Sr no 37176, Mk :- Cummins India Ltd
Model:- KTA-38-G5
- 3)5 Mw Steam Turbine:-Sr no :-71 Mk :- Maxwatt
Model:- PGSB-500
- 4)Bio Gas Engine :-Sr no 70201701:- Mk Schmittenertec
347 KW
- 5) Bio Gas Engine :-Sr no 70201703:- Mk Schmittenertec
347 KW

All above connections are not connected with MSEDCL grid .

सिद्ध
Executive Engineer
M.S.E.D.C.L. Division Office
Shrirampur