

MAHARASHTRA STATE ELECTRICITY BOARD
O & M DIVISION, KARAD

EE/KRD/T/ JE III / UDL (4 X 600 KW) /

DATE-

15 JAN 2002

To,

No 00433

The Superintending Engineer,
M.S.E.B. O & M Circle,
Satara.

Sub- Commissioning of 4 X 600 KW Wind electric generators in
respect of M/s. Uni Deritend Ltd, Mumbai at Site Varekarwadi,
Taluka - Patan, Dist.- Satara.

- Ref- 1) NOC from M.S.E.B H.O.NO. Co-Ord Cell/ Wind/ Uni Deritend
/ 47525 Dtd. 24 Dec 2001.
2) NOC from MEDA WFP / A-15 / P:2001-2002 / 4718
Dtd. 26 Dec 2001
3) SE / STRC / T / UDL (4 X 600 KW) / 9506
Dtd. 26 Dec 2001
4) SE / STRC / T / UDL (4 X 600 KW) / 09752
Dtd. 29 Dec 2001.
5) TM-4 Form DYEE / KRD / CSD / 351 Dtd. 26 Dec 2001.
6) EE / KRD / T / JE III / 10403 Dtd. 31 Dec 2001.

With reference to the above subject this is to inform you that Enercon Make
4 X 600 KW Wind electric generator in respect of M/s. Uni Deritend Ltd, Site-
Varekarwadi, Taluka-Patan, Dist- Satara has been commissioned after
completing all the formalities as per Boards rule on 31 Dec 2001 in presence of
Representative of Executive Engineer (O&M Dn.), Karad (J.E (CSD), Karad)
& Representative of Executive Engineer (Testing), Satara (Assistant
Engineer (Testing), Satara)

1) 33 KV S/c Line - 0.36 Kms

- 2) C.T Details - Ratio 50 / 5 Amp.
VA/Class - 15 / 0.5
Sr.No. (R Phase) - 14595
(Y Phase) - 14596
(B Phase) - 14597
Ownership - Consumers



3) P.T. Details - Ratio $33000 / \sqrt{3} / 110 / \sqrt{3}$ Volts.
VA/Class - 100 / 0.5

Sr.No. (R Phase) - 3118
(Y Phase) - 3119
(B Phase) - 3120
Ownership - Consumers.

4) The T.V Meter Make- Duke-Amics Hyderabad ,
Sr.No.- 52720 , Type- MPC3
Voltage Rating - 11000 / 110 Volts.
Current Rating - 5/5 Amp.
M.F for Units -30
Ownership - Consumers.

Reading on 31 Dec 2001 - @ 18:45 Hrs.

I (Import to MSEB)

I Kwh-129
I kvarhG- 70.1
I KvarhD- 0.0
I Kvah- 148.7
I Cm - 0.0
I Cum -185.4

X (Export to MSEB)

X Kwh - 56.7
X KvarhG-27.5
X KvarhD- 0.0
X Kvah- 63.1
X Cm -0.0
X Cum - 95.7

This is for your favour of information & further needful please .

Executive Engineer
(O & M Division), Karad

Copy. f.w.c.s. to -

- 1) The Executive Engineer (Testing Div.) , MSEB , Satara.
- 2) M/s. Uni Deritend Ltd , Mumbai.

Copy to -

- 1) The Dy EE CSD, MSEB , Karad.
- 2) The Assistant Engineer (S/Dn) , MSEB , Karad-I
- 3) M/f.

TRUE COPY

O. P. NIGAM
NOTARY (Govt. of India)
Regd. No. 816
Mumbai, Maharashtra.

.1 2 JUN 2012