



Elect/NM/MERC/001-2017

SI Group – India Private Limited
Registered Office & Navi Mumbai Unit
Plot No. D-2/1 TTC Industrial Area
Opp. Juinagar Railway Station
Thane Belapur Road
Turbhe, Navi Mumbai - 400705
T. +91.22.6673 2000
F. +91.22.2767.1848
www.siigroup.com

Date: - 29.06.2017
CIN: U99999MH1963PTC012674

To,
The Secretary,
Maharashtra Electricity Regulatory Commission
13th Floor, Centre No. 1,
World trade Centre,
Cuff parade, Colaba,
Mumbai - 400005

Subject: Your letter MERC/Case.101 of 2017/2017-18/3262 Dated 23rd June 2017 pertaining to RPO targets by Obligated Entities (Ref: Re-validation Report submitted by MEDA vide letter No BP/RPO status/CR-116/2015-16/391 dt: 30/1/2016)

Dear Sirs,

With reference to your above letter dated 23rd June 2017, we wish to re-iterate the following:

1. We, SI Group India Private Ltd, Navi Mumbai have a Co-Generation Power plant generating maximum up to 4.2 MW. Our Co-Gen power plant does not cater to entire power requirement of the plant. We run our Co-Gen power plant depending on plant requirement in island mode to the capacity of 4.2 MW & balance requirement is met with MSEDCL network.
2. Our **Co-Gen power plant is not grid connected** & we synchronise our Co-Gen plant with MSEDCL network **momentarily** only during transfer of load from Co-Gen generator to MSEDCL grid. In support of this statement, please see the letter dated 2nd May 1998 sent by the Superintending Engineer (TCC), Pune II of MSEDCL to The Chief Engineer (Dist), MSEDCL, Mumbai acknowledging the said fact.
3. In view of above, we are not covered under the definition of "Obligated Entities" being an "Off-Grid Co-generation Power Plant". Hence we do not fall in the category for RPO targeted Entities as per RPO Regulation 2010.

(Continued on next page...)

Handwritten signature and date 24/6/17.




SI Group – India Private Limited
Registered Office & Navi Mumbai Unit
Plot No. D-2/1 TTC Industrial Area
Opp. Juinagar Railway Station
Thane Belapur Road
Turbhe, Navi Mumbai - 400705
T. +91.22.6673.2000
F. +91.22.2767.1848
www.siigroup.com

CIN: U99999MH1963PTC012674

4. The Captive Power Producers Association (CPPA) along with Century Rayon and Uttam Galva have moved MERC pleading for Exemption from RPO for Captive Power Producers. Already MERC has heard the matter while reserving its ORDER in the matter.

We, therefore request you to delete our name from the list of Obligated Entities for RPO obligations in your records and update M/s MEDA and us accordingly.

Thanking you,
Yours faithfully,


Mr. Sanjay S. Borwankar,
Vice-president - Operations
SI Group - India Private Ltd.
Navi Mumbai


Encl: Copy of MSEB letter no. SE/TCC/PN/I/Co-generation/293 dated 2nd May 1995.



MAHARASHTRA STATE ELECTRICITY BOARD

Testing & Communication Circle

Phone Nos.

- 27725 637525
- 27532 637532
- 346386 371231

600
20.6
DATE -

Block No. 403, 3rd floor
ADM Building Rasta Path,
Pune - 411 011.

SK/CC/PN/ I/Co-generation/293

Date

2 MAY 1998

To

The Chief Engineer (Dist.),
M.S.E.B. Board,
Mumbai.

Sub : Co-generation in respect of M/s.
Herdillia Chemical Ltd. Washi.

Ref : T.O. Letter No. SK/CCP/I/Co.gen./
0197 dt. 1 April 1998.

.....

The undersigned has visited the Electrical Installation of M/s. Herdillia Chemical Ltd. Washi on 22.4.98 along with Executive Engineer (Testing) Washi and have checked the 5 MW co-generation system. The synchronising arrangement for following option was checked.

- 1) Total load on M.S.E.B.
- 2) Major load on Generator (4 MW) and partial load (0.5 MW) on M.S.E.B.
- 3) Generator and M.S.E.B. in parallel.

The system arrangement for option (II) is in order. We have suggested few interlocks for both M.S.E.B. and generator in parallel. It is learnt from factory authority that synchronising with M.S.E.B. will be done only during transferring or load from Generator to M.S.E.B. Board grid. The synchronising arrangement provided for this purpose is adequate. Hence proposal of co-generation for above purpose may be permitted.

Superintending Engineer (TCC)
Pune.

Copy to : The Executive Engineer (Testing) Washi

S. E. DIST.
Inward No. 331/1
DATE 20/6/98
R.E. D. 1/

(S.E. DIST.) mpd/
20/6/98