

BEFORE THE MAHARASHTRA ELECTRICITY REGULATORY COMMISSION

WORLD TRADE CENTRE, CENTRE NO.1,

13th FLOOR,

CUFFE PARADE, MUMBAI 400005

CASE NO. 182 OF 2014

IN THE MATTER OF:

The Tata Power Company Limited

... Petitioner

Versus

BEST Undertaking & Ors.

... Respondents

Brief Summary of comparison of Network Rollout Plans submitted by Tata Power

Particulars	Unit	FY 2014-15 to FY 2018-19 (5 years)		FY 2014-15 to FY 2020-21 (7 years)	
		Business Plan - April 2014 Case No. 90 of 2014	Revised Network Rollout - Oct 2014	Revised Network Rollout - Oct 2014	Revised Network Rollout - Feb 2015 (Post Appeal 246 Judgment)
No of DSS	Nos	17	20	28	22
Power transformers Capacity (DSS)	MVA	680	800	1120	540
33 KV HT Network	Km	255	200	280	220
11 KV Network	Km	1360	630	900	432
No of CSS (11/0.4 or 22/0.4)	Nos	408	665	1000	904
CSS (MVA)	MVA	408	665	1000	739
LT Mains Cable	Km	2040	1925	2455	509
Total Capex	Rs. Crore	1879	2060	2845	1380

Submitted in Court on 12/08/2015 @ 11:45 am.