



New Connection Inspection of Premises

(Regulation 4.3 of MERC, Standards of Performance Regulations, 2014)

	Quarter	SOP Regulation No.	Parameters	Area	Pending Compliant Nos	Complaints In Current Qtr.	Total Complaints	With In Standard Of Performance	More Than Stipulated Time	Total Complaints Redressed	Pending Complaints End Of the Qtr
		a	b	c	d	e	f=d+e	g	h	l=g+h	j=f-i
1	Q3_FY 16-17										138
	Q4_FY 16-17	4.3	New Connection Inspection of Permises	Urban	138	7410	7548	7403	0	7403	145



Intimation of Charges Where Supply From Existing Lines

(Regulation 4.4 of MERC, Standards of Performance Regulations, 2014)

	Quarter	SOP Regulation No.	Parameters	Area	Pending Compliant Nos	Complaints In Current Qtr.	Total Complaints	With In Standard Of Performance	More Than Stipulated Time	Total Complaints Redressed	Pending Complaints End Of the Qtr
		a	b	c	d	e	f=d+e	g	h	l=g+h	j=f-i
2	Q3_FY 16-17										8
	Q4_FY 16-17	4.4	Intimation of Charges where supply from existing Lines	Urban	8	238	246	196	0	196	50



Intimation of Charges where supply to dedicated or after extension/augmentation

(Regulation 4.5 & 4.6 of MERC, Standards of Performance Regulations, 2014)

	Quarter	SOP Regulation No.	Parameters	Area	Pending Compliant Nos	Complaints In Current Qtr.	Total Complaints	With In Standard Of Performance	More Than Stipulated Time	Total Complaints Redressed	Pending Complaints End Of the Qtr
		a	b	c	d	e	f=d+e	g	h	l=g+h	j=f-i
3	Q3_FY 16-17										166
	Q4_FY 16-17	4.5 & 4.6	Intimation of Charges where supply to dedicated or after extension/augmentation	Urban	166	7095	7261	7232	0	7232	29



New Connection where supply from Existing Line

(Regulation 4.7 of MERC, Standards of Performance Regulations, 2014)

	Quarter	SOP Regulation No.	Parameters	Area	Pending Compliant Nos	Complaints In Current Qtr.	Total Complaints	With In Standard Of Performance	More Than Stipulated Time	Total Complaints Redressed	Pending Complaints End Of the Qtr
		a	b	c	d	e	f=d+e	g	h	l=g+h	j=f-i
4	Q3_FY 16-17										39
	Q4_FY 16-17	4.7	New Connection where supply from existing line	Urban	39	166	205	161	0	161	44



New Connection where supply after extension/augmentation

(Regulation 4.8 of MERC, Standards of Performance Regulations, 2014)

	Quarter	SOP Regulation No.	Parameters	Area	Pending Compliant Nos	Complaints In Current Qtr.	Total Complaints	With In Standard Of Performance	More Than Stipulated Time	Total Complaints Redressed	Pending Complaints End Of the Qtr
		a	b	c	d	e	f=d+e	g	h	l=g+h	j=f-i
5	Q3_FY 16-17										3926
	Q4_FY 16-17	4.8	New Connection where supply after extention/augentation	Urban	3926	2090	6016	2688	0	2688	3328



New Connection where supply after commissioning of Sub-Station

(Regulation 4.9 of MERC, Standards of Performance Regulations, 2014)

	Quarter	SOP Regulation No.	Parameters	Area	Pending Compliant Nos	Complaints In Current Qtr.	Total Complaints	With In Standard Of Performance	More Than Stipulated Time	Total Complaints Redressed	Pending Complaints End Of the Qtr
		a	b	c	d	e	f=d+e	g	h	l=g+h	j=f-i
6	Q3_FY 16-17										4598
	Q4_FY 16-17	4.9	New Connection where supply after after commissioning of Sub-Station	Urban	4598	2038	6636	2357	0	2357	4279



Shifting of Meter/Service Line

(Regulation 4.12 of MERC, Standards of Performance Regulations, 2014)

	Quarter	SOP Regulation No.	Parameters	Area	Pending Compliant Nos	Complaints In Current Qtr.	Total Complaints	With In Standard Of Performance	More Than Stipulated Time	Total Complaints Redressed	Pending Complaints End Of the Qtr
		a	b	c	d	e	f=d+e	g	h	l=g+h	j=f-i
7	Q3_FY 16-17										23
	Q4_FY 16-17	4.12	Shifting of Meter/ Service Lane	Urban	23	12	35	4	0	4	31



Reconnection of Supply after Payment of Dues

(Regulation 6.10 of MERC, Standards of Performance Regulations, 2014)

Sr. No	Month	SOP Regulation No	Parameters	Area	Pending Complaints Nos (Reconnection Requests)	Complaints in Current Qtr (Reconnection Requests)	Total Complaints (Total Reconnection Requests)	No. of Complaints Addressed			Pending complaints at the end of Qtr
								Within standards of Performance	More than stipulated Time	Total Complaints Addressed	
		a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i
8	January	6.10	Reconnection of supply after payment of dues	Class- I Cities/Urban	0	688	688	580	108	688	0
8	February	6.10	Reconnection of supply after payment of dues	Class- I Cities/Urban	0	588	588	501	87	588	0
8	March	6.10	Reconnection of supply after payment of dues	Class- I Cities/Urban	0	674	674	611	63	674	0



Change of Name

(Regulation 4.13 of MERC, Standards of Performance Regulations, 2014)

Sr. No	Quarter	SOP Regulation No.	Parameters	Area	Pending Compliant Nos	Complaints In Current Qtr.	Total Complaints	With In Standard Of Performance	More Than Stipulated Time	Total Complaints Redressed	Pending Complaints End Of the Qtr
		a	b	c	d	e	f=d+e	g	h	l=g+h	j=f-i
9	Q3_FY 16-17										240
	Q4_FY 16-17	4.13	Change of Name	Urban	240	4970	5210	5025	0	5025	185



Change of Category

(Regulation 4.13 of MERC, Standards of Performance Regulations, 2014)

Sr. No	Quarter	SOP Regulation No.	Parameters	Area	Pending Compliant Nos	Complaints In Current Qtr.	Total Complaints	With In Standard Of Performance	More Than Stipulated Time	Total Complaints Redressed	Pending Complaints End Of the Qtr
		a	b	c	d	e	f=d+e	g	h	l=g+h	j=f-i
10	Q3_FY 16-17										17
	Q4_FY 16-17	4.13	Change of Category	Urban	17	98	115	106	0	106	9



Complaint of Voltage Variation-Local fault

(Regulation 5.4 (a) of MERC, Standards of Performance Regulations, 2014)

	SOP Regulation No.	Parameters	Area	Pending complaint Nos. (Previous Quarter)	Complaints in current Qtr.	Total Complaints	No. of Complaints addressed			Pending complaints at end of Qtr.
							Within standard of Performance	More then stipulated time	Total complaints redressed	
	a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i
11	5.4 (a)	Complaint of Voltage Variation-Local fault	Class-I Cities/Urban	0	133	133	133	0	133	0



Complaint of Voltage Variation-Net work

(Regulation 5.4 (b) of MERC, Standards of Performance Regulations, 2014)

Sr. No.	SOP Regulation No.	Parameters	Area	Pending complaint Nos. (Previous Quarter)	Complaints in current Qtr.	Total Complaints	No. of Complaints addressed			Pending complaints at end of Qtr.
							Within standard of Performance	More then stipulated time	Total complaints redressed	
	a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i
12	5.4 (b)	Complaint of Voltage Variation-Net work	Class-I Cities/Urban	0	0	0	0	0	0	0



Complaint of Voltage Variation-Expansion/Augmentation

(Regulation 5.4 (c) of MERC, Standards of Performance Regulations, 2014)

Sr. No.	SOP Regulation No.	Parameters	Area	Pending complaint Nos. (Previous Quarter)	Complaints in current Qtr.	Total Complaints	No. of Complaints addressed			Pending complaints at end of Qtr.
							Within standard of Performance	More then stipulated time	Total complaints redressed	
	a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i
13	5.4 (c)	Complaint of Voltage Variation - Expansion/ augmentation required		0	0	0	0	0	0	0



Fuse off call

(Regulation 6.1 of MERC, Standards of Performance Regulations, 2014)

	SOP Regulation No.	Parameters	Area	Pending complaint Nos. (Previous Quarter)	Complaints in current Qtr.	Total Complaints	No. of Complaints addressed			Pending complaints at end of Qtr.
							Within standard of Performance	More then stipulated time	Total complaints redressed	
	a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i
14	6.1	Fuse off call	Class-I Cities/Urban	0	3393	3393	354	3039	3393	0



Break down of Over head Line

(Regulation 6.2 of MERC, Standards of Performance Regulations, 2014)

Sr. No.	SOP Regulation No.	Parameters	Area	Pending complaint Nos. (Previous Quarter)	Complaints in current Qtr.	Total Complaints	No. of Complaints addressed			Pending complaints at end of Qtr.
							Within standard of Performance	More then stipulated time	Total complaints redressed	
	a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i
15	6.2	Break down of Over head line	Class-I Cities/Urban	0	0	0	0	0	0	0



Underground Cable fault

(Regulation 6.3 of MERC, Standards of Performance Regulations, 2014)

	SOP Regulation No.	Parameters	Area	Pending complaint Nos. (Previous Quarter)	Complaints in current Qtr.	Total Complaints	No. of Complaints addressed			Pending complaints at end of Qtr.
							Within standard of Performance	More then stipulated time	Total complaints redressed	
	a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i
16	6.3	Underground cable fault	Class-I Cities/Urban	0	5740	5740	2140	3600	5740	0



Transformer Failure

(Regulation 6.4 of MERC, Standards of Performance Regulations, 2014)

	SOP Regulation No.	Parameters	Area	Pending complaint Nos. (Previous Quarter)	Complaints in current Qtr.	Total Complaints	No. of Complaints addressed			Pending complaints at end of Qtr.
							Within standard of Performance	More then stipulated time	Total complaints redressed	
	a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i
17	6.4	Transformer Failure	Class-I Cities/Urban	0	86	86	55	31	86	0



Meter Reading

(Regulation 7.2 of MERC, Standards of Performance Regulations, 2014)

Sr. no.	SOP Regulation no.	Parameters	Area	Pending complaints nos. (Previous Quarter)	Complaints in Current Qtr	Total Complaints	Within Standards of performance	More than stipulated time	Total complaints redressed	Pending Complaints at end of Qtr
	a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i
18	7.2	Meter Reading		0	0	0	0	0	0	0



Replacement of Faulty Meter

(Regulation 7.3 of MERC, Standards of Performance Regulations, 2014)

Sr.no.	SOP Regulation no.	Parameters	Area	Pending complaints nos. (Previous Quarter)	Complaints in Current Qtr	Total Complaints	Within Standards of performance	More than stipulated time	Total complaints redressed	Pending Complaints at end of Qtr
	a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i
19	7.3	Replacement of faulty meter	Class I Cities	0	24	24	24	0	24	0



Replacement of Burnt Meter

(Regulation 7.4 of MERC, Standards of Performance Regulations, 2014)

Sr.no.	SOP Regulation no.	Parameters	Area	Pending complaints nos. (Previous)	Complaints in Current Qtr	Total Complaints	Within Standards of performance	More than stipulated time	Total complaints redressed	Pending Complaints at end of Qtr
	a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i
20	7.4	Replacement of Burnt meter	Class I Cities	0	100	100	99	0	99	1



Billing Complaint

(Regulation 7.6 of MERC, Standards of Performance Regulations, 2014)

Sr. No.	SOP Regulation No.	Parameters	Area	Pending Complaint nos. (Previous Quarter)	Complaints in current Quarter (Q3)	Total Complaints	No. of Complaints addressed			Pending complaints at end of Qtr.
							Within standards of Performance	More than stipulated time	Total Complaints redressed	
	a	b	c	d	e	f=d+e	g	h	l=g+h	j=f-i
21	7.6	Billing Complaint	All zones	0	59	59	59	0	59	0



Annexure-III

Report of action on Faulty Meters (1 Phase / 3 Phase)

Format for quarterly return to be submitted to the Commission by the Distribution Licensee
(MERC, Standards of Performance Regulations, 2014)

Sr. no.	Name Of Distribution Licensee	Ref. to overall standards	Faulty meters at start of quarter (Nos.)	Faulty meters added during quarter (Nos.)	Total Faulty Meters (Nos.)	Meters rectified/ replaced (Nos.)	Faulty meters pending at end of quarter (Nos.)
1	Tata Power		9	932	941	927	14



Annexure-IV

Performance Report regarding Reliability Indices

(1) System Average Interruption Duration Index (SAIDI)

(Regulation 10 of MERC, Standards of Performance Regulations, 2014)

Sr. No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri= Restoration time for each interruption event on ith feeder	Nt=Total number of consumers of the distribution Licensees area	Sum (Ri*Ni) for all feeders excluding agri. Feeders)	SAIDI = 6/5
1	2	3	4	5	6	7
1	Jan-17	761	45.00	102823	34245	2.28
2	Jan-17	426	23.02	102823	9808	0.35
3	Jan-17	18	13.72	102823	247	0.03
4	Jan-17	1866	15.75	102823	29386	1.03
5	Jan-17	959	25.00	102823	23975	0.81
6	Jan-17	66	15.00	102823	990	0.14
7	Jan-17	1146	32.14	102823	36835	1.30
8	Jan-17	47	16.00	102823	752	0.10
9	Jan-17	46	7.72	102823	355	0.01
10	Jan-17	2839	24.67	102823	70029	2.37
11	Jan-17	2189	9.72	102823	21271	0.72
12	Jan-17	903	24.00	102823	21672	0.99
13	Jan-17	98	25.20	102823	2470	0.16
14	Jan-17	370	22.57	102823	8350	0.55
15	Jan-17	344	47.11	102823	16205	0.57
16	Jan-17	106	23.83	102823	2526	0.35
	Total January - 17	12184	22.91	102823	279116	2.71
	YTD FY 17	61727	18.70	102823	1154427	11.22



Annexure-IV

Performance Report regarding Reliability Indices

(2) System Average Interruption Frequency Index (SAIFI)

(Regulation 10 of MERC, Standards of Performance Regulations, 2014)

Sr. No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions =Sum Ni	Nt=Total number of consumers of the distribution Licensees area	SAIFI = 4/5
1	2	3	4	5	6
1	Jan-17	761	761	102823	0.05
2	Jan-17	426	426	102823	0.01
3	Jan-17	18	18	102823	0.00
4	Jan-17	1866	1866	102823	0.07
5	Jan-17	959	959	102823	0.03
6	Jan-17	66	66	102823	0.01
7	Jan-17	1146	1146	102823	0.04
8	Jan-17	47	47	102823	0.01
9	Jan-17	46	46	102823	0.00
10	Jan-17	2839	2839	102823	0.10
11	Jan-17	2189	2189	102823	0.07
12	Jan-17	903	903	102823	0.04
13	Jan-17	98	98	102823	0.01
14	Jan-17	370	370	102823	0.02
15	Jan-17	344	344	102823	0.01
16	Jan-17	106	106	102823	0.01
	Total January - 17	12184	12184	102823	0.12
	YTD FY 17	61727	61727	102823	0.60



Annexure-IV

Performance Report regarding Reliability Indices
 (3) Customer Average Interruption Duration Index (CAIDI)
 (Regulation 10 of MERC, Standards of Performance Regulations, 2014)

Sr. No.	Month	SAIDI	SAIFI	SAIDI/SAIFI
1	2	3	4	5
1	Jan-17	2.28	0.05	45.00
2	Jan-17	0.35	0.01	23.02
3	Jan-17	0.03	0.00	13.72
4	Jan-17	1.03	0.07	15.75
5	Jan-17	0.81	0.03	25.00
6	Jan-17	0.14	0.01	15.00
7	Jan-17	1.30	0.04	32.14
8	Jan-17	0.10	0.01	16.00
9	Jan-17	0.01	0.00	7.72
10	Jan-17	2.37	0.10	24.67
11	Jan-17	0.72	0.07	9.72
12	Jan-17	0.99	0.04	24.00
13	Jan-17	0.16	0.01	25.20
14	Jan-17	0.55	0.02	22.57
15	Jan-17	0.57	0.01	47.11
16	Jan-17	0.35	0.01	23.83
	Total January - 17	2.71	0.12	22.91
	YTD FY 17	11.22	0.60	18.70



Annexure-IV

Performance Report regarding Reliability Indices

(1) System Average Interruption Duration Index (SAIDI)

(Regulation 10 of MERC, Standards of Performance Regulations, 2014)

Sr. No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri= Restoration time for each interruption event on ith feeder	Nt=Total number of consumers of the distribution Licensees area	Sum (Ri*Ni) for all feeders excluding agri. Feeders)	SAIDI = 6/5
1	2	3	4	5	6	7
1	Feb-17	190	17.61	103782	3346	0.12
2	Feb-17	18	15.78	103782	284	0.04
3	Feb-17	1946	7.13	103782	13880	0.47
4	Feb-17	946	6.73	103782	6369	0.42
5	Feb-17	3932	8.80	103782	34612	1.21
6	Feb-17	1	21.00	103782	21	0.00
7	Feb-17	127	11.35	103782	1442	0.05
8	Feb-17	21	15.86	103782	333	0.05
9	Feb-17	31	16.00	103782	496	0.02
10	Feb-17	1793	26.80	103782	48054	3.19
11	Feb-17	229	40.32	103782	9233	0.32
12	Feb-17	42	17.36	103782	729	0.05
13	Feb-17	33	18.27	103782	603	0.02
14	Feb-17	226	24.00	103782	5424	0.36
15	Feb-17	393	11.34	103782	4456	0.16
16	Feb-17	918	35.86	103782	32924	1.11
17	Feb-17	38	9.00	103782	342	0.01
18	Feb-17	74	9.53	103782	705	0.05
	Total February - 17	10958	14.89	103782	163253	1.57
	YTD FY 17	72685	18.12	103782	1317680	12.70



Annexure-IV

Performance Report regarding Reliability Indices

(2) System Average Interruption Frequency Index (SAIFI)

(Regulation 10 of MERC, Standards of Performance Regulations, 2014)

Sr. No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions =Sum Ni	Nt=Total number of consumers of the distribution Licensees area	SAIFI = 4/5
1	2	3	4	5	6
1	Feb-17	190	190	103782	0.01
2	Feb-17	18	18	103782	0.00
3	Feb-17	1946	1946	103782	0.07
4	Feb-17	946	946	103782	0.06
5	Feb-17	3932	3932	103782	0.14
6	Feb-17	1	1	103782	0.00
7	Feb-17	127	127	103782	0.00
8	Feb-17	21	21	103782	0.00
9	Feb-17	31	31	103782	0.00
10	Feb-17	1793	1793	103782	0.12
11	Feb-17	229	229	103782	0.01
12	Feb-17	42	42	103782	0.00
13	Feb-17	33	33	103782	0.00
14	Feb-17	226	226	103782	0.02
15	Feb-17	393	393	103782	0.01
16	Feb-17	918	918	103782	0.03
17	Feb-17	38	38	103782	0.00
18	Feb-17	74	74	103782	0.00
	Total February - 17	10958	10958	103782	0.11
	YTD FY 17	72685	72685	103782	0.70



Annexure-IV

Performance Report regarding Reliability Indices
 (3) Customer Average Interruption Duration Index (CAIDI)
 (Regulation 10 of MERC, Standards of Performance Regulations, 2014)

Sr. No.	Month	SAIDI	SAIFI	SAIDI/SAIFI
1	2	3	4	5
1	Feb-17	0.12	0.01	17.61
2	Feb-17	0.04	0.00	15.78
3	Feb-17	0.47	0.07	7.13
4	Feb-17	0.42	0.06	6.73
5	Feb-17	1.21	0.14	8.80
6	Feb-17	0.00	0.00	21.00
7	Feb-17	0.05	0.00	11.35
8	Feb-17	0.05	0.00	15.86
9	Feb-17	0.02	0.00	16.00
10	Feb-17	3.19	0.12	26.80
11	Feb-17	0.32	0.01	40.32
12	Feb-17	0.05	0.00	17.36
13	Feb-17	0.02	0.00	18.27
14	Feb-17	0.36	0.02	24.00
15	Feb-17	0.16	0.01	11.34
16	Feb-17	1.11	0.03	35.86
17	Feb-17	0.01	0.00	9.00
18	Feb-17	0.05	0.00	9.53
	Total February - 17	1.57	0.11	14.89
	YTD FY 17	12.70	0.70	18.12



Annexure-IV

Performance Report regarding Reliability Indices

(1) System Average Interruption Duration Index (SAIDI)

(Regulation 10 of MERC, Standards of Performance Regulations, 2014)

Sr. No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri= Restoration time for each interruption event on ith feeder	Nt=Total number of consumers of the distribution Licensees area	Sum (Ri*Ni) for all feeders excluding agri. Feeders)	SAIDI = 6/5
1	2	3	4	5	6	7
1	Mar-17	1	8.00	106318	8	0.00
2	Mar-17	356	30.00	106318	10680	0.71
3	Mar-17	233	13.30	106318	3098	0.14
4	Mar-17	1	6.00	106318	6	0.00
5	Mar-17	356	22.47	106318	8000	0.53
6	Mar-17	3	32.00	106318	96	0.01
7	Mar-17	1054	7.00	106318	7378	1.02
8	Mar-17	1175	13.69	106318	16085	1.06
9	Mar-17	53	30.00	106318	1590	0.05
10	Mar-17	133	26.00	106318	3458	0.12
11	Mar-17	757	42.99	106318	32542	2.15
12	Mar-17	4	10.75	106318	43	0.00
13	Mar-17	53	16.96	106318	899	0.03
14	Mar-17	30	0.00	106318	0	0.00
15	Mar-17	260	8.00	106318	2080	0.07
16	Mar-17	398	25.98	106318	10340	0.44
	Total March - 17	4867	19.78	106318	96303	0.91
	YTD FY 17	77552	18.23	106318	1413983	13.30



Annexure-IV

Performance Report regarding Reliability Indices

(2) System Average Interruption Frequency Index (SAIFI)

(Regulation 10 of MERC, Standards of Performance Regulations, 2014)

Sr. No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions =Sum Ni	Nt=Total number of consumers of the distribution Licensees area	SAIFI = 4/5
1	2	3	4	5	6
1	Mar-17	1	1	106318	0.00
2	Mar-17	356	356	106318	0.02
3	Mar-17	233	233	106318	0.01
4	Mar-17	1	1	106318	0.00
5	Mar-17	356	356	106318	0.02
6	Mar-17	3	3	106318	0.00
7	Mar-17	1054	1054	106318	0.15
8	Mar-17	1175	1175	106318	0.08
9	Mar-17	53	53	106318	0.00
10	Mar-17	133	133	106318	0.00
11	Mar-17	757	757	106318	0.05
12	Mar-17	4	4	106318	0.00
13	Mar-17	53	53	106318	0.00
14	Mar-17	30	30	106318	0.00
15	Mar-17	260	260	106318	0.01
16	Mar-17	398	398	106318	0.02
	Total March - 17	4867	4867	106318	0.05
	YTD FY 17	77552	77552	106318	0.73



Annexure-IV

Performance Report regarding Reliability Indices
(3) Customer Average Interruption Duration Index (CAIDI)
(Regulation 10 of MERC, Standards of Performance Regulations, 2014)

Sr. No.	Month	SAIDI	SAIFI	SAIDI/SAIFI
1	2	3	4	5
1	Mar-17	0.00	0.00	8.00
2	Mar-17	0.71	0.02	30.00
3	Mar-17	0.14	0.01	13.30
4	Mar-17	0.00	0.00	6.00
5	Mar-17	0.53	0.02	22.47
6	Mar-17	0.01	0.00	32.00
7	Mar-17	1.02	0.15	7.00
8	Mar-17	1.06	0.08	13.69
9	Mar-17	0.05	0.00	30.00
10	Mar-17	0.12	0.00	26.00
11	Mar-17	2.15	0.05	42.99
12	Mar-17	0.00	0.00	10.75
13	Mar-17	0.03	0.00	16.96
14	Mar-17	0.00	0.00	0.00
15	Mar-17	0.07	0.01	8.00
16	Mar-17	0.44	0.02	25.98
	Total March - 17	0.91	0.05	19.78
	YTD FY 17	13.30	0.73	18.23