

MINUTES OF MEETING
OF THE
MUMBAI DISTRIBUTION NETWORK ASSESSMENT COMMITTEE (M-DNAC)

Date :- 6 August, 2019 at 15.00 Hrs.

Venue :- MERC, 12th Floor Conference Hall

Present :- Shri. Dineshchandra Saboo, Member (External)
Shri. Prafulla Varhade, Member (Commission's Officer)
Shri. Dilip Dumbre, Member (Ombudsman's Officer)
Shri. Rakesh Guhagarkar, Member Convener, (Commission's Officer)

Discussions held

1. Proposals in sealed envelope were received from TPC-D and AEML-D on 22 July, 2019 and 23 July, 2019 respectively for power supply to the applicant “**Katyani Heights**” (Starwing Developers), Andheri East, Mumbai.
2. During meeting held on 1 August 2019, the proposals were opened in presence of the representatives of both the Licensees. Shri Nilesh Potphode and Shri Girish Pednekar were present on behalf of TPC-D. Shri. Vivek Mishra and Shri. Shabbir Dharwala were present on behalf of AEML-D. The representatives of Licensees briefly explained their respective proposals.
3. Subsequently, to decide least cost Licensee for power supply to the instant consumer based on their proposals, a meeting of M-DNAC was held on 6 August 2019. It was observed that TPC-D had proposed cost of Rs. 78.45 Lacs whereas AEML-D had proposed cost of Rs. 28.93 lacs. TPC-D had considered 1250 KVA, 22/0.433kV Oil type transformer and 22 kV feeder of 550 meters and AEML-D had considered 1000 KVA, 11/0.433kV Dry type transformer with 11 kV feeder of 150 meters on account of which the cost difference had been arisen.
4. Item-wise details and cost submitted by TPC-D is as follows:

Sr. No.	Item	Unit	Quantity
1	22 kV 3C 300 sq mm HT Cable	M	550
2	22 kV 3 Way Ring Main Unit	Ea	1
3	22 kV 1250 kVA Oil Type Transformer	Ea	1
4	LT Breaker 2000 A 1/C	Ea	1

5. Item-wise details and cost submitted by AEML-D is as follows:

Sr. No.	Item	Unit	Quantity
1	11 kV, 3C/300 sq mm XLPE Cable	M	150
2	11 kV Dry Switchgear (1+2)	Nos.	1
3	11/0.4 kV, 1000 kVA Dry Type Transformer	Nos.	1
4	Low Voltage Panels	Nos.	1
5	Civil Structure (Stilt - Part of building)	Nos.	1

6. After evaluation of the proposals alongwith the additional details of assumptions and backup calculations of MD estimation submitted by AEML-D, the Committee observed that AEML-D is least cost Licensee for releasing the connection to instant consumer.
7. In view of the above, the Committee has decided to allow AEML-D to release power supply connection to “Katyani Heights” (Starwing Developers), Andheri East, Mumbai. The total cost submitted by AEML-D of Rs. 28.93 lacs shall be the ceiling cost (with no further incremental cost) for ARR of AEML-D as mentioned in the Case No. 182 of 2014.
