

Report as submitted by  
AEML - Distribution

**Annexure-III**  
**Standards of Performance Level by the Distribution Licensee**  
**Format for Quarterly Return to be submitted to the Commission by the Distribution Licensee**

Name of Distribution Licensee: Adani Electricity Mumbai Limited  
 Period: Apr-2024 to Jun-2024

Sr.No.	Parameters	Area	Pending complaint Nos. (previous Quarter)	Complaints in current Qtr.	Total cases / complaints	No. of complaints addressed			Pending complaints at end of Qtr.	Remark
						Within Standards of performance	More than stipulated time	Total complaints redressed		
	a	b	c	d	e=c+d	f	g	h=f+g	i=e-h	
1	Intimation of charges where supply to dedicated or after extension / augmentation	Urban	0	0	0	0	0	0	0	No connection was released using dedicated distribution network and all cases of network extension / augmentation are covered under normative charges
2	New connection/ add. load where supply from existing line		183	10914	11097	10967	0	10967	130	
3	New connection/ add. Load where supply after extension / augmentation		22	16298	16320	16311	0	16311	9	
4	New connection/ add. load where supply after commissioning of sub-station		0	0	0	0	0	0	0	
5	Shifting of Meter / service Line	Urban	20	579	599	582	0	582	17	No timelines mentioned in SOP Regulations, 2021 for shifting of meters / services
6	Reconnection of supply after payment of dues	Urban	0	19540	19540	19461	79	19540	0	It is clarified that while certain applications are shown as being addressed in "more than stipulated time", that is only a representation and not a non-compliance of SOP norms, because total time taken increased due to the following reasons: Objection by 3rd parties at site -8 Meter cabin: Locked/Not accessible-20 Structure found Demolished-1 Consumer side Wiring damaged / Incomplete-50
7	Change of Name		0	27906	27906	27906	0	27906	0	
8	Change of category		12	1016	1028	960	0	960	68	
9	Fuse off call	Urban	0	27675	27675	27658	17	27675	0	Refer Table in Notes below #
10	Breakdown of Overhead Line	Urban	0	0	0	0	0	0	0	
11	Underground Cable fault / Bus Riser Fault	Urban	0	14923	14923	14762	161	14923	0	Refer Table in Notes below #

Sr.No.	Parameters	Area	Pending complaint Nos. (previous Quarter)	Complaints in current Qtr.	Total cases / complaints	No. of complaints addressed			Pending complaints at end of Qtr.	Remark
						Within Standards of performance	More than stipulated time	Total complaints redressed		
12	Transformer and Associated Switchgear Failure	Urban	0	14	14	14	0	14	0	
13	Meter Reading	Annexure II (Sr.	0	7972165	7972165	7971838	327	7972165	0	Estimated reading due to: No Access to meter cabin : 327 (due to reasons such as approach road to meter cabin blocked due to construction works, damaged / under repair road etc., refusal of consumers to provide access to meter cabin etc)
14	Replacement of Faulty Meter*	Urban	0	159	159	159	0	159	0	
15	Replacement of Burnt Meter*	Urban	0	1495	1495	1495	0	1495	0	
16	Billing Complaint		17	7534	7551	6640	7	6647	904	It is clarified that while certain applications are shown as being addressed in "more than stipulated time", that is only a representation and not a non-compliance of SOP norms, because total time taken increased due to the following reasons: Customer Meter Cabin lock - 05 nos Premise found lock - 02 nos
17	Quality of Supply #									
a	11kV Supply Variation	Urban	0	0	0	0	0	0	0	
b	Long term flicker severity	Urban	0	0	0	0	0	0	0	
c	Unbalance Voltage	Urban	0	0	0	0	0	0	0	
d	Number of Voltage Dips	Urban	0	4	4	4	0	4	0	
e	Number of Short Interruption	Urban	0	0	0	0	0	0	0	
f	Voltage THD (<8% at 11kV)	Urban	0	0	0	0	0	0	0	

**Notes:**

1. \*\* Faulty meter includes defect in the meters not affecting the customer's supply, however affecting recording of consumer's consumption and needs immediate replacement. This does not include black spot meters, meters used for reconnection of supply, meters replaced due to change in load of consumer etc. Also the above data represents the replacement of faulty meters after receipt of consumer complaints regarding high billing complaints, meter being damaged or improper recording of meter. As per Supply Code and SoP Regns, 2021, in case of energy being correctly measured and /or recorded in Meter but communication accessories have failed, then such Meter shall not be treated as faulty. Thus display defective / black spot meters are not faulty meters as per Supply Code and SoP Regns, 2021 and hence replacement of display defective meters/ black spot meters has not been included in the above data.

2. As per Regulation 26.1 (d) of the Supply Code and SoP Regulations, 2021, Distribution Licensees are exempt from performance obligation if non-performance is on account of occurrences beyond the control of Distribution Licensee. AEML-D has provided the occurrences where it had failed to meet the standards as per Regulations and these are beyond the control of AEML. The Hon'ble Commission is requested to consider these submissions while evaluating SOP compliance.

Sr.No.	Parameters	Area	Ref Regulation
--------	------------	------	----------------

# Notes: Fuse off Call, Overhaed failures and Underground Cable faults

Sr.no	Reasons for delay	6.1 Fuse off call	6.3UG Cable fault
1	In theft prone areas miscreants are tapping wires from AEML's feeder boxes and meter cabins. The overloading due to such unauthorized load results in to interruption of supply. AEML is taking efforts to remove such unauthorized connections from time to time. During any interruption, for safety purpose, AEML needs to first remove such unauthorized connections and then restore the supply. This results in delay in restoration of supply to complainant or even delay repairing of fault. Events related to this reason are specified here.	0	48
2	Adverse site conditions (cable deep/multiple cables at one location/multiple complaints/ road crossing/supply restoration not possible by temporary means/mass objection): AEML's network is developed over 7 decades. Due to road widening, level raising, concerting, etc. cables have gone deep under the roads. It takes time to get all necessary permission and excavation for repair of such faults. Since using temporary cable or wire on such public roads is safety hazard, it is preferred to repair the fault. Mass objections on site is also faced sometimes. Availability of multiple Utilities under ground and makes it difficult to trace/locate the fault. In such cases supply restoration is delayed.	14	67
3	Heavy Rains, Water Logging, water ingress due to side by Nalla: In such conditions it becomes difficult to access installation/cables. In such cases it take more time to attended complaint/fault.	3	6
4	Request from Consumer to attend the fault at later suitable time	0	23
5	Fault at Consumer installation, which consumer needs to rectify. Supply is kept OFF for safety purpose.	0	0
6	Objection from Consumer: Some time consumers in the area take the objection (specially in slums) for excavation or laying of temporary cable or wire. At times it becomes very difficult to convince public and take longer time. Such events are covered here.	0	12
7	Access issue to meter cabin /AEML network equipment: Many times it is found that the access to AEML feeder pillars / meter cabin is blocked due to car or motor cycle parking or by any other means. This requires first removal of such obstructions to get access. It take longer time to search owner to get the site cleared. Once the access is available, repairing work or DG Set connection is initiated. However, this delays the supply restoration. Also rectification took time due to adverse site conditions.	0	5
<b>Grand Total</b>		<b>17</b>	<b>161</b>

**Annexure-IV**  
**Report of individual Complaints where Compensation has been paid**  
**Format for quarterly return to be submitted to the Commission by the Distribution Licensee**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: Apr-2024 to Jun-2024**

Sr. No.	Complain t No.	Date of filing complaint/Automati c Compensation	Consumer No.	Name and address of Consumer	Nature of Complain t	Reference Standard of Performanc e	Amount of Compensation (Rs.)	Date of payment of Compensation (DD/MM/YYYY )
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	<b>NIL</b>							
2								
3								
4								
5								
6								
7								

**Annexure-V**  
**Report of action on Faulty Meters (1 Phase/ 3 Phase)**  
**Format for quarterly return to be submitted to the Commission by the Distribution Licensee**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: Apr-2024 to Jun-2024**

Sr.No.	Name of Distribution Licensee	Reference to Overall Standards	Faulty Meters at the start of the Quarter (Nos.)	Faulty Meters added during Quarter (Nos.)	Total Faulty Meters (Nos.)	Meters rectified / replaced (Nos.)	Faulty Meters pending at end of Quarter (Nos.)
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
1	AEML	Annexure II (Sr. 3 ii) of Supply Code and SoP Regns, 2021	0	159	159	159	0

**Note:**

1. Faulty meter includes defect in the meters not affecting the customer's supply, however affecting recording of consumer's consumption and needs immediate replacement. This does not include black spot meters, meters used for reconnection of supply, meters replaced due to change in load of consumer etc. Also the above data represents the replacement of faulty meters after receipt of consumer complaints regarding high billing complaints, meter being damaged or improper recording of meter.
2. As per Supply Code and SoP Regns, 2021, in case of energy being correctly measured and /or recorded in Meter but communication accessories have failed, then such Meter shall not be treated as faulty. Thus display defective / black spot meters are not faulty meters as per Supply Code and SoP Regns, 2021 and hence replacement of display defective meters/ black spot meters has not been included in the above data.

**Annexure- VI**  
**Report of Installation of Meters**  
**Format for quarterly return to be submitted to the Commission by the Distribution Licensee**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: Apr-2024 to Jun-2024**

Sr.No.	Name of Distribution Licensee	Total Agriculture Connections at start of the Quarter (Nos.)	Metered Agriculture Connections at the start of the Quarter (Nos.)	New Metered Agriculture Connections released during the Quarter (Nos.)	Unmetered Agriculture Connections at the start of the Quarter (Nos.)	New Unmetered Agriculture Connections released during the Quarter (Nos.)	Meter installed to unmeterd connections during the Quarter.(Nos.)	Unmetered Agriculture Connections at the end of the Quarter (Nos.)	Metered Agriculture Connections at the end of the Quarter (Nos.)	Total Agriculture Connections at the end of the Quarter (Nos.)
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9=6+7-8)	(10=4+5+8)	(9+10)
1	AEML	38	38	6	0	0	0	0	44	44

Note: Total agriculture connections at the end of previous quarter (Q4 of FY 2023-24) was shown inadvertently shown as 45. The same is corrected above and hence the total agriculture connections at the opening of this quarter (Q1 of FY 2024-25) is 38.

**Annexure-VII**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(1) System Average Interruption Duration Index (SAIDI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: April 2024**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	Apr-24	1	22.2	3194473	22	0.0000
2	Apr-24	1	34.8	3194473	35	0.0000
3	Apr-24	13	16.98	3194473	221	0.0001
4	Apr-24	19	18	3194473	342	0.0001
5	Apr-24	69	9	3194473	621	0.0002
6	Apr-24	33	22	3194473	726	0.0002
7	Apr-24	3	271.2	3194473	814	0.0003
8	Apr-24	180	7	3194473	1260	0.0004
9	Apr-24	96	20	3194473	1920	0.0006
10	Apr-24	115	19	3194473	2185	0.0007
11	Apr-24	341	7	3194473	2387	0.0007
12	Apr-24	78	31	3194473	2418	0.0008
13	Apr-24	286	9.89	3194473	2829	0.0009
14	Apr-24	141	23	3194473	3243	0.0010
15	Apr-24	410	7.93	3194473	3251	0.0010
16	Apr-24	265	13	3194473	3445	0.0011
17	Apr-24	189	21	3194473	3969	0.0012
18	Apr-24	270	15	3194473	4050	0.0013
19	Apr-24	195	22	3194473	4290	0.0013
20	Apr-24	567	8	3194473	4536	0.0014
21	Apr-24	125	37	3194473	4625	0.0014
22	Apr-24	271	18	3194473	4878	0.0015
23	Apr-24	272	19	3194473	5168	0.0016
24	Apr-24	227	23	3194473	5221	0.0016
25	Apr-24	573	11.32	3194473	6486	0.0020
26	Apr-24	279	23.39	3194473	6526	0.0020
27	Apr-24	470	15.11	3194473	7102	0.0022
28	Apr-24	514	14.43	3194473	7417	0.0023
29	Apr-24	363	22	3194473	7986	0.0025
30	Apr-24	439	19	3194473	8341	0.0026
31	Apr-24	244	37	3194473	9028	0.0028
32	Apr-24	163	56	3194473	9128	0.0029
33	Apr-24	341	28	3194473	9548	0.0030
34	Apr-24	287	34.15	3194473	9801	0.0031
35	Apr-24	714	14.02	3194473	10010	0.0031
36	Apr-24	1172	8.63	3194473	10114	0.0032
37	Apr-24	439	24	3194473	10536	0.0033
38	Apr-24	1234	8.78	3194473	10835	0.0034
39	Apr-24	283	39	3194473	11037	0.0035
40	Apr-24	552	20	3194473	11040	0.0035
41	Apr-24	619	19	3194473	11761	0.0037
42	Apr-24	556	21.93	3194473	12193	0.0038
43	Apr-24	421	29	3194473	12209	0.0038



Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
44	Apr-24	476	26	3194473	12376	0.0039
45	Apr-24	708	21	3194473	14868	0.0047
46	Apr-24	829	18.42	3194473	15270	0.0048
47	Apr-24	2408	7	3194473	16856	0.0053
48	Apr-24	619	29	3194473	17951	0.0056
49	Apr-24	562	32	3194473	17984	0.0056
50	Apr-24	855	23	3194473	19665	0.0062
51	Apr-24	567	35	3194473	19845	0.0062
52	Apr-24	983	20.53	3194473	20181	0.0063
53	Apr-24	2900	7	3194473	20300	0.0064
54	Apr-24	911	22.7	3194473	20680	0.0065
55	Apr-24	562	37.34	3194473	20985	0.0066
56	Apr-24	879	24.5	3194473	21536	0.0067
57	Apr-24	760	28.38	3194473	21569	0.0068
58	Apr-24	628	38.07	3194473	23908	0.0075
59	Apr-24	1141	20.95	3194473	23904	0.0075
60	Apr-24	4077	6	3194473	24462	0.0077
61	Apr-24	783	33.02	3194473	25855	0.0081
62	Apr-24	929	29	3194473	26941	0.0084
63	Apr-24	2048	14	3194473	28672	0.0090
64	Apr-24	939	31	3194473	29109	0.0091
65	Apr-24	623	47.03	3194473	29300	0.0092
66	Apr-24	1377	21.75	3194473	29950	0.0094
67	Apr-24	1475	21	3194473	30975	0.0097
68	Apr-24	3205	9.71	3194473	31121	0.0097
69	Apr-24	1689	18.49	3194473	31230	0.0098
70	Apr-24	2134	15.06	3194473	32138	0.0101
71	Apr-24	1303	24.7	3194473	32184	0.0101
72	Apr-24	585	55.58	3194473	32514	0.0102
73	Apr-24	1072	32.14	3194473	34454	0.0108
74	Apr-24	3462	10	3194473	34620	0.0108
75	Apr-24	478	73.53	3194473	35147	0.0110
76	Apr-24	672	52.48	3194473	35267	0.0110
77	Apr-24	1645	22.52	3194473	37045	0.0116
78	Apr-24	1029	38	3194473	39102	0.0122
79	Apr-24	844	46.48	3194473	39229	0.0123
80	Apr-24	1086	36.18	3194473	39291	0.0123
81	Apr-24	1591	24.77	3194473	39409	0.0123
82	Apr-24	1538	26.57	3194473	40865	0.0128
83	Apr-24	3751	11	3194473	41261	0.0129
84	Apr-24	1657	25	3194473	41425	0.0130
85	Apr-24	1481	29.76	3194473	44075	0.0138
86	Apr-24	2011	22.08	3194473	44403	0.0139
87	Apr-24	1486	29.97	3194473	44535	0.0139
88	Apr-24	2877	16	3194473	46032	0.0144
89	Apr-24	1490	30.96	3194473	46130	0.0144
90	Apr-24	3332	14.52	3194473	48381	0.0151
91	Apr-24	3581	13.53	3194473	48451	0.0152
92	Apr-24	2042	25	3194473	51050	0.0160
93	Apr-24	1787	29.06	3194473	51930	0.0163
94	Apr-24	2033	26.03	3194473	52919	0.0166
95	Apr-24	5495	9.93	3194473	54565	0.0171
96	Apr-24	4513	12.18	3194473	54968	0.0172
97	Apr-24	3711	15.02	3194473	55739	0.0174

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
98	Apr-24	1123	50.87	3194473	57127	0.0179
99	Apr-24	2073	27.58	3194473	57173	0.0179
100	Apr-24	2384	24.96	3194473	59505	0.0186
101	Apr-24	1493	40.19	3194473	60004	0.0188
102	Apr-24	1850	32.62	3194473	60347	0.0189
103	Apr-24	4908	12.36	3194473	60663	0.0190
104	Apr-24	4530	13.48	3194473	61064	0.0191
105	Apr-24	2446	26.18	3194473	64036	0.0200
106	Apr-24	2885	23.09	3194473	66615	0.0209
107	Apr-24	8268	8.09	3194473	66888	0.0209
108	Apr-24	2309	29	3194473	66961	0.0210
109	Apr-24	2750	25.45	3194473	69988	0.0219
110	Apr-24	2162	34.68	3194473	74978	0.0235
111	Apr-24	4973	15.53	3194473	77231	0.0242
112	Apr-24	3005	25.86	3194473	77709	0.0243
113	Apr-24	3854	20.23	3194473	77966	0.0244
114	Apr-24	1907	41	3194473	78187	0.0245
115	Apr-24	5336	14.71	3194473	78493	0.0246
116	Apr-24	1379	57.71	3194473	79582	0.0249
117	Apr-24	1924	43.41	3194473	83521	0.0261
118	Apr-24	9849	8.56	3194473	84307	0.0264
119	Apr-24	2799	30.6	3194473	85649	0.0268
120	Apr-24	4141	21.51	3194473	89073	0.0279
121	Apr-24	3005	30.82	3194473	92614	0.0290
122	Apr-24	2812	32.96	3194473	92684	0.0290
123	Apr-24	5371	17.29	3194473	92865	0.0291
124	Apr-24	3173	31.52	3194473	100013	0.0313
125	Apr-24	3422	31.37	3194473	107348	0.0336
126	Apr-24	4366	24.82	3194473	108364	0.0339
127	Apr-24	4841	23.65	3194473	114490	0.0358
128	Apr-24	4933	24.71	3194473	121894	0.0382
129	Apr-24	2862	43.08	3194473	123295	0.0386
130	Apr-24	4014	30.89	3194473	123992	0.0388
131	Apr-24	3897	32.09	3194473	125055	0.0391
132	Apr-24	4738	27.14	3194473	128589	0.0403
133	Apr-24	2791	48.46	3194473	135252	0.0423
134	Apr-24	6141	22.33	3194473	137129	0.0429
135	Apr-24	11977	11.9	3194473	142526	0.0446
136	Apr-24	2164	66.28	3194473	143430	0.0449
137	Apr-24	5339	27.3	3194473	145755	0.0456
138	Apr-24	3072	48.34	3194473	148500	0.0465
139	Apr-24	6266	23.84	3194473	149381	0.0468
140	Apr-24	2849	57.93	3194473	165043	0.0517
141	Apr-24	6644	25.48	3194473	169289	0.0530
142	Apr-24	2670	67.33	3194473	179771	0.0563
143	Apr-24	5179	38.94	3194473	201670	0.0631
144	Apr-24	4886	43.87	3194473	214349	0.0671
145	Apr-24	15210	14.66	3194473	222979	0.0698
146	Apr-24	5361	42.75	3194473	229183	0.0717
147	Apr-24	4323	57.65	3194473	249221	0.0780
148	Apr-24	6176	46.68	3194473	288296	0.0902
149	Apr-24	5780	50.84	3194473	293855	0.0920
150	Apr-24	10510	30.48	3194473	320345	0.1003
151	Apr-24	5252	66.23	3194473	347840	0.1089

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
152	Apr-24	6873	58.67	3194473	403239	0.1262
153	Apr-24	2058	249.13	3194473	512710	0.1605
154	Apr-24	2382	789.43	3194473	1880422	0.5886
155	Apr-24	9740	433.95	3194473	4226673	1.3231
156	Apr-24	1311	16.79	3194473	22012	0.0069
157	Apr-24	1386	21.72	3194473	30104	0.0094
158	Apr-24	4187	59.16	3194473	247703	0.0775
159	Apr-24	5252	90.68	3194473	476251	0.1491
160	Apr-24	9425	301.31	3194473	2839847	0.8890
161	Apr-24	3014	36	3194473	108504	0.0340
162	Apr-24	293	6	3194473	1758	0.0006
163	Apr-24	477	11	3194473	5247	0.0016
164	Apr-24	733	13	3194473	9529	0.0030
165	Apr-24	1086	9	3194473	9774	0.0031
166	Apr-24	1391	10.47	3194473	14564	0.0046
167	Apr-24	713	27	3194473	19251	0.0060
168	Apr-24	1337	44.85	3194473	59964	0.0188
169	Apr-24	3569	23.23	3194473	82908	0.0260
170	Apr-24	6453	15	3194473	96795	0.0303
171	Apr-24	7258	15	3194473	108870	0.0341
172	Apr-24	5338	23	3194473	122774	0.0384
Total		418097	48.24	3194473	20167157	6.3131

Remark :

- 1 Customer served by AEML are 3194473 nos.
- 2 Number of feeders are 1295 Nos.

**Annexure-VII**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(1) System Average Interruption Duration Index (SAIDI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: May 2024**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	May-24	1	36	3199722	36	0.0000
2	May-24	1	37.2	3199722	37	0.0000
3	May-24	1	42	3199722	42	0.0000
4	May-24	7	31.03	3199722	217	0.0001
5	May-24	12	19	3199722	228	0.0001
6	May-24	14	43.71	3199722	612	0.0002
7	May-24	37	24	3199722	888	0.0003
8	May-24	59	17	3199722	1003	0.0003
9	May-24	126	15	3199722	1890	0.0006
10	May-24	115	16.7	3199722	1921	0.0006
11	May-24	113	18	3199722	2034	0.0006
12	May-24	212	10	3199722	2120	0.0007
13	May-24	377	7	3199722	2639	0.0008
14	May-24	167	24.44	3199722	4081	0.0013
15	May-24	311	13.59	3199722	4226	0.0013
16	May-24	215	20	3199722	4300	0.0013
17	May-24	142	30.55	3199722	4338	0.0014
18	May-24	596	9	3199722	5364	0.0017
19	May-24	140	44	3199722	6160	0.0019
20	May-24	283	25	3199722	7075	0.0022
21	May-24	278	26	3199722	7228	0.0023
22	May-24	438	16.62	3199722	7280	0.0023
23	May-24	280	29	3199722	8120	0.0025
24	May-24	459	18	3199722	8262	0.0026
25	May-24	638	13.04	3199722	8320	0.0026
26	May-24	1161	7.31	3199722	8487	0.0027
27	May-24	512	16.85	3199722	8627	0.0027
28	May-24	259	36.92	3199722	9562	0.0030
29	May-24	238	43.03	3199722	10241	0.0032
30	May-24	792	13	3199722	10296	0.0032
31	May-24	286	38	3199722	10868	0.0034
32	May-24	653	17.08	3199722	11153	0.0035
33	May-24	791	14.17	3199722	11208	0.0035
34	May-24	712	16.01	3199722	11399	0.0036
35	May-24	666	18	3199722	11988	0.0037
36	May-24	722	16.71	3199722	12065	0.0038
37	May-24	722	16.88	3199722	12187	0.0038
38	May-24	1018	12.05	3199722	12267	0.0038
39	May-24	691	18	3199722	12438	0.0039
40	May-24	622	20.03	3199722	12459	0.0039
41	May-24	410	31	3199722	12710	0.0040
42	May-24	1313	9.84	3199722	12920	0.0040
43	May-24	387	34.19	3199722	13232	0.0041

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
44	May-24	447	30.33	3199722	13558	0.0042
45	May-24	703	19.61	3199722	13786	0.0043
46	May-24	496	29	3199722	14384	0.0045
47	May-24	597	25	3199722	14925	0.0047
48	May-24	327	47.68	3199722	15591	0.0049
49	May-24	514	31	3199722	15934	0.0050
50	May-24	1550	10.52	3199722	16306	0.0051
51	May-24	1022	16.41	3199722	16771	0.0052
52	May-24	1341	13	3199722	17433	0.0054
53	May-24	1044	17.36	3199722	18124	0.0057
54	May-24	976	19	3199722	18544	0.0058
55	May-24	1118	16.68	3199722	18648	0.0058
56	May-24	487	39.25	3199722	19115	0.0060
57	May-24	1139	18	3199722	20502	0.0064
58	May-24	2598	8.05	3199722	20914	0.0065
59	May-24	1409	14.98	3199722	21107	0.0066
60	May-24	941	24.58	3199722	23130	0.0072
61	May-24	3117	7.46	3199722	23253	0.0073
62	May-24	1674	14.15	3199722	23687	0.0074
63	May-24	902	27	3199722	24354	0.0076
64	May-24	1831	13.67	3199722	25030	0.0078
65	May-24	1326	19	3199722	25194	0.0079
66	May-24	733	35	3199722	25655	0.0080
67	May-24	1812	14.17	3199722	25676	0.0080
68	May-24	734	35	3199722	25690	0.0080
69	May-24	1548	17.09	3199722	26455	0.0083
70	May-24	653	42.05	3199722	27459	0.0086
71	May-24	1857	15.2	3199722	28226	0.0088
72	May-24	528	55.65	3199722	29383	0.0092
73	May-24	594	50.37	3199722	29920	0.0094
74	May-24	5047	6	3199722	30282	0.0095
75	May-24	1936	15.69	3199722	30376	0.0095
76	May-24	2225	13.69	3199722	30460	0.0095
77	May-24	1213	26	3199722	31538	0.0099
78	May-24	1818	17.56	3199722	31924	0.0100
79	May-24	1574	20.46	3199722	32204	0.0101
80	May-24	1525	22	3199722	33550	0.0105
81	May-24	2831	11.92	3199722	33746	0.0105
82	May-24	1123	30.99	3199722	34802	0.0109
83	May-24	1129	34	3199722	38386	0.0120
84	May-24	537	72.93	3199722	39163	0.0122
85	May-24	1471	26.89	3199722	39555	0.0124
86	May-24	2654	15.1	3199722	40075	0.0125
87	May-24	1614	25.04	3199722	40415	0.0126
88	May-24	2307	18	3199722	41526	0.0130
89	May-24	869	47.87	3199722	41599	0.0130
90	May-24	808	52.52	3199722	42436	0.0133
91	May-24	1269	33.7	3199722	42765	0.0134
92	May-24	1518	28.55	3199722	43339	0.0135
93	May-24	2231	20.65	3199722	46070	0.0144
94	May-24	1052	45.8	3199722	48182	0.0151
95	May-24	2436	20	3199722	48720	0.0152
96	May-24	1591	30.68	3199722	48812	0.0153
97	May-24	1319	37.21	3199722	49080	0.0153

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
98	May-24	1286	38.51	3199722	49524	0.0155
99	May-24	2354	21.27	3199722	50070	0.0156
100	May-24	2601	19.77	3199722	51422	0.0161
101	May-24	1394	37.11	3199722	51731	0.0162
102	May-24	5960	8.75	3199722	52150	0.0163
103	May-24	2326	23.22	3199722	54010	0.0169
104	May-24	1815	31.23	3199722	56682	0.0177
105	May-24	7213	8	3199722	57704	0.0180
106	May-24	6968	8.48	3199722	59089	0.0185
107	May-24	5958	10	3199722	59580	0.0186
108	May-24	3166	20	3199722	63320	0.0198
109	May-24	2805	23.11	3199722	64824	0.0203
110	May-24	2325	29	3199722	67425	0.0211
111	May-24	2433	27.99	3199722	68100	0.0213
112	May-24	577	120	3199722	69240	0.0216
113	May-24	6924	11.05	3199722	76510	0.0239
114	May-24	3630	21.12	3199722	76666	0.0240
115	May-24	4323	18.84	3199722	81445	0.0255
116	May-24	6441	13	3199722	83733	0.0262
117	May-24	3532	24	3199722	84768	0.0265
118	May-24	9267	9.52	3199722	88222	0.0276
119	May-24	3720	24	3199722	89280	0.0279
120	May-24	2549	35.87	3199722	91433	0.0286
121	May-24	1490	62	3199722	92380	0.0289
122	May-24	1969	49.37	3199722	97210	0.0304
123	May-24	4030	24.24	3199722	97687	0.0305
124	May-24	2482	40.92	3199722	101563	0.0317
125	May-24	2382	43	3199722	102426	0.0320
126	May-24	3939	26.03	3199722	102532	0.0320
127	May-24	1413	73.68	3199722	104110	0.0325
128	May-24	1969	54	3199722	106326	0.0332
129	May-24	5780	19.97	3199722	115427	0.0361
130	May-24	7528	16	3199722	120448	0.0376
131	May-24	5325	23.23	3199722	123700	0.0387
132	May-24	6404	21	3199722	134484	0.0420
133	May-24	3669	37.68	3199722	138248	0.0432
134	May-24	4366	34.24	3199722	149492	0.0467
135	May-24	11283	13.89	3199722	156721	0.0490
136	May-24	10584	15.37	3199722	162676	0.0508
137	May-24	5000	33.77	3199722	168850	0.0528
138	May-24	6393	27.59	3199722	176383	0.0551
139	May-24	6270	28.42	3199722	178193	0.0557
140	May-24	6991	26	3199722	181766	0.0568
141	May-24	4933	37.5	3199722	184988	0.0578
142	May-24	4190	44.23	3199722	185324	0.0579
143	May-24	4146	45.27	3199722	187689	0.0587
144	May-24	3721	51.1	3199722	190143	0.0594
145	May-24	7630	27.32	3199722	208452	0.0651
146	May-24	2382	104	3199722	247728	0.0774
147	May-24	11107	22.31	3199722	247797	0.0774
148	May-24	2997	95	3199722	284715	0.0890
149	May-24	9475	32.16	3199722	304716	0.0952
150	May-24	6188	49.8	3199722	308162	0.0963
151	May-24	13914	22.42	3199722	311952	0.0975

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
152	May-24	6412	49.28	3199722	315983	0.0988
153	May-24	15915	20.37	3199722	324189	0.1013
154	May-24	3169	112	3199722	354928	0.1109
155	May-24	3164	120	3199722	379680	0.1187
156	May-24	9267	46.9	3199722	434622	0.1358
157	May-24	4883	166.98	3199722	815363	0.2548
158	May-24	502	22.11	3199722	11099	0.0035
159	May-24	4987	22	3199722	109714	0.0343
160	May-24	4853	15.26	3199722	74057	0.0231
161	May-24	2	54.9	3199722	110	0.0000
162	May-24	49	10	3199722	490	0.0002
163	May-24	23	169.8	3199722	3905	0.0012
164	May-24	248	20	3199722	4960	0.0016
165	May-24	448	23	3199722	10304	0.0032
166	May-24	4326	7.18	3199722	31061	0.0097
167	May-24	4326	9	3199722	38934	0.0122
Total		415183	27.94	3199722	11598899	3.6250

Remark :

- 1 Customer served by AEML are 3199722 nos.
- 2 Number of feeders are 1332 Nos.

**Annexure-VII**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(1) System Average Interruption Duration Index (SAIDI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: June 2024**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	Jun-24	14	22.71	3204370	318	0.0001
2	Jun-24	21	26	3204370	546	0.0002
3	Jun-24	71	19	3204370	1349	0.0004
4	Jun-24	57	37	3204370	2109	0.0007
5	Jun-24	215	23	3204370	4945	0.0015
6	Jun-24	295	18	3204370	5310	0.0017
7	Jun-24	768	7	3204370	5376	0.0017
8	Jun-24	991	6.56	3204370	6501	0.0020
9	Jun-24	934	7	3204370	6538	0.0020
10	Jun-24	567	11.93	3204370	6764	0.0021
11	Jun-24	348	21	3204370	7308	0.0023
12	Jun-24	283	30	3204370	8490	0.0026
13	Jun-24	708	12	3204370	8496	0.0027
14	Jun-24	239	36.24	3204370	8661	0.0027
15	Jun-24	387	27.32	3204370	10573	0.0033
16	Jun-24	439	27	3204370	11853	0.0037
17	Jun-24	542	22	3204370	11924	0.0037
18	Jun-24	415	29	3204370	12035	0.0038
19	Jun-24	577	23.33	3204370	13461	0.0042
20	Jun-24	2352	6	3204370	14112	0.0044
21	Jun-24	997	15	3204370	14955	0.0047
22	Jun-24	649	23.59	3204370	15310	0.0048
23	Jun-24	558	31.08	3204370	17343	0.0054
24	Jun-24	950	20.81	3204370	19770	0.0062
25	Jun-24	862	23.72	3204370	20447	0.0064
26	Jun-24	1125	19.43	3204370	21859	0.0068
27	Jun-24	1118	20	3204370	22360	0.0070
28	Jun-24	2913	8	3204370	23304	0.0073
29	Jun-24	3095	9	3204370	27855	0.0087
30	Jun-24	2078	13.43	3204370	27908	0.0087
31	Jun-24	734	39.41	3204370	28927	0.0090
32	Jun-24	817	37.26	3204370	30441	0.0095
33	Jun-24	3064	10	3204370	30640	0.0096
34	Jun-24	941	34.1	3204370	32088	0.0100
35	Jun-24	1895	17	3204370	32215	0.0101
36	Jun-24	1467	21.99	3204370	32259	0.0101
37	Jun-24	839	40.05	3204370	33602	0.0105
38	Jun-24	1088	35	3204370	38080	0.0119
39	Jun-24	3382	11.38	3204370	38487	0.0120
40	Jun-24	1053	37.45	3204370	39435	0.0123
41	Jun-24	3403	12.18	3204370	41449	0.0129
42	Jun-24	3732	12	3204370	44784	0.0140
43	Jun-24	4513	9.98	3204370	45040	0.0141



Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
44	Jun-24	1946	23.51	3204370	45750	0.0143
45	Jun-24	409	118	3204370	48262	0.0151
46	Jun-24	5758	8.39	3204370	48310	0.0151
47	Jun-24	2626	18.86	3204370	49526	0.0155
48	Jun-24	3599	13.91	3204370	50062	0.0156
49	Jun-24	2716	18.6	3204370	50518	0.0158
50	Jun-24	2564	20	3204370	51280	0.0160
51	Jun-24	1904	28.44	3204370	54150	0.0169
52	Jun-24	3314	16.41	3204370	54383	0.0170
53	Jun-24	1351	42	3204370	56742	0.0177
54	Jun-24	3266	18.39	3204370	60062	0.0187
55	Jun-24	2564	24	3204370	61536	0.0192
56	Jun-24	2382	25.99	3204370	61908	0.0193
57	Jun-24	7346	8.72	3204370	64057	0.0200
58	Jun-24	2440	27.88	3204370	68027	0.0212
59	Jun-24	4630	14.89	3204370	68941	0.0215
60	Jun-24	2585	27.23	3204370	70390	0.0220
61	Jun-24	3037	23.86	3204370	72463	0.0226
62	Jun-24	2755	26.63	3204370	73366	0.0229
63	Jun-24	3257	23.43	3204370	76312	0.0238
64	Jun-24	2877	30.73	3204370	88410	0.0276
65	Jun-24	3072	29.1	3204370	89395	0.0279
66	Jun-24	5334	18.79	3204370	100226	0.0313
67	Jun-24	3501	30.7	3204370	107481	0.0335
68	Jun-24	3061	37	3204370	113257	0.0353
69	Jun-24	3096	39.44	3204370	122106	0.0381
70	Jun-24	2206	59.49	3204370	131235	0.0410
71	Jun-24	3620	38.09	3204370	137886	0.0430
72	Jun-24	4687	29.75	3204370	139438	0.0435
73	Jun-24	6824	23.13	3204370	157839	0.0493
74	Jun-24	748	216	3204370	161568	0.0504
75	Jun-24	5587	29.6	3204370	165375	0.0516
76	Jun-24	9168	19.96	3204370	182993	0.0571
77	Jun-24	4905	38.18	3204370	187273	0.0584
78	Jun-24	4747	43.91	3204370	208441	0.0650
79	Jun-24	6712	32	3204370	214784	0.0670
80	Jun-24	9313	25.98	3204370	241952	0.0755
81	Jun-24	18316	21.38	3204370	391596	0.1222
82	Jun-24	6239	123.77	3204370	772201	0.2410
83	Jun-24	169	39.01	3204370	6593	0.0021
84	Jun-24	2731	19.28	3204370	52654	0.0164
85	Jun-24	1762	58.65	3204370	103341	0.0323
86	Jun-24	111	33	3204370	3663	0.0011
87	Jun-24	536	17	3204370	9112	0.0028
88	Jun-24	401	33	3204370	13233	0.0041
89	Jun-24	2959	18.04	3204370	53380	0.0167
90	Jun-24	3325	20.13	3204370	66932	0.0209
91	Jun-24	86	20	3204370	1720	0.0005
92	Jun-24	785	10.77	3204370	8454	0.0026
93	Jun-24	1156	12	3204370	13872	0.0043
94	Jun-24	408	34.54	3204370	14092	0.0044
95	Jun-24	3145	11	3204370	34595	0.0108
96	Jun-24	3985	15.06	3204370	60014	0.0187
97	Jun-24	2541	24.29	3204370	61721	0.0193

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
98	Jun-24	3271	27	3204370	88317	0.0276
99	Jun-24	4324	24.24	3204370	104814	0.0327
100	Jun-24	3706	36.46	3204370	135121	0.0422
Total		251359	26.08	3204370	6556354	2.0461

Remark :

- 1 Customer served by AEML are 3204370 nos.
- 2 Number of feeders are 1338 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(2) System Average Interruption Frequency Index (SAIFI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: April 2024**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
1	Apr-24	1	1	3194473	0.0000
2	Apr-24	1	1	3194473	0.0000
3	Apr-24	13	13	3194473	0.0000
4	Apr-24	19	19	3194473	0.0000
5	Apr-24	69	69	3194473	0.0000
6	Apr-24	33	33	3194473	0.0000
7	Apr-24	3	3	3194473	0.0000
8	Apr-24	180	180	3194473	0.0001
9	Apr-24	96	96	3194473	0.0000
10	Apr-24	115	115	3194473	0.0000
11	Apr-24	341	341	3194473	0.0001
12	Apr-24	78	78	3194473	0.0000
13	Apr-24	286	286	3194473	0.0001
14	Apr-24	141	141	3194473	0.0000
15	Apr-24	410	410	3194473	0.0001
16	Apr-24	265	265	3194473	0.0001
17	Apr-24	189	189	3194473	0.0001
18	Apr-24	270	270	3194473	0.0001
19	Apr-24	195	195	3194473	0.0001
20	Apr-24	567	567	3194473	0.0002
21	Apr-24	125	125	3194473	0.0000
22	Apr-24	271	271	3194473	0.0001
23	Apr-24	272	272	3194473	0.0001
24	Apr-24	227	227	3194473	0.0001
25	Apr-24	573	573	3194473	0.0002
26	Apr-24	279	279	3194473	0.0001
27	Apr-24	470	470	3194473	0.0001
28	Apr-24	514	514	3194473	0.0002
29	Apr-24	363	363	3194473	0.0001
30	Apr-24	439	439	3194473	0.0001
31	Apr-24	244	244	3194473	0.0001
32	Apr-24	163	163	3194473	0.0001
33	Apr-24	341	341	3194473	0.0001
34	Apr-24	287	287	3194473	0.0001
35	Apr-24	714	714	3194473	0.0002
36	Apr-24	1172	1172	3194473	0.0004
37	Apr-24	439	439	3194473	0.0001
38	Apr-24	1234	1234	3194473	0.0004
39	Apr-24	283	283	3194473	0.0001
40	Apr-24	552	552	3194473	0.0002
41	Apr-24	619	619	3194473	0.0002

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
42	Apr-24	556	556	3194473	0.0002
43	Apr-24	421	421	3194473	0.0001
44	Apr-24	476	476	3194473	0.0001
45	Apr-24	708	708	3194473	0.0002
46	Apr-24	829	829	3194473	0.0003
47	Apr-24	2408	2408	3194473	0.0008
48	Apr-24	619	619	3194473	0.0002
49	Apr-24	562	562	3194473	0.0002
50	Apr-24	855	855	3194473	0.0003
51	Apr-24	567	567	3194473	0.0002
52	Apr-24	983	983	3194473	0.0003
53	Apr-24	2900	2900	3194473	0.0009
54	Apr-24	911	911	3194473	0.0003
55	Apr-24	562	562	3194473	0.0002
56	Apr-24	879	879	3194473	0.0003
57	Apr-24	760	760	3194473	0.0002
58	Apr-24	628	628	3194473	0.0002
59	Apr-24	1141	1141	3194473	0.0004
60	Apr-24	4077	4077	3194473	0.0013
61	Apr-24	783	783	3194473	0.0002
62	Apr-24	929	929	3194473	0.0003
63	Apr-24	2048	2048	3194473	0.0006
64	Apr-24	939	939	3194473	0.0003
65	Apr-24	623	623	3194473	0.0002
66	Apr-24	1377	1377	3194473	0.0004
67	Apr-24	1475	1475	3194473	0.0005
68	Apr-24	3205	3205	3194473	0.0010
69	Apr-24	1689	1689	3194473	0.0005
70	Apr-24	2134	2134	3194473	0.0007
71	Apr-24	1303	1303	3194473	0.0004
72	Apr-24	585	585	3194473	0.0002
73	Apr-24	1072	1072	3194473	0.0003
74	Apr-24	3462	3462	3194473	0.0011
75	Apr-24	478	478	3194473	0.0001
76	Apr-24	672	672	3194473	0.0002
77	Apr-24	1645	1645	3194473	0.0005
78	Apr-24	1029	1029	3194473	0.0003
79	Apr-24	844	844	3194473	0.0003
80	Apr-24	1086	1086	3194473	0.0003
81	Apr-24	1591	1591	3194473	0.0005
82	Apr-24	1538	1538	3194473	0.0005
83	Apr-24	3751	3751	3194473	0.0012
84	Apr-24	1657	1657	3194473	0.0005
85	Apr-24	1481	1481	3194473	0.0005
86	Apr-24	2011	2011	3194473	0.0006
87	Apr-24	1486	1486	3194473	0.0005
88	Apr-24	2877	2877	3194473	0.0009
89	Apr-24	1490	1490	3194473	0.0005
90	Apr-24	3332	3332	3194473	0.0010
91	Apr-24	3581	3581	3194473	0.0011
92	Apr-24	2042	2042	3194473	0.0006

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
93	Apr-24	1787	1787	3194473	0.0006
94	Apr-24	2033	2033	3194473	0.0006
95	Apr-24	5495	5495	3194473	0.0017
96	Apr-24	4513	4513	3194473	0.0014
97	Apr-24	3711	3711	3194473	0.0012
98	Apr-24	1123	1123	3194473	0.0004
99	Apr-24	2073	2073	3194473	0.0006
100	Apr-24	2384	2384	3194473	0.0007
101	Apr-24	1493	1493	3194473	0.0005
102	Apr-24	1850	1850	3194473	0.0006
103	Apr-24	4908	4908	3194473	0.0015
104	Apr-24	4530	4530	3194473	0.0014
105	Apr-24	2446	2446	3194473	0.0008
106	Apr-24	2885	2885	3194473	0.0009
107	Apr-24	8268	8268	3194473	0.0026
108	Apr-24	2309	2309	3194473	0.0007
109	Apr-24	2750	2750	3194473	0.0009
110	Apr-24	2162	2162	3194473	0.0007
111	Apr-24	4973	4973	3194473	0.0016
112	Apr-24	3005	3005	3194473	0.0009
113	Apr-24	3854	3854	3194473	0.0012
114	Apr-24	1907	1907	3194473	0.0006
115	Apr-24	5336	5336	3194473	0.0017
116	Apr-24	1379	1379	3194473	0.0004
117	Apr-24	1924	1924	3194473	0.0006
118	Apr-24	9849	9849	3194473	0.0031
119	Apr-24	2799	2799	3194473	0.0009
120	Apr-24	4141	4141	3194473	0.0013
121	Apr-24	3005	3005	3194473	0.0009
122	Apr-24	2812	2812	3194473	0.0009
123	Apr-24	5371	5371	3194473	0.0017
124	Apr-24	3173	3173	3194473	0.0010
125	Apr-24	3422	3422	3194473	0.0011
126	Apr-24	4366	4366	3194473	0.0014
127	Apr-24	4841	4841	3194473	0.0015
128	Apr-24	4933	4933	3194473	0.0015
129	Apr-24	2862	2862	3194473	0.0009
130	Apr-24	4014	4014	3194473	0.0013
131	Apr-24	3897	3897	3194473	0.0012
132	Apr-24	4738	4738	3194473	0.0015
133	Apr-24	2791	2791	3194473	0.0009
134	Apr-24	6141	6141	3194473	0.0019
135	Apr-24	11977	11977	3194473	0.0037
136	Apr-24	2164	2164	3194473	0.0007
137	Apr-24	5339	5339	3194473	0.0017
138	Apr-24	3072	3072	3194473	0.0010
139	Apr-24	6266	6266	3194473	0.0020
140	Apr-24	2849	2849	3194473	0.0009
141	Apr-24	6644	6644	3194473	0.0021
142	Apr-24	2670	2670	3194473	0.0008
143	Apr-24	5179	5179	3194473	0.0016

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
144	Apr-24	4886	4886	3194473	0.0015
145	Apr-24	15210	15210	3194473	0.0048
146	Apr-24	5361	5361	3194473	0.0017
147	Apr-24	4323	4323	3194473	0.0014
148	Apr-24	6176	6176	3194473	0.0019
149	Apr-24	5780	5780	3194473	0.0018
150	Apr-24	10510	10510	3194473	0.0033
151	Apr-24	5252	5252	3194473	0.0016
152	Apr-24	6873	6873	3194473	0.0022
153	Apr-24	2058	2058	3194473	0.0006
154	Apr-24	2382	2382	3194473	0.0007
155	Apr-24	9740	9740	3194473	0.0030
156	Apr-24	1311	1311	3194473	0.0004
157	Apr-24	1386	1386	3194473	0.0004
158	Apr-24	4187	4187	3194473	0.0013
159	Apr-24	5252	5252	3194473	0.0016
160	Apr-24	9425	9425	3194473	0.0030
161	Apr-24	3014	3014	3194473	0.0009
162	Apr-24	293	293	3194473	0.0001
163	Apr-24	477	477	3194473	0.0001
164	Apr-24	733	733	3194473	0.0002
165	Apr-24	1086	1086	3194473	0.0003
166	Apr-24	1391	1391	3194473	0.0004
167	Apr-24	713	713	3194473	0.0002
168	Apr-24	1337	1337	3194473	0.0004
169	Apr-24	3569	3569	3194473	0.0011
170	Apr-24	6453	6453	3194473	0.0020
171	Apr-24	7258	7258	3194473	0.0023
172	Apr-24	5338	5338	3194473	0.0017
Total		418097	418097	3194473	0.1309

Remark :

- 1 Customer served by AEML are 3194473 nos.
- 2 Number of feeders are 1316 Nos.

**Annexure-VII**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(2) System Average Interruption Frequency Index (SAIFI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period:May 2024**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
1	May-24	1	1	3199722	0.0000
2	May-24	1	1	3199722	0.0000
3	May-24	1	1	3199722	0.0000
4	May-24	7	7	3199722	0.0000
5	May-24	12	12	3199722	0.0000
6	May-24	14	14	3199722	0.0000
7	May-24	37	37	3199722	0.0000
8	May-24	59	59	3199722	0.0000
9	May-24	126	126	3199722	0.0000
10	May-24	115	115	3199722	0.0000
11	May-24	113	113	3199722	0.0000
12	May-24	212	212	3199722	0.0001
13	May-24	377	377	3199722	0.0001
14	May-24	167	167	3199722	0.0001
15	May-24	311	311	3199722	0.0001
16	May-24	215	215	3199722	0.0001
17	May-24	142	142	3199722	0.0000
18	May-24	596	596	3199722	0.0002
19	May-24	140	140	3199722	0.0000
20	May-24	283	283	3199722	0.0001
21	May-24	278	278	3199722	0.0001
22	May-24	438	438	3199722	0.0001
23	May-24	280	280	3199722	0.0001
24	May-24	459	459	3199722	0.0001
25	May-24	638	638	3199722	0.0002
26	May-24	1161	1161	3199722	0.0004
27	May-24	512	512	3199722	0.0002
28	May-24	259	259	3199722	0.0001
29	May-24	238	238	3199722	0.0001
30	May-24	792	792	3199722	0.0002
31	May-24	286	286	3199722	0.0001
32	May-24	653	653	3199722	0.0002
33	May-24	791	791	3199722	0.0002
34	May-24	712	712	3199722	0.0002
35	May-24	666	666	3199722	0.0002
36	May-24	722	722	3199722	0.0002
37	May-24	722	722	3199722	0.0002
38	May-24	1018	1018	3199722	0.0003
39	May-24	691	691	3199722	0.0002
40	May-24	622	622	3199722	0.0002
41	May-24	410	410	3199722	0.0001

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
42	May-24	1313	1313	3199722	0.0004
43	May-24	387	387	3199722	0.0001
44	May-24	447	447	3199722	0.0001
45	May-24	703	703	3199722	0.0002
46	May-24	496	496	3199722	0.0002
47	May-24	597	597	3199722	0.0002
48	May-24	327	327	3199722	0.0001
49	May-24	514	514	3199722	0.0002
50	May-24	1550	1550	3199722	0.0005
51	May-24	1022	1022	3199722	0.0003
52	May-24	1341	1341	3199722	0.0004
53	May-24	1044	1044	3199722	0.0003
54	May-24	976	976	3199722	0.0003
55	May-24	1118	1118	3199722	0.0003
56	May-24	487	487	3199722	0.0002
57	May-24	1139	1139	3199722	0.0004
58	May-24	2598	2598	3199722	0.0008
59	May-24	1409	1409	3199722	0.0004
60	May-24	941	941	3199722	0.0003
61	May-24	3117	3117	3199722	0.0010
62	May-24	1674	1674	3199722	0.0005
63	May-24	902	902	3199722	0.0003
64	May-24	1831	1831	3199722	0.0006
65	May-24	1326	1326	3199722	0.0004
66	May-24	733	733	3199722	0.0002
67	May-24	1812	1812	3199722	0.0006
68	May-24	734	734	3199722	0.0002
69	May-24	1548	1548	3199722	0.0005
70	May-24	653	653	3199722	0.0002
71	May-24	1857	1857	3199722	0.0006
72	May-24	528	528	3199722	0.0002
73	May-24	594	594	3199722	0.0002
74	May-24	5047	5047	3199722	0.0016
75	May-24	1936	1936	3199722	0.0006
76	May-24	2225	2225	3199722	0.0007
77	May-24	1213	1213	3199722	0.0004
78	May-24	1818	1818	3199722	0.0006
79	May-24	1574	1574	3199722	0.0005
80	May-24	1525	1525	3199722	0.0005
81	May-24	2831	2831	3199722	0.0009
82	May-24	1123	1123	3199722	0.0004
83	May-24	1129	1129	3199722	0.0004
84	May-24	537	537	3199722	0.0002
85	May-24	1471	1471	3199722	0.0005
86	May-24	2654	2654	3199722	0.0008
87	May-24	1614	1614	3199722	0.0005
88	May-24	2307	2307	3199722	0.0007
89	May-24	869	869	3199722	0.0003
90	May-24	808	808	3199722	0.0003
91	May-24	1269	1269	3199722	0.0004
92	May-24	1518	1518	3199722	0.0005



Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
93	May-24	2231	2231	3199722	0.0007
94	May-24	1052	1052	3199722	0.0003
95	May-24	2436	2436	3199722	0.0008
96	May-24	1591	1591	3199722	0.0005
97	May-24	1319	1319	3199722	0.0004
98	May-24	1286	1286	3199722	0.0004
99	May-24	2354	2354	3199722	0.0007
100	May-24	2601	2601	3199722	0.0008
101	May-24	1394	1394	3199722	0.0004
102	May-24	5960	5960	3199722	0.0019
103	May-24	2326	2326	3199722	0.0007
104	May-24	1815	1815	3199722	0.0006
105	May-24	7213	7213	3199722	0.0023
106	May-24	6968	6968	3199722	0.0022
107	May-24	5958	5958	3199722	0.0019
108	May-24	3166	3166	3199722	0.0010
109	May-24	2805	2805	3199722	0.0009
110	May-24	2325	2325	3199722	0.0007
111	May-24	2433	2433	3199722	0.0008
112	May-24	577	577	3199722	0.0002
113	May-24	6924	6924	3199722	0.0022
114	May-24	3630	3630	3199722	0.0011
115	May-24	4323	4323	3199722	0.0014
116	May-24	6441	6441	3199722	0.0020
117	May-24	3532	3532	3199722	0.0011
118	May-24	9267	9267	3199722	0.0029
119	May-24	3720	3720	3199722	0.0012
120	May-24	2549	2549	3199722	0.0008
121	May-24	1490	1490	3199722	0.0005
122	May-24	1969	1969	3199722	0.0006
123	May-24	4030	4030	3199722	0.0013
124	May-24	2482	2482	3199722	0.0008
125	May-24	2382	2382	3199722	0.0007
126	May-24	3939	3939	3199722	0.0012
127	May-24	1413	1413	3199722	0.0004
128	May-24	1969	1969	3199722	0.0006
129	May-24	5780	5780	3199722	0.0018
130	May-24	7528	7528	3199722	0.0024
131	May-24	5325	5325	3199722	0.0017
132	May-24	6404	6404	3199722	0.0020
133	May-24	3669	3669	3199722	0.0011
134	May-24	4366	4366	3199722	0.0014
135	May-24	11283	11283	3199722	0.0035
136	May-24	10584	10584	3199722	0.0033
137	May-24	5000	5000	3199722	0.0016
138	May-24	6393	6393	3199722	0.0020
139	May-24	6270	6270	3199722	0.0020
140	May-24	6991	6991	3199722	0.0022
141	May-24	4933	4933	3199722	0.0015
142	May-24	4190	4190	3199722	0.0013
143	May-24	4146	4146	3199722	0.0013

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
144	May-24	3721	3721	3199722	0.0012
145	May-24	7630	7630	3199722	0.0024
146	May-24	2382	2382	3199722	0.0007
147	May-24	11107	11107	3199722	0.0035
148	May-24	2997	2997	3199722	0.0009
149	May-24	9475	9475	3199722	0.0030
150	May-24	6188	6188	3199722	0.0019
151	May-24	13914	13914	3199722	0.0043
152	May-24	6412	6412	3199722	0.0020
153	May-24	15915	15915	3199722	0.0050
154	May-24	3169	3169	3199722	0.0010
155	May-24	3164	3164	3199722	0.0010
156	May-24	9267	9267	3199722	0.0029
157	May-24	4883	4883	3199722	0.0015
158	May-24	502	502	3199722	0.0002
159	May-24	4987	4987	3199722	0.0016
160	May-24	4853	4853	3199722	0.0015
161	May-24	2	2	3199722	0.0000
162	May-24	49	49	3199722	0.0000
163	May-24	23	23	3199722	0.0000
164	May-24	248	248	3199722	0.0001
165	May-24	448	448	3199722	0.0001
166	May-24	4326	4326	3199722	0.0014
167	May-24	4326	4326	3199722	0.0014
Total		415183	415183	3199722	0.1298

Remark :

- 1 Customer served by AEML are 3199722 nos.
- 2 Number of feeders are 1332 Nos.

**Annexure-VII**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(2) System Average Interruption Frequency Index (SAIFI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: June 2024**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
1	Jun-24	14	14	3204370	0.0000
2	Jun-24	21	21	3204370	0.0000
3	Jun-24	71	71	3204370	0.0000
4	Jun-24	57	57	3204370	0.0000
5	Jun-24	215	215	3204370	0.0001
6	Jun-24	295	295	3204370	0.0001
7	Jun-24	768	768	3204370	0.0002
8	Jun-24	991	991	3204370	0.0003
9	Jun-24	934	934	3204370	0.0003
10	Jun-24	567	567	3204370	0.0002
11	Jun-24	348	348	3204370	0.0001
12	Jun-24	283	283	3204370	0.0001
13	Jun-24	708	708	3204370	0.0002
14	Jun-24	239	239	3204370	0.0001
15	Jun-24	387	387	3204370	0.0001
16	Jun-24	439	439	3204370	0.0001
17	Jun-24	542	542	3204370	0.0002
18	Jun-24	415	415	3204370	0.0001
19	Jun-24	577	577	3204370	0.0002
20	Jun-24	2352	2352	3204370	0.0007
21	Jun-24	997	997	3204370	0.0003
22	Jun-24	649	649	3204370	0.0002
23	Jun-24	558	558	3204370	0.0002
24	Jun-24	950	950	3204370	0.0003
25	Jun-24	862	862	3204370	0.0003
26	Jun-24	1125	1125	3204370	0.0004
27	Jun-24	1118	1118	3204370	0.0003
28	Jun-24	2913	2913	3204370	0.0009
29	Jun-24	3095	3095	3204370	0.0010
30	Jun-24	2078	2078	3204370	0.0006
31	Jun-24	734	734	3204370	0.0002
32	Jun-24	817	817	3204370	0.0003
33	Jun-24	3064	3064	3204370	0.0010
34	Jun-24	941	941	3204370	0.0003
35	Jun-24	1895	1895	3204370	0.0006
36	Jun-24	1467	1467	3204370	0.0005
37	Jun-24	839	839	3204370	0.0003
38	Jun-24	1088	1088	3204370	0.0003
39	Jun-24	3382	3382	3204370	0.0011
40	Jun-24	1053	1053	3204370	0.0003
41	Jun-24	3403	3403	3204370	0.0011

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
42	Jun-24	3732	3732	3204370	0.0012
43	Jun-24	4513	4513	3204370	0.0014
44	Jun-24	1946	1946	3204370	0.0006
45	Jun-24	409	409	3204370	0.0001
46	Jun-24	5758	5758	3204370	0.0018
47	Jun-24	2626	2626	3204370	0.0008
48	Jun-24	3599	3599	3204370	0.0011
49	Jun-24	2716	2716	3204370	0.0008
50	Jun-24	2564	2564	3204370	0.0008
51	Jun-24	1904	1904	3204370	0.0006
52	Jun-24	3314	3314	3204370	0.0010
53	Jun-24	1351	1351	3204370	0.0004
54	Jun-24	3266	3266	3204370	0.0010
55	Jun-24	2564	2564	3204370	0.0008
56	Jun-24	2382	2382	3204370	0.0007
57	Jun-24	7346	7346	3204370	0.0023
58	Jun-24	2440	2440	3204370	0.0008
59	Jun-24	4630	4630	3204370	0.0014
60	Jun-24	2585	2585	3204370	0.0008
61	Jun-24	3037	3037	3204370	0.0009
62	Jun-24	2755	2755	3204370	0.0009
63	Jun-24	3257	3257	3204370	0.0010
64	Jun-24	2877	2877	3204370	0.0009
65	Jun-24	3072	3072	3204370	0.0010
66	Jun-24	5334	5334	3204370	0.0017
67	Jun-24	3501	3501	3204370	0.0011
68	Jun-24	3061	3061	3204370	0.0010
69	Jun-24	3096	3096	3204370	0.0010
70	Jun-24	2206	2206	3204370	0.0007
71	Jun-24	3620	3620	3204370	0.0011
72	Jun-24	4687	4687	3204370	0.0015
73	Jun-24	6824	6824	3204370	0.0021
74	Jun-24	748	748	3204370	0.0002
75	Jun-24	5587	5587	3204370	0.0017
76	Jun-24	9168	9168	3204370	0.0029
77	Jun-24	4905	4905	3204370	0.0015
78	Jun-24	4747	4747	3204370	0.0015
79	Jun-24	6712	6712	3204370	0.0021
80	Jun-24	9313	9313	3204370	0.0029
81	Jun-24	18316	18316	3204370	0.0057
82	Jun-24	6239	6239	3204370	0.0019
83	Jun-24	169	169	3204370	0.0001
84	Jun-24	2731	2731	3204370	0.0009
85	Jun-24	1762	1762	3204370	0.0005
86	Jun-24	111	111	3204370	0.0000
87	Jun-24	536	536	3204370	0.0002
88	Jun-24	401	401	3204370	0.0001
89	Jun-24	2959	2959	3204370	0.0009
90	Jun-24	3325	3325	3204370	0.0010
91	Jun-24	86	86	3204370	0.0000
92	Jun-24	785	785	3204370	0.0002

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
93	Jun-24	1156	1156	3204370	0.0004
94	Jun-24	408	408	3204370	0.0001
95	Jun-24	3145	3145	3204370	0.0010
96	Jun-24	3985	3985	3204370	0.0012
97	Jun-24	2541	2541	3204370	0.0008
98	Jun-24	3271	3271	3204370	0.0010
99	Jun-24	4324	4324	3204370	0.0013
100	Jun-24	3706	3706	3204370	0.0012
Total		251359	251359	3204370	0.0784

Remark :

- 1 Customer served by AEML are 3204370 nos.
- 2 Number of feeders are 1338 Nos.

**Annexure-VII**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(3) Customer Average Interruption Duration Index (CAIDI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: April 2024**

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
1	Apr-24	0.0000	0.0000	22.2000
2	Apr-24	0.0000	0.0000	34.8000
3	Apr-24	0.0001	0.0000	16.9800
4	Apr-24	0.0001	0.0000	18.0000
5	Apr-24	0.0002	0.0000	9.0000
6	Apr-24	0.0002	0.0000	22.0000
7	Apr-24	0.0003	0.0000	271.2000
8	Apr-24	0.0004	0.0001	7.0000
9	Apr-24	0.0006	0.0000	20.0000
10	Apr-24	0.0007	0.0000	19.0000
11	Apr-24	0.0007	0.0001	7.0000
12	Apr-24	0.0008	0.0000	31.0000
13	Apr-24	0.0009	0.0001	9.8900
14	Apr-24	0.0010	0.0000	23.0000
15	Apr-24	0.0010	0.0001	7.9300
16	Apr-24	0.0011	0.0001	13.0000
17	Apr-24	0.0012	0.0001	21.0000
18	Apr-24	0.0013	0.0001	15.0000
19	Apr-24	0.0013	0.0001	22.0000
20	Apr-24	0.0014	0.0002	8.0000
21	Apr-24	0.0014	0.0000	37.0000
22	Apr-24	0.0015	0.0001	18.0000
23	Apr-24	0.0016	0.0001	19.0000
24	Apr-24	0.0016	0.0001	23.0000
25	Apr-24	0.0020	0.0002	11.3200
26	Apr-24	0.0020	0.0001	23.3900
27	Apr-24	0.0022	0.0001	15.1100
28	Apr-24	0.0023	0.0002	14.4300
29	Apr-24	0.0025	0.0001	22.0000
30	Apr-24	0.0026	0.0001	19.0000
31	Apr-24	0.0028	0.0001	37.0000
32	Apr-24	0.0029	0.0001	56.0000
33	Apr-24	0.0030	0.0001	28.0000
34	Apr-24	0.0031	0.0001	34.1500
35	Apr-24	0.0031	0.0002	14.0200
36	Apr-24	0.0032	0.0004	8.6300
37	Apr-24	0.0033	0.0001	24.0000
38	Apr-24	0.0034	0.0004	8.7800
39	Apr-24	0.0035	0.0001	39.0000
40	Apr-24	0.0035	0.0002	20.0000
41	Apr-24	0.0037	0.0002	19.0000
42	Apr-24	0.0038	0.0002	21.9300
43	Apr-24	0.0038	0.0001	29.0000
44	Apr-24	0.0039	0.0001	26.0000
45	Apr-24	0.0047	0.0002	21.0000
46	Apr-24	0.0048	0.0003	18.4200
47	Apr-24	0.0053	0.0008	7.0000

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
48	Apr-24	0.0056	0.0002	29.0000
49	Apr-24	0.0056	0.0002	32.0000
50	Apr-24	0.0062	0.0003	23.0000
51	Apr-24	0.0062	0.0002	35.0000
52	Apr-24	0.0063	0.0003	20.5300
53	Apr-24	0.0064	0.0009	7.0000
54	Apr-24	0.0065	0.0003	22.7000
55	Apr-24	0.0066	0.0002	37.3400
56	Apr-24	0.0067	0.0003	24.5000
57	Apr-24	0.0068	0.0002	28.3800
58	Apr-24	0.0075	0.0002	38.0700
59	Apr-24	0.0075	0.0004	20.9500
60	Apr-24	0.0077	0.0013	6.0000
61	Apr-24	0.0081	0.0002	33.0200
62	Apr-24	0.0084	0.0003	29.0000
63	Apr-24	0.0090	0.0006	14.0000
64	Apr-24	0.0091	0.0003	31.0000
65	Apr-24	0.0092	0.0002	47.0300
66	Apr-24	0.0094	0.0004	21.7500
67	Apr-24	0.0097	0.0005	21.0000
68	Apr-24	0.0097	0.0010	9.7100
69	Apr-24	0.0098	0.0005	18.4900
70	Apr-24	0.0101	0.0007	15.0600
71	Apr-24	0.0101	0.0004	24.7000
72	Apr-24	0.0102	0.0002	55.5800
73	Apr-24	0.0108	0.0003	32.1400
74	Apr-24	0.0108	0.0011	10.0000
75	Apr-24	0.0110	0.0001	73.5300
76	Apr-24	0.0110	0.0002	52.4800
77	Apr-24	0.0116	0.0005	22.5200
78	Apr-24	0.0122	0.0003	38.0000
79	Apr-24	0.0123	0.0003	46.4800
80	Apr-24	0.0123	0.0003	36.1800
81	Apr-24	0.0123	0.0005	24.7700
82	Apr-24	0.0128	0.0005	26.5700
83	Apr-24	0.0129	0.0012	11.0000
84	Apr-24	0.0130	0.0005	25.0000
85	Apr-24	0.0138	0.0005	29.7600
86	Apr-24	0.0139	0.0006	22.0800
87	Apr-24	0.0139	0.0005	29.9700
88	Apr-24	0.0144	0.0009	16.0000
89	Apr-24	0.0144	0.0005	30.9600
90	Apr-24	0.0151	0.0010	14.5200
91	Apr-24	0.0152	0.0011	13.5300
92	Apr-24	0.0160	0.0006	25.0000
93	Apr-24	0.0163	0.0006	29.0600
94	Apr-24	0.0166	0.0006	26.0300
95	Apr-24	0.0171	0.0017	9.9300
96	Apr-24	0.0172	0.0014	12.1800
97	Apr-24	0.0174	0.0012	15.0200
98	Apr-24	0.0179	0.0004	50.8700
99	Apr-24	0.0179	0.0006	27.5800
100	Apr-24	0.0186	0.0007	24.9600
101	Apr-24	0.0188	0.0005	40.1900
102	Apr-24	0.0189	0.0006	32.6200
103	Apr-24	0.0190	0.0015	12.3600
104	Apr-24	0.0191	0.0014	13.4800

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
105	Apr-24	0.0200	0.0008	26.1800
106	Apr-24	0.0209	0.0009	23.0900
107	Apr-24	0.0209	0.0026	8.0900
108	Apr-24	0.0210	0.0007	29.0000
109	Apr-24	0.0219	0.0009	25.4500
110	Apr-24	0.0235	0.0007	34.6800
111	Apr-24	0.0242	0.0016	15.5300
112	Apr-24	0.0243	0.0009	25.8600
113	Apr-24	0.0244	0.0012	20.2300
114	Apr-24	0.0245	0.0006	41.0000
115	Apr-24	0.0246	0.0017	14.7100
116	Apr-24	0.0249	0.0004	57.7100
117	Apr-24	0.0261	0.0006	43.4100
118	Apr-24	0.0264	0.0031	8.5600
119	Apr-24	0.0268	0.0009	30.6000
120	Apr-24	0.0279	0.0013	21.5100
121	Apr-24	0.0290	0.0009	30.8200
122	Apr-24	0.0290	0.0009	32.9600
123	Apr-24	0.0291	0.0017	17.2900
124	Apr-24	0.0313	0.0010	31.5200
125	Apr-24	0.0336	0.0011	31.3700
126	Apr-24	0.0339	0.0014	24.8200
127	Apr-24	0.0358	0.0015	23.6500
128	Apr-24	0.0382	0.0015	24.7100
129	Apr-24	0.0386	0.0009	43.0800
130	Apr-24	0.0388	0.0013	30.8900
131	Apr-24	0.0391	0.0012	32.0900
132	Apr-24	0.0403	0.0015	27.1400
133	Apr-24	0.0423	0.0009	48.4600
134	Apr-24	0.0429	0.0019	22.3300
135	Apr-24	0.0446	0.0037	11.9000
136	Apr-24	0.0449	0.0007	66.2800
137	Apr-24	0.0456	0.0017	27.3000
138	Apr-24	0.0465	0.0010	48.3400
139	Apr-24	0.0468	0.0020	23.8400
140	Apr-24	0.0517	0.0009	57.9300
141	Apr-24	0.0530	0.0021	25.4800
142	Apr-24	0.0563	0.0008	67.3300
143	Apr-24	0.0631	0.0016	38.9400
144	Apr-24	0.0671	0.0015	43.8700
145	Apr-24	0.0698	0.0048	14.6600
146	Apr-24	0.0717	0.0017	42.7500
147	Apr-24	0.0780	0.0014	57.6500
148	Apr-24	0.0902	0.0019	46.6800
149	Apr-24	0.0920	0.0018	50.8400
150	Apr-24	0.1003	0.0033	30.4800
151	Apr-24	0.1089	0.0016	66.2300
152	Apr-24	0.1262	0.0022	58.6700
153	Apr-24	0.1605	0.0006	249.1300
154	Apr-24	0.5886	0.0007	789.4300
155	Apr-24	1.3231	0.0030	433.9500
156	Apr-24	0.0069	0.0004	16.7900
157	Apr-24	0.0094	0.0004	21.7200
158	Apr-24	0.0775	0.0013	59.1600
159	Apr-24	0.1491	0.0016	90.6800
160	Apr-24	0.8890	0.0030	301.3100
161	Apr-24	0.0340	0.0009	36.0000



Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
162	Apr-24	0.0006	0.0001	6.0000
163	Apr-24	0.0016	0.0001	11.0000
164	Apr-24	0.0030	0.0002	13.0000
165	Apr-24	0.0031	0.0003	9.0000
166	Apr-24	0.0046	0.0004	10.4700
167	Apr-24	0.0060	0.0002	27.0000
168	Apr-24	0.0188	0.0004	44.8500
169	Apr-24	0.0260	0.0011	23.2300
170	Apr-24	0.0303	0.0020	15.0000
171	Apr-24	0.0341	0.0023	15.0000
172	Apr-24	0.0384	0.0017	23.0000
Total		6.3131	0.1309	48.24

Remark :

- 1 Customer served by AEML are 3194473 nos.
- 2 Number of feeders are 1316 Nos.

**Annexure-VII**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(3) Customer Average Interruption Duration Index (CAIDI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period:May 2024**

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
1	May-24	0.0000	0.0000	36.0000
2	May-24	0.0000	0.0000	37.2000
3	May-24	0.0000	0.0000	42.0000
4	May-24	0.0001	0.0000	31.0300
5	May-24	0.0001	0.0000	19.0000
6	May-24	0.0002	0.0000	43.7100
7	May-24	0.0003	0.0000	24.0000
8	May-24	0.0003	0.0000	17.0000
9	May-24	0.0006	0.0000	15.0000
10	May-24	0.0006	0.0000	16.7000
11	May-24	0.0006	0.0000	18.0000
12	May-24	0.0007	0.0001	10.0000
13	May-24	0.0008	0.0001	7.0000
14	May-24	0.0013	0.0001	24.4400
15	May-24	0.0013	0.0001	13.5900
16	May-24	0.0013	0.0001	20.0000
17	May-24	0.0014	0.0000	30.5500
18	May-24	0.0017	0.0002	9.0000
19	May-24	0.0019	0.0000	44.0000
20	May-24	0.0022	0.0001	25.0000
21	May-24	0.0023	0.0001	26.0000
22	May-24	0.0023	0.0001	16.6200
23	May-24	0.0025	0.0001	29.0000
24	May-24	0.0026	0.0001	18.0000
25	May-24	0.0026	0.0002	13.0400
26	May-24	0.0027	0.0004	7.3100
27	May-24	0.0027	0.0002	16.8500
28	May-24	0.0030	0.0001	36.9200
29	May-24	0.0032	0.0001	43.0300
30	May-24	0.0032	0.0002	13.0000
31	May-24	0.0034	0.0001	38.0000
32	May-24	0.0035	0.0002	17.0800
33	May-24	0.0035	0.0002	14.1700
34	May-24	0.0036	0.0002	16.0100
35	May-24	0.0037	0.0002	18.0000
36	May-24	0.0038	0.0002	16.7100
37	May-24	0.0038	0.0002	16.8800
38	May-24	0.0038	0.0003	12.0500
39	May-24	0.0039	0.0002	18.0000
40	May-24	0.0039	0.0002	20.0300
41	May-24	0.0040	0.0001	31.0000
42	May-24	0.0040	0.0004	9.8400
43	May-24	0.0041	0.0001	34.1900
44	May-24	0.0042	0.0001	30.3300
45	May-24	0.0043	0.0002	19.6100
46	May-24	0.0045	0.0002	29.0000
47	May-24	0.0047	0.0002	25.0000

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
48	May-24	0.0049	0.0001	47.6800
49	May-24	0.0050	0.0002	31.0000
50	May-24	0.0051	0.0005	10.5200
51	May-24	0.0052	0.0003	16.4100
52	May-24	0.0054	0.0004	13.0000
53	May-24	0.0057	0.0003	17.3600
54	May-24	0.0058	0.0003	19.0000
55	May-24	0.0058	0.0003	16.6800
56	May-24	0.0060	0.0002	39.2500
57	May-24	0.0064	0.0004	18.0000
58	May-24	0.0065	0.0008	8.0500
59	May-24	0.0066	0.0004	14.9800
60	May-24	0.0072	0.0003	24.5800
61	May-24	0.0073	0.0010	7.4600
62	May-24	0.0074	0.0005	14.1500
63	May-24	0.0076	0.0003	27.0000
64	May-24	0.0078	0.0006	13.6700
65	May-24	0.0079	0.0004	19.0000
66	May-24	0.0080	0.0002	35.0000
67	May-24	0.0080	0.0006	14.1700
68	May-24	0.0080	0.0002	35.0000
69	May-24	0.0083	0.0005	17.0900
70	May-24	0.0086	0.0002	42.0500
71	May-24	0.0088	0.0006	15.2000
72	May-24	0.0092	0.0002	55.6500
73	May-24	0.0094	0.0002	50.3700
74	May-24	0.0095	0.0016	6.0000
75	May-24	0.0095	0.0006	15.6900
76	May-24	0.0095	0.0007	13.6900
77	May-24	0.0099	0.0004	26.0000
78	May-24	0.0100	0.0006	17.5600
79	May-24	0.0101	0.0005	20.4600
80	May-24	0.0105	0.0005	22.0000
81	May-24	0.0105	0.0009	11.9200
82	May-24	0.0109	0.0004	30.9900
83	May-24	0.0120	0.0004	34.0000
84	May-24	0.0122	0.0002	72.9300
85	May-24	0.0124	0.0005	26.8900
86	May-24	0.0125	0.0008	15.1000
87	May-24	0.0126	0.0005	25.0400
88	May-24	0.0130	0.0007	18.0000
89	May-24	0.0130	0.0003	47.8700
90	May-24	0.0133	0.0003	52.5200
91	May-24	0.0134	0.0004	33.7000
92	May-24	0.0135	0.0005	28.5500
93	May-24	0.0144	0.0007	20.6500
94	May-24	0.0151	0.0003	45.8000
95	May-24	0.0152	0.0008	20.0000
96	May-24	0.0153	0.0005	30.6800
97	May-24	0.0153	0.0004	37.2100
98	May-24	0.0155	0.0004	38.5100
99	May-24	0.0156	0.0007	21.2700
100	May-24	0.0161	0.0008	19.7700
101	May-24	0.0162	0.0004	37.1100
102	May-24	0.0163	0.0019	8.7500
103	May-24	0.0169	0.0007	23.2200
104	May-24	0.0177	0.0006	31.2300

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
105	May-24	0.0180	0.0023	8.0000
106	May-24	0.0185	0.0022	8.4800
107	May-24	0.0186	0.0019	10.0000
108	May-24	0.0198	0.0010	20.0000
109	May-24	0.0203	0.0009	23.1100
110	May-24	0.0211	0.0007	29.0000
111	May-24	0.0213	0.0008	27.9900
112	May-24	0.0216	0.0002	120.0000
113	May-24	0.0239	0.0022	11.0500
114	May-24	0.0240	0.0011	21.1200
115	May-24	0.0255	0.0014	18.8400
116	May-24	0.0262	0.0020	13.0000
117	May-24	0.0265	0.0011	24.0000
118	May-24	0.0276	0.0029	9.5200
119	May-24	0.0279	0.0012	24.0000
120	May-24	0.0286	0.0008	35.8700
121	May-24	0.0289	0.0005	62.0000
122	May-24	0.0304	0.0006	49.3700
123	May-24	0.0305	0.0013	24.2400
124	May-24	0.0317	0.0008	40.9200
125	May-24	0.0320	0.0007	43.0000
126	May-24	0.0320	0.0012	26.0300
127	May-24	0.0325	0.0004	73.6800
128	May-24	0.0332	0.0006	54.0000
129	May-24	0.0361	0.0018	19.9700
130	May-24	0.0376	0.0024	16.0000
131	May-24	0.0387	0.0017	23.2300
132	May-24	0.0420	0.0020	21.0000
133	May-24	0.0432	0.0011	37.6800
134	May-24	0.0467	0.0014	34.2400
135	May-24	0.0490	0.0035	13.8900
136	May-24	0.0508	0.0033	15.3700
137	May-24	0.0528	0.0016	33.7700
138	May-24	0.0551	0.0020	27.5900
139	May-24	0.0557	0.0020	28.4200
140	May-24	0.0568	0.0022	26.0000
141	May-24	0.0578	0.0015	37.5000
142	May-24	0.0579	0.0013	44.2300
143	May-24	0.0587	0.0013	45.2700
144	May-24	0.0594	0.0012	51.1000
145	May-24	0.0651	0.0024	27.3200
146	May-24	0.0774	0.0007	104.0000
147	May-24	0.0774	0.0035	22.3100
148	May-24	0.0890	0.0009	95.0000
149	May-24	0.0952	0.0030	32.1600
150	May-24	0.0963	0.0019	49.8000
151	May-24	0.0975	0.0043	22.4200
152	May-24	0.0988	0.0020	49.2800
153	May-24	0.1013	0.0050	20.3700
154	May-24	0.1109	0.0010	112.0000
155	May-24	0.1187	0.0010	120.0000
156	May-24	0.1358	0.0029	46.9000
157	May-24	0.2548	0.0015	166.9800
158	May-24	0.0035	0.0002	22.1100
159	May-24	0.0343	0.0016	22.0000
160	May-24	0.0231	0.0015	15.2600
161	May-24	0.0000	0.0000	54.9000

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
162	May-24	0.0002	0.0000	10.0000
163	May-24	0.0012	0.0000	169.8000
164	May-24	0.0016	0.0001	20.0000
165	May-24	0.0032	0.0001	23.0000
166	May-24	0.0097	0.0014	7.1800
167	May-24	0.0122	0.0014	9.0000
Total		3.6250	0.1298	27.94

Remark :

- 1 Customer served by AEML are 3199722 nos.
- 2 Number of feeders are 1332 Nos.

**Annexure-VII**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(3) Customer Average Interruption Duration Index (CAIDI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: June 2024**

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
1	Jun-24	0.0001	0.0000	22.7100
2	Jun-24	0.0002	0.0000	26.0000
3	Jun-24	0.0004	0.0000	19.0000
4	Jun-24	0.0007	0.0000	37.0000
5	Jun-24	0.0015	0.0001	23.0000
6	Jun-24	0.0017	0.0001	18.0000
7	Jun-24	0.0017	0.0002	7.0000
8	Jun-24	0.0020	0.0003	6.5600
9	Jun-24	0.0020	0.0003	7.0000
10	Jun-24	0.0021	0.0002	11.9300
11	Jun-24	0.0023	0.0001	21.0000
12	Jun-24	0.0026	0.0001	30.0000
13	Jun-24	0.0027	0.0002	12.0000
14	Jun-24	0.0027	0.0001	36.2400
15	Jun-24	0.0033	0.0001	27.3200
16	Jun-24	0.0037	0.0001	27.0000
17	Jun-24	0.0037	0.0002	22.0000
18	Jun-24	0.0038	0.0001	29.0000
19	Jun-24	0.0042	0.0002	23.3300
20	Jun-24	0.0044	0.0007	6.0000
21	Jun-24	0.0047	0.0003	15.0000
22	Jun-24	0.0048	0.0002	23.5900
23	Jun-24	0.0054	0.0002	31.0800
24	Jun-24	0.0062	0.0003	20.8100
25	Jun-24	0.0064	0.0003	23.7200
26	Jun-24	0.0068	0.0004	19.4300
27	Jun-24	0.0070	0.0003	20.0000
28	Jun-24	0.0073	0.0009	8.0000
29	Jun-24	0.0087	0.0010	9.0000
30	Jun-24	0.0087	0.0006	13.4300
31	Jun-24	0.0090	0.0002	39.4100
32	Jun-24	0.0095	0.0003	37.2600
33	Jun-24	0.0096	0.0010	10.0000
34	Jun-24	0.0100	0.0003	34.1000
35	Jun-24	0.0101	0.0006	17.0000
36	Jun-24	0.0101	0.0005	21.9900
37	Jun-24	0.0105	0.0003	40.0500
38	Jun-24	0.0119	0.0003	35.0000
39	Jun-24	0.0120	0.0011	11.3800
40	Jun-24	0.0123	0.0003	37.4500
41	Jun-24	0.0129	0.0011	12.1800
42	Jun-24	0.0140	0.0012	12.0000
43	Jun-24	0.0141	0.0014	9.9800
44	Jun-24	0.0143	0.0006	23.5100
45	Jun-24	0.0151	0.0001	118.0000
46	Jun-24	0.0151	0.0018	8.3900
47	Jun-24	0.0155	0.0008	18.8600

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
48	Jun-24	0.0156	0.0011	13.9100
49	Jun-24	0.0158	0.0008	18.6000
50	Jun-24	0.0160	0.0008	20.0000
51	Jun-24	0.0169	0.0006	28.4400
52	Jun-24	0.0170	0.0010	16.4100
53	Jun-24	0.0177	0.0004	42.0000
54	Jun-24	0.0187	0.0010	18.3900
55	Jun-24	0.0192	0.0008	24.0000
56	Jun-24	0.0193	0.0007	25.9900
57	Jun-24	0.0200	0.0023	8.7200
58	Jun-24	0.0212	0.0008	27.8800
59	Jun-24	0.0215	0.0014	14.8900
60	Jun-24	0.0220	0.0008	27.2300
61	Jun-24	0.0226	0.0009	23.8600
62	Jun-24	0.0229	0.0009	26.6300
63	Jun-24	0.0238	0.0010	23.4300
64	Jun-24	0.0276	0.0009	30.7300
65	Jun-24	0.0279	0.0010	29.1000
66	Jun-24	0.0313	0.0017	18.7900
67	Jun-24	0.0335	0.0011	30.7000
68	Jun-24	0.0353	0.0010	37.0000
69	Jun-24	0.0381	0.0010	39.4400
70	Jun-24	0.0410	0.0007	59.4900
71	Jun-24	0.0430	0.0011	38.0900
72	Jun-24	0.0435	0.0015	29.7500
73	Jun-24	0.0493	0.0021	23.1300
74	Jun-24	0.0504	0.0002	216.0000
75	Jun-24	0.0516	0.0017	29.6000
76	Jun-24	0.0571	0.0029	19.9600
77	Jun-24	0.0584	0.0015	38.1800
78	Jun-24	0.0650	0.0015	43.9100
79	Jun-24	0.0670	0.0021	32.0000
80	Jun-24	0.0755	0.0029	25.9800
81	Jun-24	0.1222	0.0057	21.3800
82	Jun-24	0.2410	0.0019	123.7700
83	Jun-24	0.0021	0.0001	39.0100
84	Jun-24	0.0164	0.0009	19.2800
85	Jun-24	0.0323	0.0005	58.6500
86	Jun-24	0.0011	0.0000	33.0000
87	Jun-24	0.0028	0.0002	17.0000
88	Jun-24	0.0041	0.0001	33.0000
89	Jun-24	0.0167	0.0009	18.0400
90	Jun-24	0.0209	0.0010	20.1300
91	Jun-24	0.0005	0.0000	20.0000
92	Jun-24	0.0026	0.0002	10.7700
93	Jun-24	0.0043	0.0004	12.0000
94	Jun-24	0.0044	0.0001	34.5400
95	Jun-24	0.0108	0.0010	11.0000
96	Jun-24	0.0187	0.0012	15.0600
97	Jun-24	0.0193	0.0008	24.2900
98	Jun-24	0.0276	0.0010	27.0000
99	Jun-24	0.0327	0.0013	24.2400
100	Jun-24	0.0422	0.0012	36.4600
Total		2.0461	0.0784	26.08

Remark :

1 Customer served by AEML are 3204370 nos.

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
--------	-------	-------	-------	--------------------------------

2 Number of feeders are 1338 Nos.



**Annexure-VII**  
**Performance Report regarding Reliability Indices**  
**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**

**(4) Customer Average Interruption Duration Index (CAIDI) for HT Consumers**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**

**Period: April 2024**

Sr.No.	Month	Ni = Number of HT consumers who experienced a sustained interruption	Ri = Restoration time for each interruption event of HT Consumers	Sum(Ri*Ni) for all HT Consumers	CAIDI=(5)/(3)
(1)	(2)	(3)	(4)	(5)	(6)
1	Apr-24	1	84	84	84
2	Apr-24	1	29	29	29
3	Apr-24	1	9	9	9
4	Apr-24	1	19	19	19
5	Apr-24	1	22	22	22
6	Apr-24	1	323	323	323
7	Apr-24	1	14	14	14
8	Apr-24	1	24	24	24
9	Apr-24	1	48	48	48
10	Apr-24	1	8	8	8
11	Apr-24	1	15	15	15
12	Apr-24	1	47	47	47
13	Apr-24	1	21	21	21
14	Apr-24	1	8	8	8
15	Apr-24	1	15	15	15
16	Apr-24	1	16	16	16
17	Apr-24	1	6	6	6
18	Apr-24	1	6	6	6
19	Apr-24	1	7	7	7
20	Apr-24	1	9	9	9
21	Apr-24	1	10	10	10
22	Apr-24	1	8	8	8
23	Apr-24	1	50	50	50
24	Apr-24	1	15	15	15
25	Apr-24	1	14	14	14
26	Apr-24	1	13	13	13
27	Apr-24	1	7	7	7
28	Apr-24	1	35	35	35
29	Apr-24	1	21	21	21
30	Apr-24	1	10	10	10
31	Apr-24	1	24	24	24
32	Apr-24	1	9	9	9
33	Apr-24	1	84	84	84
34	Apr-24	1	9	9	9
35	Apr-24	1	9	9	9
36	Apr-24	1	6	6	6
37	Apr-24	1	9	9	9
38	Apr-24	1	20	20	20
39	Apr-24	1	10	10	10
40	Apr-24	1	25	25	25
41	Apr-24	1	25	25	25
42	Apr-24	1	16	16	16
43	Apr-24	1	13	13	13
44	Apr-24	1	9	9	9
45	Apr-24	1	18	18	18

Sr.No.	Month	Ni = Number of HT consumers who experienced a sustained interruption	Ri = Restoration time for each interruption event of HT Consumers	Sum(Ri*Ni) for all HT Consumers	CAIDI=(5)/(3)
46	Apr-24	1	16	16	16
47	Apr-24	1	10	10	10
48	Apr-24	1	18	18	18
49	Apr-24	1	9	9	9
50	Apr-24	1	19	19	19
51	Apr-24	1	18	18	18
52	Apr-24	1	23	23	23
53	Apr-24	1	6	6	6
54	Apr-24	1	51	51	51
55	Apr-24	1	29	29	29
56	Apr-24	1	11	11	11
57	Apr-24	1	69	69	69
58	Apr-24	1	89	89	89
59	Apr-24	1	49	49	49
60	Apr-24	1	15	15	15
61	Apr-24	1	20	20	20
62	Apr-24	1	7	7	7
63	Apr-24	1	10	10	10
64	Apr-24	1	34	34	34
65	Apr-24	1	9	9	9
66	Apr-24	1	30	30	30
67	Apr-24	1	24	24	24
68	Apr-24	1	7	7	7
69	Apr-24	1	15	15	15
70	Apr-24	1	51	51	51
71	Apr-24	1	6	6	6
72	Apr-24	1	29	29	29
TOTAL		72	26.01	1873	26.01

Note: CAIDI for HT consumers provided in this report has been calculated based on meter reading data.

**Annexure-VII**  
**Performance Report regarding Reliability Indices**  
**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**

**(4) Customer Average Interruption Duration Index (CAIDI) for HT Consumers**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**

**Period:May 2024**

Sr.No.	Month	Ni = Number of HT consumers who experienced a sustained interruption	Ri = Restoration time for each interruption event of HT Consumers	Sum(Ri*Ni) for all HT Consumers	CAIDI=(5)/(3)
(1)	(2)	(3)	(4)	(5)	(6)
1	May-24	1	7	7	7
2	May-24	1	13	13	13
3	May-24	1	8	8	8
4	May-24	1	11	11	11
5	May-24	1	45	45	45
6	May-24	1	7	7	7
7	May-24	1	9	9	9
8	May-24	1	29	29	29
9	May-24	1	46	46	46
10	May-24	1	10	10	10
11	May-24	1	8	8	8
12	May-24	1	23	23	23
13	May-24	1	20	20	20
14	May-24	1	16	16	16
15	May-24	1	20	20	20
16	May-24	1	15	15	15
17	May-24	1	20	20	20
18	May-24	1	7	7	7
19	May-24	1	9	9	9
20	May-24	1	53	53	53
21	May-24	1	12	12	12
22	May-24	1	51	51	51
23	May-24	1	8	8	8
24	May-24	1	16	16	16
25	May-24	1	16	16	16
26	May-24	1	6	6	6
27	May-24	1	25	25	25
28	May-24	1	7	7	7
29	May-24	1	6	6	6
30	May-24	1	14	14	14
31	May-24	1	13	13	13
32	May-24	1	73	73	73
33	May-24	1	36	36	36
34	May-24	1	39	39	39
35	May-24	1	38	38	38
36	May-24	1	30	30	30
37	May-24	1	10	10	10
38	May-24	1	299	299	299
39	May-24	1	27	27	27
40	May-24	1	21	21	21
41	May-24	1	15	15	15
42	May-24	1	15	15	15
43	May-24	1	9	9	9
44	May-24	1	9	9	9
45	May-24	1	45	45	45

Sr.No.	Month	Ni = Number of HT consumers who experienced a sustained interruption	Ri = Restoration time for each interruption event of HT Consumers	Sum(Ri*Ni) for all HT Consumers	CAIDI=(5)/(3)
46	May-24	1	45	45	45
47	May-24	1	7	7	7
48	May-24	1	23	23	23
49	May-24	1	30	30	30
50	May-24	1	30	30	30
51	May-24	1	8	8	8
52	May-24	1	6	6	6
53	May-24	1	9	9	9
54	May-24	1	9	9	9
55	May-24	1	47	47	47
56	May-24	1	33	33	33
57	May-24	1	19	19	19
58	May-24	1	6	6	6
59	May-24	1	58	58	58
60	May-24	1	26	26	26
61	May-24	1	14	14	14
62	May-24	1	12	12	12
63	May-24	1	12	12	12
64	May-24	1	24	24	24
65	May-24	1	35	35	35
66	May-24	1	35	35	35
67	May-24	1	7	7	7
68	May-24	1	12	12	12
69	May-24	1	54	54	54
70	May-24	1	23	23	23
71	May-24	1	40	40	40
72	May-24	1	8	8	8
73	May-24	1	134	134	134
74	May-24	1	35	35	35
75	May-24	1	67	67	67
76	May-24	1	23	23	23
77	May-24	1	22	22	22
78	May-24	1	11	11	11
TOTAL		78	27.44	2140	27.44

Note: CAIDI for HT consumers provided in this report has been calculated based on meter reading data.

**Annexure-VII**  
**Performance Report regarding Reliability Indices**  
**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**

**(4) Customer Average Interruption Duration Index (CAIDI) for HT Consumers**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**

**Period: June 2024**

Sr.No.	Month	Ni = Number of HT consumers who experienced a sustained interruption	Ri = Restoration time for each interruption event of HT Consumers	Sum(Ri*Ni) for all HT Consumers	CAIDI=(5)/(3)
(1)	(2)	(3)	(4)	(5)	(6)
1	Jun-24	1	17	17	17
2	Jun-24	1	8	8	8
3	Jun-24	1	29	29	29
4	Jun-24	1	6	6	6
5	Jun-24	1	124	124	124
6	Jun-24	1	11	11	11
7	Jun-24	1	204	204	204
8	Jun-24	1	7	7	7
9	Jun-24	1	9	9	9
10	Jun-24	1	9	9	9
11	Jun-24	1	42	42	42
12	Jun-24	1	8	8	8
13	Jun-24	1	8	8	8
14	Jun-24	1	57	57	57
15	Jun-24	1	35	35	35
16	Jun-24	1	45	45	45
17	Jun-24	1	32	32	32
18	Jun-24	1	112	112	112
19	Jun-24	1	104	104	104
20	Jun-24	1	9	9	9
21	Jun-24	1	13	13	13
22	Jun-24	1	7	7	7
23	Jun-24	1	38	38	38
24	Jun-24	1	20	20	20
25	Jun-24	1	11	11	11
26	Jun-24	1	6	6	6
27	Jun-24	1	6	6	6
28	Jun-24	1	10	10	10
29	Jun-24	1	47	47	47
30	Jun-24	1	14	14	14
31	Jun-24	1	8	8	8
32	Jun-24	1	12	12	12
33	Jun-24	1	24	24	24
34	Jun-24	1	34	34	34
35	Jun-24	1	33	33	33
36	Jun-24	1	19	19	19
37	Jun-24	1	31	31	31
38	Jun-24	1	28	28	28
39	Jun-24	1	136	136	136
40	Jun-24	1	6	6	6
41	Jun-24	1	6	6	6
42	Jun-24	1	8	8	8
43	Jun-24	1	6	6	6
44	Jun-24	1	9	9	9
45	Jun-24	1	26	26	26

Sr.No.	Month	Ni = Number of HT consumers who experienced a sustained interruption	Ri = Restoration time for each interruption event of HT Consumers	Sum(Ri*Ni) for all HT Consumers	CAIDI=(5)/(3)
46	Jun-24	1	18	18	18
47	Jun-24	1	61	61	61
48	Jun-24	1	6	6	6
49	Jun-24	1	10	10	10
50	Jun-24	1	34	34	34
51	Jun-24	1	11	11	11
52	Jun-24	1	14	14	14
53	Jun-24	1	7	7	7
54	Jun-24	1	6	6	6
55	Jun-24	1	7	7	7
56	Jun-24	1	18	18	18
57	Jun-24	1	26	26	26
58	Jun-24	1	7	7	7
59	Jun-24	1	58	58	58
60	Jun-24	1	10	10	10
61	Jun-24	1	39	39	39
TOTAL		61	28.95	1766	28.95

Note: CAIDI for HT consumers provided in this report has been calculated based on meter reading data.