Report as submitted by Nidar Utilities



Ref. No.: NUPLLP/ MERC/DL/2020/012 Date: 13th July, 2020

To,

The Secretary,

Maharashtra Electricity Regulatory Commission,

World Trade Centre, Centre No. 1,

13th Floor, Cuffe Parade, Mumbai – 400005.

Subject: Submission of SoP Report of NUP LLP for Quarter I of FY 2020-21

Respected Sir,

All Distribution Licensees as per the Regulations 13.1 of the MERC (Standards of Performance of Distribution Licensees, Period for Giving Supply and Determination of Compensation) Regulations, 2014, are required to submit the information covered under clauses (a) and (b) of sub-section (1) of section 59 of the Electricity Act 2003 on quarterly basis to the Commission.

In compliances of the above said Regulation, NUP LLP hereby submits the above said information related to the level of performance achieved, the number of cases in which compensation was made and aggregate amount of the compensation paid to the consumers, for Quarter I of FY 2020 – 21 in the specified formats.

Thanks and Regards,

Yours Faithfully,

Saurabh Gupta

Head (Regulatory & Power Purchase)

Pending in current complaintNos. Qtr.
э р
NIL
NIL
NIL
NIL NIL

Prasbant Maying de

NIL NIL NIL	NIL NIL NIL	NIL NIL NIL	NIL NIL NIL	NIL NIL NIL	NA NA NA	NIC NIC NIC	NIL NIL NIL	NIL NIL NIL	NIL NIL	NIL NIL NIL	
NIL	Z Z	NIL	NIL	NIL	NA	NIL	NIL	NIL	NIL	NIC	
NIC	ML	NIC	NIL	Z	AN	NIL	NIL	NIL	NE	NE	
NIL	NIC	NIC	NIL	NE	YZ Z	IIZ	NIL	NIL	NIL	NIL	
NIL	NIL	NIL	NIL	Z	V.V.	NIL	NIL	NIL	NIL	ZII	
				Class-I Cities/Urban Rural	Class-1 Citics/Urban Rural	Class-I Cities/Urban Rural	Class-I Cities/Urban Rural		Class-I Citics/Urban Rural	Class-I Cities/Urban Rural	
Change of category	Complaint of Voltage Variation-Local fault	Complaint of Voltage Variation-Net work	Complaint of Voltage Variation - Expansion/ augmentation required	Fuse off call	Break down of Over head Line	Underground Cable fault	Transformer Failure	Meter Reading	Replacement of Faulty Meter	Replacement of Burnt Meter	
4.13	5.4 (a)	5.4 (b)	5.4 (c)	1.9	6.2	6.3	6.4	7.2	7.3	7.4	1
10	=	12	13	14	15	16	17	18	16	20	

Prashant Minumber

Annexure II Report of individual Complaints where Compensation has been paid By Nidar Utilities Panvel LLP

Consumer No of Consumer	ne and address f Consumer	Nature of Complaint	Reference Standard of Performance	Amount of Compensation (Rs)	Date of payment of Compensation (DD/MM/YYYY)
(4).	(5).	(9)	(2)	(8)	(0)
	NIC	NIC	EX		(9).
				7110	NIC
-					

NOTE - The report shall be prepared as per category of item for which the compensation is paid for non-observance of Standards of Performance.



Prashaut Mujimdal

Annexure-III

Report of action on Faulty Meters (1 Phase/ 3 Phase) By Nidar Utilities Panvel LLP

			notation to			
Total Meters Faulty Meters faulty rectified / pending at end feters replaced of Quarter (Nos.) (Nos.)	(8).	NIL				
Total Meters Faulty rectified / Meters replaced (Nos.) (Nos.)	(7).	NIL				
120	(6).	NIL				
Faulty Meters at start of the added during Quarter (Nos.)	(5).	NIL				
Name of Reference to Faulty Meters Faulty Meters istribution Overall at start of the added during Licensee Standards Quarter (Nos.)	(4).	NIL				
Reference to Overall Standards	(3).	NIL				
Sr. No. Distribution Licensee	(2).	NUPLLP				
Sr. No.	(1)	_	2	3	4	5

Prastrant Mijumber

Annexure-IV Performance Report regarding Reliability Indices By Nidar Utilities Panvel LLP

(I) System Average Interruption Duration Index (SAIDI)

Sr. No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri= Restoration time for each interruption event on ith feeder	Nt=Total number of consumers of the distribution Licensees area	Sum (Ri*Ni) for all feeders excluding agri. Feeders)	SAIDI = 6/5 (in Min)
(1).	(2).	(3).	(4).	(5).	(6).	(7).
1	Apr-20	0	0	439	0	0.00
2	May-20	0	0	441	0	0.00
3	Jun-20	0	0	447	0	0.00
-	Total	0	0	447	0	0.00

(II) System Average Interruption Frequency Index (SAIFI)

Sr. No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions	Nt=Total number of consumers of the distribution Licensees area	SAIFI = (4)/(5)
(1).	(2).	(3).	(4).	(5).	(6).
1	Apr-20	0	0	439	0.00
2	May-20	0	0	441	0.00
3	Jun-20	0	0	447	0.00
	Total	0	0	447	0.00

(III) Customer Average Interruption Duration Index (CAIDI)

Sr. No.	Month	SAIDI	SAIFI	SAIDI / SAIFI
(1).	(2).	(3).	(4).	(5).
1	Apr-20	0.00	0.00	0.00
2	May-20	0.00	0.00	0.00
3	Jun-20	0.00	0.00	0.00
	Total	0.00	0.00	0.00

Prachent Mujunder