

Report as submitted by  
AEML - Distribution

**Annexure-I**  
**Standards of Performance Level by the Distribution Licensee**  
**Format for Quarterly Return to be submitted to the Commission by the Distribution Licensee**

Name of Distribution Licensee: Adani Electricity Mumbai Limited  
 Period: July 2019 to September-2019

SOP Regulation No.	Parameters	Area	Pending complaint Nos. (previous Quarter)	Complaints in current Qtr.	Total complaints	No. of complaints addressed			Pending complaints at end of Qtr.	Remark
						Within Standards of performance	More than stipulated time	Total complaints redressed		
a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i	
4.3	New connection* - inspection of premises	Class-I Cities/Urban	223	13144	13367	13253	5	13258	109	Wrong Application by Customer- 5 cases
4.4	Intimation of charges where supply from existing lines	Class-I Cities/Urban	286	10316	10602	10311	1	10312	290	Application cancelled by Customer-1
4.5 & 4.6	Intimation of charges where supply to dedicated or after extension / augmentation	Class-I Cities/Urban	69	2336	2405	2262	4	2266	139	Non-Compliance from Customer - 4 cases
4.7	New connection/ add. load where supply from existing line		1207	9473	10680	9465	40	9505	1175	Non-Compliance by applicant-5 cases Wiring Incomplete - 18 cases Third Party Objection - 7 cases Wrong Applications -1 case Meter Cabin Locked - 9 cases
4.8	New connection/ add. Load where supply after extension / augmentation		943	1752	2695	1908	0	1908	787	
4.9	New connection/ add. load where supply after commissioning of sub-station		0	0	0	0	0	0	0	
4.12	Shifting of Meter / service Line	Class-I Cities/Urban	267	428	695	349	0	349	346	
6.10	Reconnection of supply after payment of dues	Class-I Cities/Urban	0	17057	17057	17057	0	17057	0	
4.13	Change of Name		0	19961	19961	19961	0	19961	0	
4.13	Change of category		110	1274	1384	1223	0	1223	161	
5.4 (a)	Complaint of Voltage Variation - Local fault		0	1738	1738	1738	0	1738	0	
5.4 (b)	Complaint of Voltage Variation - Network		0	1031	1031	1031	0	1031	0	
5.4 (c)	Complaint of Voltage Variation - Expansion /		0	0	0	0	0	0	0	
6.1	Fuse off call	Class-I Cities/Urban	0	29334	29334	28877	457	29334	0	Refer Notes below #
6.2	Breakdown of Overhead Line	Class-I Cities/Urban	0	0	0	0	0	0	0	
6.3	Underground Cable fault	Class-I Cities/Urban	0	20782	20782	19626	1156	20782	0	Refer Notes below #
6.4	Transformer failure	Class-I Cities/Urban	0	7	7	7	0	7	0	
7.2	Meter Reading		0	7425496	7425496	7423001	2495	7425496	0	Meter room locked-1286 cases No access to meter cabin-1209 cases
7.3	Replacement of Faulty Meter**	Class-I Cities/Urban	0	1523	1523	1523	0	1523	0	
7.4	Replacement of Burnt Meter	Class-I Cities/Urban	0	2887	2887	2887	0	2887	0	
7.6 , 7.7	Billing Complaint		0	47377	47377	47377	0	47377	0	

**Notes:**

\* New Connection report is based on number of applications received of individual building wherein multiple meters are connected.

\*\* Faulty meter includes- Defect in the meters not affecting the customer's supply, however affecting recording of consumer's consumption and needs immediate replacement. This does not include black spot meters, meters used for reconnection of supply, meter replaced on consumer request, stolen or missing meters.

# Notes: Fuse of Call, Underground Cable faults

Sr.no	Reasons for delay	6.1 Fuse off call	6.3UG Cable fault	Grand Total
1	In theft prone areas miscreants are tapping wires from AEML's feeder boxes and meter cabins. The overloading due to such unauthorized load results in to interruption of supply. AEML is taking efforts to remove such unauthorized connections from time to time. During any interruption, for safety purpose, AEML needs to first	17	295	312
2	Adverse site conditions (cable deep/multiple cables at one location/road crossing/supply restoration not possible by temporary means/mass objection): AEML's network is developed over 7 decades. Due to road widening, level raising, concerting, etc. cables have gone deep under the roads. It takes time to get all necessary permission and excavation for repair of such faults. Since	13	117	130
3	Heavy Rains, Water Logging, water ingress due to side by Nalla: In such conditions it becomes difficult to access	426	532	958
4	Request from Consumer to attend the fault at later	1	127	128
5	Fault at Consumer installation, which consumer needs to	0	36	36
6	Objection from Consumer: Some time consumers in the area take the objection (specially in slums) for excavation or laying of temporary cable or wire. At times it becomes	0	35	35
7	Access issue to meter cabin /AEML network equipment: Many times it is found that the access to AEML feeder pillars / meter cabin is blocked due to car or motor cycle parking or by any other means. This requires first removal of such obstructions to get access. It take linger	0	9	9
8	Labour commotion	0	0	0
9	Multiple Faults: In some cases multiple faults get developed due to damages by external agency (e.g. road widening/concreting contractors). After repair of one	0	3	3
10	Multiple services tapped from common point/main network: It was old practice to tap services from common point. If any service cable becomes faulty, for isolation, it takes more time as all services need to be removed,	0	1	1
11	Access issue to AEML substation	0	1	1
	Grand Total	457	1156	1613

**Annexure-II**  
**Report of individual Complaints where Compensation has been paid**  
**Format for quarterly return to be submitted to the Commission by the Distribution Licensee**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: July 2019 to September-2019**

Sr. No.	Complaint No.	Date of filing complaint	Consumer No.	Name and address of Consumer	Nature of Complaint	Reference Standard of Performance	Amount of Compensation (Rs.)	Date of payment of Compensation (DD/MM/YYYY)
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1								
2								
3								
4								
5								
6								
7								

NIL

**NOTE - The report shall be prepared as per category of item for which the compensation is paid for non- observance of Standards of Performance.**

**Annexure-III**  
**Report of action on Faulty Meters (1 Phase/ 3 Phase)**  
**Format for quarterly return to be submitted to the Commission by the Distribution Licensee**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**

**Period: July 2019 to September-2019**

Sr.No.	Name of Distribution Licensee	Reference to Overall Standards	Faulty Meters at the start of the Quarter (Nos.)	Faulty Meters added during Quarter (Nos.)	Total Faulty Meters (Nos.)	Meters rectified / replaced (Nos.)	Faulty Meters pending at end of Quarter (Nos.)
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
1	AEML	7.3	0	1523	1523	1523	0
2							
3							
4							
5							

**Note:**

Faulty meter includes- Defect in the meters not affecting the customer's supply, however affecting recording of consumer's consumption and needs immediate replacement. This does not include black spot meters, meters used for reconnection of supply, meter replaced on consumer request, stolen or missing meters.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee  
**(1) System Average Interruption Duration Index (SAIDI)**

Name of Distribution Licensee: Adani Electricity Mumbai Limited  
Period: July 2019 to September 2019

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	Jul-19	1	22.2	3041472	22	0.0000
2	Jul-19	1	22.8	3041472	23	0.0000
3	Jul-19	2	17.1	3041472	34	0.0000
4	Jul-19	21	16	3041472	336	0.0001
5	Jul-19	73	23	3041472	1679	0.0006
6	Jul-19	117	16.79	3041472	1964	0.0006
7	Jul-19	134	19	3041472	2546	0.0008
8	Jul-19	364	12	3041472	4368	0.0014
9	Jul-19	551	8	3041472	4408	0.0014
10	Jul-19	716	7	3041472	5012	0.0016
11	Jul-19	138	65.72	3041472	9069	0.0030
12	Jul-19	1032	9	3041472	9288	0.0031
13	Jul-19	317	31	3041472	9827	0.0032
14	Jul-19	958	10.43	3041472	9992	0.0033
15	Jul-19	1569	6.54	3041472	10261	0.0034
16	Jul-19	777	17	3041472	13209	0.0043
17	Jul-19	542	26	3041472	14092	0.0046
18	Jul-19	911	16	3041472	14576	0.0048
19	Jul-19	736	20.02	3041472	14735	0.0048
20	Jul-19	680	22.43	3041472	15252	0.0050
21	Jul-19	1876	8.75	3041472	16415	0.0054
22	Jul-19	995	17	3041472	16915	0.0056
23	Jul-19	260	68.85	3041472	17901	0.0059
24	Jul-19	912	21.06	3041472	19207	0.0063
25	Jul-19	1013	19.43	3041472	19683	0.0065
26	Jul-19	499	41	3041472	20459	0.0067
27	Jul-19	811	26	3041472	21086	0.0069
28	Jul-19	1247	17.03	3041472	21236	0.0070
29	Jul-19	808	27	3041472	21816	0.0072
30	Jul-19	1499	15	3041472	22485	0.0074
31	Jul-19	747	30.25	3041472	22597	0.0074
32	Jul-19	1200	19.46	3041472	23352	0.0077
33	Jul-19	2936	8.22	3041472	24134	0.0079
34	Jul-19	3096	8.44	3041472	26130	0.0086
35	Jul-19	1017	27	3041472	27459	0.0090
36	Jul-19	944	30.99	3041472	29255	0.0096
37	Jul-19	65	461	3041472	29965	0.0099
38	Jul-19	996	34	3041472	33864	0.0111
39	Jul-19	994	37	3041472	36778	0.0121
40	Jul-19	981	39.93	3041472	39171	0.0129
41	Jul-19	970	41.02	3041472	39789	0.0131

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
42	Jul-19	5332	8.31	3041472	44309	0.0146
43	Jul-19	2503	18.64	3041472	46656	0.0153
44	Jul-19	1696	28	3041472	47488	0.0156
45	Jul-19	3556	13.87	3041472	49322	0.0162
46	Jul-19	2149	23.4	3041472	50287	0.0165
47	Jul-19	1638	31.17	3041472	51056	0.0168
48	Jul-19	1949	28.21	3041472	54981	0.0181
49	Jul-19	3709	17.3	3041472	64166	0.0211
50	Jul-19	2177	29.62	3041472	64483	0.0212
51	Jul-19	1849	38.89	3041472	71908	0.0236
52	Jul-19	2775	27.57	3041472	76507	0.0252
53	Jul-19	3497	23.12	3041472	80851	0.0266
54	Jul-19	2917	29.65	3041472	86489	0.0284
55	Jul-19	5984	15	3041472	89760	0.0295
56	Jul-19	285	328	3041472	93480	0.0307
57	Jul-19	2234	46	3041472	102764	0.0338
58	Jul-19	4840	22.93	3041472	110981	0.0365
59	Jul-19	5175	24.92	3041472	128961	0.0424
60	Jul-19	7146	18.37	3041472	131272	0.0432
61	Jul-19	2552	55	3041472	140360	0.0461
62	Jul-19	4639	33.12	3041472	153644	0.0505
63	Jul-19	4277	36.69	3041472	156923	0.0516
64	Jul-19	4639	34.39	3041472	159535	0.0525
65	Jul-19	6756	23.89	3041472	161401	0.0531
66	Jul-19	4653	34.73	3041472	161599	0.0531
67	Jul-19	1720	95.86	3041472	164879	0.0542
68	Jul-19	4349	42.71	3041472	185746	0.0611
69	Jul-19	9009	25.08	3041472	225946	0.0743
70	Jul-19	4328	119.59	3041472	517586	0.1702
71	Jul-19	680	22	3041472	14960	0.0049
72	Jul-19	914	27	3041472	24678	0.0081
73	Jul-19	8214	8.57	3041472	70394	0.0231
74	Jul-19	2216	35.68	3041472	79067	0.0260
75	Jul-19	15	22	3041472	330	0.0001
76	Jul-19	15	78	3041472	1170	0.0004
77	Jul-19	142	10.17	3041472	1444	0.0005
78	Jul-19	209	15	3041472	3135	0.0010
79	Jul-19	1638	20.27	3041472	33202	0.0109
80	Jul-19	2749	24.04	3041472	66086	0.0217
81	Jul-19	1656	40.45	3041472	66985	0.0220
82	Jul-19	2688	119.48	3041472	321162	0.1056
83	Jul-19	15	21	3041472	315	0.0001
84	Jul-19	41	15	3041472	615	0.0002
85	Jul-19	981	8	3041472	7848	0.0026
86	Jul-19	388	47.15	3041472	18294	0.0060
87	Jul-19	4439	6	3041472	26634	0.0088
88	Jul-19	3224	14	3041472	45136	0.0148
89	Jul-19	1360	56	3041472	76160	0.0250
90	Jul-19	3649	22	3041472	80278	0.0264
91	Jul-19	8128	16.96	3041472	137851	0.0453
Total		185200	28.18	3041472	5219473	1.7161

Remark :

- 1 Customer served by AEML are 3041472 nos.
- 2 Number of feeders are 1179 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(1) System Average Interruption Duration Index (SAIDI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: July 2019 to September 2019**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	Aug-19	1	52.8	3045167	53	0.0000
2	Aug-19	2	41.1	3045167	82	0.0000
3	Aug-19	4	20.55	3045167	82	0.0000
4	Aug-19	32	21	3045167	672	0.0002
5	Aug-19	250	9.7	3045167	2425	0.0008
6	Aug-19	147	17	3045167	2499	0.0008
7	Aug-19	170	19.07	3045167	3242	0.0011
8	Aug-19	134	27	3045167	3618	0.0012
9	Aug-19	138	34	3045167	4692	0.0015
10	Aug-19	189	36.23	3045167	6847	0.0022
11	Aug-19	790	15	3045167	11850	0.0039
12	Aug-19	442	29.49	3045167	13035	0.0043
13	Aug-19	1122	15	3045167	16830	0.0055
14	Aug-19	1192	14.14	3045167	16855	0.0055
15	Aug-19	996	17.03	3045167	16962	0.0056
16	Aug-19	705	32.97	3045167	23244	0.0076
17	Aug-19	718	38	3045167	27284	0.0090
18	Aug-19	627	44	3045167	27588	0.0091
19	Aug-19	1123	25.75	3045167	28917	0.0095
20	Aug-19	3698	8.06	3045167	29806	0.0098
21	Aug-19	1212	30.1	3045167	36481	0.0120
22	Aug-19	2816	14	3045167	39424	0.0129
23	Aug-19	2118	19	3045167	40242	0.0132
24	Aug-19	2036	21.7	3045167	44181	0.0145
25	Aug-19	5421	11.05	3045167	59902	0.0197
26	Aug-19	2189	27.46	3045167	60110	0.0197
27	Aug-19	6453	9.62	3045167	62078	0.0204
28	Aug-19	4199	15.47	3045167	64959	0.0213
29	Aug-19	2951	22.09	3045167	65188	0.0214
30	Aug-19	2123	31.67	3045167	67235	0.0221
31	Aug-19	2002	36.89	3045167	73854	0.0243
32	Aug-19	2218	34	3045167	75412	0.0248
33	Aug-19	2426	35.67	3045167	86535	0.0284
34	Aug-19	3098	27.96	3045167	86620	0.0284
35	Aug-19	4091	23.8	3045167	97366	0.0320
36	Aug-19	2682	39	3045167	104598	0.0343
37	Aug-19	4644	24	3045167	111456	0.0366
38	Aug-19	4550	26.61	3045167	121076	0.0398
39	Aug-19	3297	38.58	3045167	127198	0.0418
40	Aug-19	7296	18.87	3045167	137676	0.0452
41	Aug-19	4544	31.04	3045167	141046	0.0463



Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
42	Aug-19	4091	36.46	3045167	149158	0.0490
43	Aug-19	2585	58.41	3045167	150990	0.0496
44	Aug-19	5655	31.66	3045167	179037	0.0588
45	Aug-19	4089	56.98	3045167	232991	0.0765
46	Aug-19	3002	86.98	3045167	261114	0.0857
47	Aug-19	4739	55.42	3045167	262635	0.0862
48	Aug-19	6549	60.53	3045167	396411	0.1302
49	Aug-19	9677	42.51	3045167	411369	0.1351
50	Aug-19	302	9	3045167	2718	0.0009
51	Aug-19	489	66.15	3045167	32347	0.0106
52	Aug-19	1052	36.43	3045167	38324	0.0126
53	Aug-19	1426	56.53	3045167	80612	0.0265
54	Aug-19	10918	9.78	3045167	106778	0.0351
55	Aug-19	8354	16.18	3045167	135168	0.0444
56	Aug-19	1537	88.8	3045167	136486	0.0448
57	Aug-19	4544	396.42	3045167	1801332	0.5915
58	Aug-19	905	18.53	3045167	16770	0.0055
59	Aug-19	3	45.4	3045167	136	0.0000
60	Aug-19	730	6	3045167	4380	0.0014
61	Aug-19	1933	6.44	3045167	12449	0.0041
62	Aug-19	593	24	3045167	14232	0.0047
63	Aug-19	893	17	3045167	15181	0.0050
64	Aug-19	3439	6	3045167	20634	0.0068
65	Aug-19	1862	12.39	3045167	23070	0.0076
66	Aug-19	604	51	3045167	30804	0.0101
67	Aug-19	1099	60	3045167	65940	0.0217
68	Aug-19	2806	26.26	3045167	73686	0.0242
69	Aug-19	3650	31	3045167	113150	0.0372
Total		172372	38.91	3045167	6707121	2.2025

Remark :

- 1 Customer served by AEML are 3045167 nos.
- 2 Number of feeders are 1180 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(1) System Average Interruption Duration Index (SAIDI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: July 2019 to September 2019**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	Sep-19	8	15.98	3043975	128	0.0000
2	Sep-19	3	116	3043975	348	0.0001
3	Sep-19	64	42.08	3043975	2693	0.0009
4	Sep-19	118	28	3043975	3304	0.0011
5	Sep-19	588	15.24	3043975	8961	0.0029
6	Sep-19	327	30.14	3043975	9856	0.0032
7	Sep-19	495	20.97	3043975	10380	0.0034
8	Sep-19	496	27	3043975	13392	0.0044
9	Sep-19	574	24.48	3043975	14052	0.0046
10	Sep-19	2057	8.22	3043975	16909	0.0056
11	Sep-19	569	31	3043975	17639	0.0058
12	Sep-19	405	46.53	3043975	18845	0.0062
13	Sep-19	430	45.16	3043975	19419	0.0064
14	Sep-19	1727	12.56	3043975	21691	0.0071
15	Sep-19	561	39.98	3043975	22429	0.0074
16	Sep-19	4203	6.66	3043975	27992	0.0092
17	Sep-19	2420	12.18	3043975	29476	0.0097
18	Sep-19	1130	26.33	3043975	29753	0.0098
19	Sep-19	588	55.73	3043975	32769	0.0108
20	Sep-19	658	51.17	3043975	33670	0.0111
21	Sep-19	1039	41.6	3043975	43222	0.0142
22	Sep-19	1545	28.62	3043975	44218	0.0145
23	Sep-19	4084	11	3043975	44924	0.0148
24	Sep-19	2011	28.2	3043975	56710	0.0186
25	Sep-19	2952	20.06	3043975	59217	0.0195
26	Sep-19	1545	39	3043975	60255	0.0198
27	Sep-19	8847	8	3043975	70776	0.0233
28	Sep-19	5324	13.78	3043975	73365	0.0241
29	Sep-19	1212	62.85	3043975	76174	0.0250
30	Sep-19	673	114.96	3043975	77368	0.0254
31	Sep-19	3650	22	3043975	80300	0.0264
32	Sep-19	1659	49.2	3043975	81623	0.0268
33	Sep-19	3505	24.13	3043975	84576	0.0278
34	Sep-19	2121	41	3043975	86961	0.0286
35	Sep-19	5285	16.91	3043975	89369	0.0294
36	Sep-19	2216	40.99	3043975	90834	0.0298
37	Sep-19	7146	20	3043975	142920	0.0470
38	Sep-19	4335	37.74	3043975	163603	0.0537
39	Sep-19	5417	30.61	3043975	165814	0.0545
40	Sep-19	3623	48.77	3043975	176694	0.0580
41	Sep-19	8644	10.04	3043975	86786	0.0285

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
42	Sep-19	2	138	3043975	276	0.0001
43	Sep-19	922	30.92	3043975	28508	0.0094
44	Sep-19	3133	18.09	3043975	56676	0.0186
45	Sep-19	1888	38.58	3043975	72839	0.0239
46	Sep-19	7995	6.43	3043975	51408	0.0169
47	Sep-19	1656	35.13	3043975	58175	0.0191
48	Sep-19	285	268	3043975	76380	0.0251
49	Sep-19	6171	19.83	3043975	122371	0.0402
50	Sep-19	4813	39.22	3043975	188766	0.0620
51	Sep-19	2568	8	3043975	20544	0.0067
52	Sep-19	3419	23.07	3043975	78876	0.0259
53	Sep-19	5198	18.22	3043975	94708	0.0311
Total		132304	22.97	3043975	3038940	0.9983

Remark :

- 1 Customer served by AEML are 3043975 nos.
- 2 Number of feeders are 1185 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(2) System Average Interruption Frequency Index (SAIFI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: July 2019 to September 2019**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
1	Jul-19	1	1	3041472	0.0000
2	Jul-19	1	1	3041472	0.0000
3	Jul-19	2	2	3041472	0.0000
4	Jul-19	21	21	3041472	0.0000
5	Jul-19	73	73	3041472	0.0000
6	Jul-19	117	117	3041472	0.0000
7	Jul-19	134	134	3041472	0.0000
8	Jul-19	364	364	3041472	0.0001
9	Jul-19	551	551	3041472	0.0002
10	Jul-19	716	716	3041472	0.0002
11	Jul-19	138	138	3041472	0.0000
12	Jul-19	1032	1032	3041472	0.0003
13	Jul-19	317	317	3041472	0.0001
14	Jul-19	958	958	3041472	0.0003
15	Jul-19	1569	1569	3041472	0.0005
16	Jul-19	777	777	3041472	0.0003
17	Jul-19	542	542	3041472	0.0002
18	Jul-19	911	911	3041472	0.0003
19	Jul-19	736	736	3041472	0.0002
20	Jul-19	680	680	3041472	0.0002
21	Jul-19	1876	1876	3041472	0.0006
22	Jul-19	995	995	3041472	0.0003
23	Jul-19	260	260	3041472	0.0001
24	Jul-19	912	912	3041472	0.0003
25	Jul-19	1013	1013	3041472	0.0003
26	Jul-19	499	499	3041472	0.0002
27	Jul-19	811	811	3041472	0.0003
28	Jul-19	1247	1247	3041472	0.0004
29	Jul-19	808	808	3041472	0.0003
30	Jul-19	1499	1499	3041472	0.0005
31	Jul-19	747	747	3041472	0.0002
32	Jul-19	1200	1200	3041472	0.0004
33	Jul-19	2936	2936	3041472	0.0010
34	Jul-19	3096	3096	3041472	0.0010
35	Jul-19	1017	1017	3041472	0.0003
36	Jul-19	944	944	3041472	0.0003
37	Jul-19	65	65	3041472	0.0000
38	Jul-19	996	996	3041472	0.0003
39	Jul-19	994	994	3041472	0.0003
40	Jul-19	981	981	3041472	0.0003
41	Jul-19	970	970	3041472	0.0003

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
42	Jul-19	5332	5332	3041472	0.0018
43	Jul-19	2503	2503	3041472	0.0008
44	Jul-19	1696	1696	3041472	0.0006
45	Jul-19	3556	3556	3041472	0.0012
46	Jul-19	2149	2149	3041472	0.0007
47	Jul-19	1638	1638	3041472	0.0005
48	Jul-19	1949	1949	3041472	0.0006
49	Jul-19	3709	3709	3041472	0.0012
50	Jul-19	2177	2177	3041472	0.0007
51	Jul-19	1849	1849	3041472	0.0006
52	Jul-19	2775	2775	3041472	0.0009
53	Jul-19	3497	3497	3041472	0.0011
54	Jul-19	2917	2917	3041472	0.0010
55	Jul-19	5984	5984	3041472	0.0020
56	Jul-19	285	285	3041472	0.0001
57	Jul-19	2234	2234	3041472	0.0007
58	Jul-19	4840	4840	3041472	0.0016
59	Jul-19	5175	5175	3041472	0.0017
60	Jul-19	7146	7146	3041472	0.0023
61	Jul-19	2552	2552	3041472	0.0008
62	Jul-19	4639	4639	3041472	0.0015
63	Jul-19	4277	4277	3041472	0.0014
64	Jul-19	4639	4639	3041472	0.0015
65	Jul-19	6756	6756	3041472	0.0022
66	Jul-19	4653	4653	3041472	0.0015
67	Jul-19	1720	1720	3041472	0.0006
68	Jul-19	4349	4349	3041472	0.0014
69	Jul-19	9009	9009	3041472	0.0030
70	Jul-19	4328	4328	3041472	0.0014
71	Jul-19	680	680	3041472	0.0002
72	Jul-19	914	914	3041472	0.0003
73	Jul-19	8214	8214	3041472	0.0027
74	Jul-19	2216	2216	3041472	0.0007
75	Jul-19	15	15	3041472	0.0000
76	Jul-19	15	15	3041472	0.0000
77	Jul-19	142	142	3041472	0.0000
78	Jul-19	209	209	3041472	0.0001
79	Jul-19	1638	1638	3041472	0.0005
80	Jul-19	2749	2749	3041472	0.0009
81	Jul-19	1656	1656	3041472	0.0005
82	Jul-19	2688	2688	3041472	0.0009
83	Jul-19	15	15	3041472	0.0000
84	Jul-19	41	41	3041472	0.0000
85	Jul-19	981	981	3041472	0.0003
86	Jul-19	388	388	3041472	0.0001
87	Jul-19	4439	4439	3041472	0.0015
88	Jul-19	3224	3224	3041472	0.0011
89	Jul-19	1360	1360	3041472	0.0004
90	Jul-19	3649	3649	3041472	0.0012
91	Jul-19	8128	8128	3041472	0.0027
Total		185200	185200	3041472	0.0609

Remark :

- 1 Customer served by AEML are 3041472 nos.
- 2 Number of feeders are 1179 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(2) System Average Interruption Frequency Index (SAIFI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: July 2019 to September 2019**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
1	Aug-19	1	1	3045167	0.0000
2	Aug-19	2	2	3045167	0.0000
3	Aug-19	4	4	3045167	0.0000
4	Aug-19	32	32	3045167	0.0000
5	Aug-19	250	250	3045167	0.0001
6	Aug-19	147	147	3045167	0.0000
7	Aug-19	170	170	3045167	0.0001
8	Aug-19	134	134	3045167	0.0000
9	Aug-19	138	138	3045167	0.0000
10	Aug-19	189	189	3045167	0.0001
11	Aug-19	790	790	3045167	0.0003
12	Aug-19	442	442	3045167	0.0001
13	Aug-19	1122	1122	3045167	0.0004
14	Aug-19	1192	1192	3045167	0.0004
15	Aug-19	996	996	3045167	0.0003
16	Aug-19	705	705	3045167	0.0002
17	Aug-19	718	718	3045167	0.0002
18	Aug-19	627	627	3045167	0.0002
19	Aug-19	1123	1123	3045167	0.0004
20	Aug-19	3698	3698	3045167	0.0012
21	Aug-19	1212	1212	3045167	0.0004
22	Aug-19	2816	2816	3045167	0.0009
23	Aug-19	2118	2118	3045167	0.0007
24	Aug-19	2036	2036	3045167	0.0007
25	Aug-19	5421	5421	3045167	0.0018
26	Aug-19	2189	2189	3045167	0.0007
27	Aug-19	6453	6453	3045167	0.0021
28	Aug-19	4199	4199	3045167	0.0014
29	Aug-19	2951	2951	3045167	0.0010
30	Aug-19	2123	2123	3045167	0.0007
31	Aug-19	2002	2002	3045167	0.0007
32	Aug-19	2218	2218	3045167	0.0007
33	Aug-19	2426	2426	3045167	0.0008
34	Aug-19	3098	3098	3045167	0.0010
35	Aug-19	4091	4091	3045167	0.0013
36	Aug-19	2682	2682	3045167	0.0009
37	Aug-19	4644	4644	3045167	0.0015
38	Aug-19	4550	4550	3045167	0.0015
39	Aug-19	3297	3297	3045167	0.0011
40	Aug-19	7296	7296	3045167	0.0024
41	Aug-19	4544	4544	3045167	0.0015

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
42	Aug-19	4091	4091	3045167	0.0013
43	Aug-19	2585	2585	3045167	0.0008
44	Aug-19	5655	5655	3045167	0.0019
45	Aug-19	4089	4089	3045167	0.0013
46	Aug-19	3002	3002	3045167	0.0010
47	Aug-19	4739	4739	3045167	0.0016
48	Aug-19	6549	6549	3045167	0.0022
49	Aug-19	9677	9677	3045167	0.0032
50	Aug-19	302	302	3045167	0.0001
51	Aug-19	489	489	3045167	0.0002
52	Aug-19	1052	1052	3045167	0.0003
53	Aug-19	1426	1426	3045167	0.0005
54	Aug-19	10918	10918	3045167	0.0036
55	Aug-19	8354	8354	3045167	0.0027
56	Aug-19	1537	1537	3045167	0.0005
57	Aug-19	4544	4544	3045167	0.0015
58	Aug-19	905	905	3045167	0.0003
59	Aug-19	3	3	3045167	0.0000
60	Aug-19	730	730	3045167	0.0002
61	Aug-19	1933	1933	3045167	0.0006
62	Aug-19	593	593	3045167	0.0002
63	Aug-19	893	893	3045167	0.0003
64	Aug-19	3439	3439	3045167	0.0011
65	Aug-19	1862	1862	3045167	0.0006
66	Aug-19	604	604	3045167	0.0002
67	Aug-19	1099	1099	3045167	0.0004
68	Aug-19	2806	2806	3045167	0.0009
69	Aug-19	3650	3650	3045167	0.0012
Total		172372	172372	3045167	0.0566

Remark :

- 1 Customer served by AEML are 3045167 nos.
- 2 Number of feeders are 1180 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(2) System Average Interruption Frequency Index (SAIFI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: July 2019 to September 2019**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
1	Sep-19	8	8	3043975	0.0000
2	Sep-19	3	3	3043975	0.0000
3	Sep-19	64	64	3043975	0.0000
4	Sep-19	118	118	3043975	0.0000
5	Sep-19	588	588	3043975	0.0002
6	Sep-19	327	327	3043975	0.0001
7	Sep-19	495	495	3043975	0.0002
8	Sep-19	496	496	3043975	0.0002
9	Sep-19	574	574	3043975	0.0002
10	Sep-19	2057	2057	3043975	0.0007
11	Sep-19	569	569	3043975	0.0002
12	Sep-19	405	405	3043975	0.0001
13	Sep-19	430	430	3043975	0.0001
14	Sep-19	1727	1727	3043975	0.0006
15	Sep-19	561	561	3043975	0.0002
16	Sep-19	4203	4203	3043975	0.0014
17	Sep-19	2420	2420	3043975	0.0008
18	Sep-19	1130	1130	3043975	0.0004
19	Sep-19	588	588	3043975	0.0002
20	Sep-19	658	658	3043975	0.0002
21	Sep-19	1039	1039	3043975	0.0003
22	Sep-19	1545	1545	3043975	0.0005
23	Sep-19	4084	4084	3043975	0.0013
24	Sep-19	2011	2011	3043975	0.0007
25	Sep-19	2952	2952	3043975	0.0010
26	Sep-19	1545	1545	3043975	0.0005
27	Sep-19	8847	8847	3043975	0.0029
28	Sep-19	5324	5324	3043975	0.0017
29	Sep-19	1212	1212	3043975	0.0004
30	Sep-19	673	673	3043975	0.0002
31	Sep-19	3650	3650	3043975	0.0012
32	Sep-19	1659	1659	3043975	0.0005
33	Sep-19	3505	3505	3043975	0.0012
34	Sep-19	2121	2121	3043975	0.0007
35	Sep-19	5285	5285	3043975	0.0017
36	Sep-19	2216	2216	3043975	0.0007
37	Sep-19	7146	7146	3043975	0.0023
38	Sep-19	4335	4335	3043975	0.0014
39	Sep-19	5417	5417	3043975	0.0018
40	Sep-19	3623	3623	3043975	0.0012
41	Sep-19	8644	8644	3043975	0.0028



Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
42	Sep-19	2	2	3043975	0.0000
43	Sep-19	922	922	3043975	0.0003
44	Sep-19	3133	3133	3043975	0.0010
45	Sep-19	1888	1888	3043975	0.0006
46	Sep-19	7995	7995	3043975	0.0026
47	Sep-19	1656	1656	3043975	0.0005
48	Sep-19	285	285	3043975	0.0001
49	Sep-19	6171	6171	3043975	0.0020
50	Sep-19	4813	4813	3043975	0.0016
51	Sep-19	2568	2568	3043975	0.0008
52	Sep-19	3419	3419	3043975	0.0011
53	Sep-19	5198	5198	3043975	0.0017
Total		132304	132304	3043975	0.0435

Remark :

- 1 Customer served by AEML are 3043975 nos.
- 2 Number of feeders are 1185 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(3) Customer Average Interruption Duration Index (CAIDI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: July 2019 to September 2019**

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
1	Jul-19	0.0000	0.0000	22.2
2	Jul-19	0.0000	0.0000	22.8
3	Jul-19	0.0000	0.0000	17.1
4	Jul-19	0.0001	0.0000	16
5	Jul-19	0.0006	0.0000	23
6	Jul-19	0.0006	0.0000	16.79
7	Jul-19	0.0008	0.0000	19
8	Jul-19	0.0014	0.0001	12
9	Jul-19	0.0014	0.0002	8
10	Jul-19	0.0016	0.0002	7
11	Jul-19	0.0030	0.0000	65.72
12	Jul-19	0.0031	0.0003	9
13	Jul-19	0.0032	0.0001	31
14	Jul-19	0.0033	0.0003	10.43
15	Jul-19	0.0034	0.0005	6.54
16	Jul-19	0.0043	0.0003	17
17	Jul-19	0.0046	0.0002	26
18	Jul-19	0.0048	0.0003	16
19	Jul-19	0.0048	0.0002	20.02
20	Jul-19	0.0050	0.0002	22.43
21	Jul-19	0.0054	0.0006	8.75
22	Jul-19	0.0056	0.0003	17
23	Jul-19	0.0059	0.0001	68.85
24	Jul-19	0.0063	0.0003	21.06
25	Jul-19	0.0065	0.0003	19.43
26	Jul-19	0.0067	0.0002	41
27	Jul-19	0.0069	0.0003	26
28	Jul-19	0.0070	0.0004	17.03
29	Jul-19	0.0072	0.0003	27
30	Jul-19	0.0074	0.0005	15
31	Jul-19	0.0074	0.0002	30.25
32	Jul-19	0.0077	0.0004	19.46
33	Jul-19	0.0079	0.0010	8.22
34	Jul-19	0.0086	0.0010	8.44
35	Jul-19	0.0090	0.0003	27
36	Jul-19	0.0096	0.0003	30.99
37	Jul-19	0.0099	0.0000	461
38	Jul-19	0.0111	0.0003	34
39	Jul-19	0.0121	0.0003	37
40	Jul-19	0.0129	0.0003	39.93
41	Jul-19	0.0131	0.0003	41.02
42	Jul-19	0.0146	0.0018	8.31
43	Jul-19	0.0153	0.0008	18.64
44	Jul-19	0.0156	0.0006	28
45	Jul-19	0.0162	0.0012	13.87
46	Jul-19	0.0165	0.0007	23.4
47	Jul-19	0.0168	0.0005	31.17

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
48	Jul-19	0.0181	0.0006	28.21
49	Jul-19	0.0211	0.0012	17.3
50	Jul-19	0.0212	0.0007	29.62
51	Jul-19	0.0236	0.0006	38.89
52	Jul-19	0.0252	0.0009	27.57
53	Jul-19	0.0266	0.0011	23.12
54	Jul-19	0.0284	0.0010	29.65
55	Jul-19	0.0295	0.0020	15
56	Jul-19	0.0307	0.0001	328
57	Jul-19	0.0338	0.0007	46
58	Jul-19	0.0365	0.0016	22.93
59	Jul-19	0.0424	0.0017	24.92
60	Jul-19	0.0432	0.0023	18.37
61	Jul-19	0.0461	0.0008	55
62	Jul-19	0.0505	0.0015	33.12
63	Jul-19	0.0516	0.0014	36.69
64	Jul-19	0.0525	0.0015	34.39
65	Jul-19	0.0531	0.0022	23.89
66	Jul-19	0.0531	0.0015	34.73
67	Jul-19	0.0542	0.0006	95.86
68	Jul-19	0.0611	0.0014	42.71
69	Jul-19	0.0743	0.0030	25.08
70	Jul-19	0.1702	0.0014	119.59
71	Jul-19	0.0049	0.0002	22
72	Jul-19	0.0081	0.0003	27
73	Jul-19	0.0231	0.0027	8.57
74	Jul-19	0.0260	0.0007	35.68
75	Jul-19	0.0001	0.0000	22
76	Jul-19	0.0004	0.0000	78
77	Jul-19	0.0005	0.0000	10.17
78	Jul-19	0.0010	0.0001	15
79	Jul-19	0.0109	0.0005	20.27
80	Jul-19	0.0217	0.0009	24.04
81	Jul-19	0.0220	0.0005	40.45
82	Jul-19	0.1056	0.0009	119.48
83	Jul-19	0.0001	0.0000	21
84	Jul-19	0.0002	0.0000	15
85	Jul-19	0.0026	0.0003	8
86	Jul-19	0.0060	0.0001	47.15
87	Jul-19	0.0088	0.0015	6
88	Jul-19	0.0148	0.0011	14
89	Jul-19	0.0250	0.0004	56
90	Jul-19	0.0264	0.0012	22
91	Jul-19	0.0453	0.0027	16.96
Total		1.7161	0.0609	28.1829

Remark :

- 1 Customer served by AEML are 3045167 nos.
- 2 Number of feeders are 1180 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(3) Customer Average Interruption Duration Index (CAIDI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: July 2019 to September 2019**

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
1	Aug-19	0.0000	0.0000	52.8
2	Aug-19	0.0000	0.0000	41.1
3	Aug-19	0.0000	0.0000	20.55
4	Aug-19	0.0002	0.0000	21
5	Aug-19	0.0008	0.0001	9.7
6	Aug-19	0.0008	0.0000	17
7	Aug-19	0.0011	0.0001	19.07
8	Aug-19	0.0012	0.0000	27
9	Aug-19	0.0015	0.0000	34
10	Aug-19	0.0022	0.0001	36.23
11	Aug-19	0.0039	0.0003	15
12	Aug-19	0.0043	0.0001	29.49
13	Aug-19	0.0055	0.0004	15
14	Aug-19	0.0055	0.0004	14.14
15	Aug-19	0.0056	0.0003	17.03
16	Aug-19	0.0076	0.0002	32.97
17	Aug-19	0.0090	0.0002	38
18	Aug-19	0.0091	0.0002	44
19	Aug-19	0.0095	0.0004	25.75
20	Aug-19	0.0098	0.0012	8.06
21	Aug-19	0.0120	0.0004	30.1
22	Aug-19	0.0129	0.0009	14
23	Aug-19	0.0132	0.0007	19
24	Aug-19	0.0145	0.0007	21.7
25	Aug-19	0.0197	0.0018	11.05
26	Aug-19	0.0197	0.0007	27.46
27	Aug-19	0.0204	0.0021	9.62
28	Aug-19	0.0213	0.0014	15.47
29	Aug-19	0.0214	0.0010	22.09
30	Aug-19	0.0221	0.0007	31.67
31	Aug-19	0.0243	0.0007	36.89
32	Aug-19	0.0248	0.0007	34
33	Aug-19	0.0284	0.0008	35.67
34	Aug-19	0.0284	0.0010	27.96
35	Aug-19	0.0320	0.0013	23.8
36	Aug-19	0.0343	0.0009	39
37	Aug-19	0.0366	0.0015	24
38	Aug-19	0.0398	0.0015	26.61
39	Aug-19	0.0418	0.0011	38.58
40	Aug-19	0.0452	0.0024	18.87
41	Aug-19	0.0463	0.0015	31.04
42	Aug-19	0.0490	0.0013	36.46
43	Aug-19	0.0496	0.0008	58.41
44	Aug-19	0.0588	0.0019	31.66
45	Aug-19	0.0765	0.0013	56.98
46	Aug-19	0.0857	0.0010	86.98
47	Aug-19	0.0862	0.0016	55.42

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
48	Aug-19	0.1302	0.0022	60.53
49	Aug-19	0.1351	0.0032	42.51
50	Aug-19	0.0009	0.0001	9
51	Aug-19	0.0106	0.0002	66.15
52	Aug-19	0.0126	0.0003	36.43
53	Aug-19	0.0265	0.0005	56.53
54	Aug-19	0.0351	0.0036	9.78
55	Aug-19	0.0444	0.0027	16.18
56	Aug-19	0.0448	0.0005	88.8
57	Aug-19	0.5915	0.0015	396.42
58	Aug-19	0.0055	0.0003	18.53
59	Aug-19	0.0000	0.0000	45.4
60	Aug-19	0.0014	0.0002	6
61	Aug-19	0.0041	0.0006	6.44
62	Aug-19	0.0047	0.0002	24
63	Aug-19	0.0050	0.0003	17
64	Aug-19	0.0068	0.0011	6
65	Aug-19	0.0076	0.0006	12.39
66	Aug-19	0.0101	0.0002	51
67	Aug-19	0.0217	0.0004	60
68	Aug-19	0.0242	0.0009	26.26
69	Aug-19	0.0372	0.0012	31
Total		2.2025	0.0566	38.9107

Remark :

- 1 Customer served by AEML are 3045167 nos.
- 2 Number of feeders are 1180 Nos.

**Annexure-IV  
Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee  
(3) Customer Average Interruption Duration Index (CAIDI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited  
Period: July 2019 to September 2019**

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
1	Sep-19	0.0000	0.0000	15.980
2	Sep-19	0.0001	0.0000	116.000
3	Sep-19	0.0009	0.0000	42.080
4	Sep-19	0.0011	0.0000	28.000
5	Sep-19	0.0029	0.0002	15.240
6	Sep-19	0.0032	0.0001	30.140
7	Sep-19	0.0034	0.0002	20.970
8	Sep-19	0.0044	0.0002	27.000
9	Sep-19	0.0046	0.0002	24.480
10	Sep-19	0.0056	0.0007	8.220
11	Sep-19	0.0058	0.0002	31.000
12	Sep-19	0.0062	0.0001	46.530
13	Sep-19	0.0064	0.0001	45.160
14	Sep-19	0.0071	0.0006	12.560
15	Sep-19	0.0074	0.0002	39.980
16	Sep-19	0.0092	0.0014	6.660
17	Sep-19	0.0097	0.0008	12.180
18	Sep-19	0.0098	0.0004	26.330
19	Sep-19	0.0108	0.0002	55.730
20	Sep-19	0.0111	0.0002	51.170
21	Sep-19	0.0142	0.0003	41.600
22	Sep-19	0.0145	0.0005	28.620
23	Sep-19	0.0148	0.0013	11.000
24	Sep-19	0.0186	0.0007	28.200
25	Sep-19	0.0195	0.0010	20.060
26	Sep-19	0.0198	0.0005	39.000
27	Sep-19	0.0233	0.0029	8.000
28	Sep-19	0.0241	0.0017	13.780
29	Sep-19	0.0250	0.0004	62.850
30	Sep-19	0.0254	0.0002	114.960
31	Sep-19	0.0264	0.0012	22.000
32	Sep-19	0.0268	0.0005	49.200
33	Sep-19	0.0278	0.0012	24.130
34	Sep-19	0.0286	0.0007	41.000
35	Sep-19	0.0294	0.0017	16.910
36	Sep-19	0.0298	0.0007	40.990
37	Sep-19	0.0470	0.0023	20.000
38	Sep-19	0.0537	0.0014	37.740
39	Sep-19	0.0545	0.0018	30.610
40	Sep-19	0.0580	0.0012	48.770
41	Sep-19	0.0285	0.0028	10.040
42	Sep-19	0.0001	0.0000	138.000
43	Sep-19	0.0094	0.0003	30.920
44	Sep-19	0.0186	0.0010	18.090
45	Sep-19	0.0239	0.0006	38.580
46	Sep-19	0.0169	0.0026	6.430
47	Sep-19	0.0191	0.0005	35.130

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
48	Sep-19	0.0251	0.0001	268.000
49	Sep-19	0.0402	0.0020	19.830
50	Sep-19	0.0620	0.0016	39.220
51	Sep-19	0.0067	0.0008	8.000
52	Sep-19	0.0259	0.0011	23.070
53	Sep-19	0.0311	0.0017	18.220
Total		0.9983	0.0435	22.9694

Remark :

- 1 Customer served by AEML are 3043975 nos.
- 2 Number of feeders are 1185 Nos.