MAHARASHTRA ELECTRICITY REGULATORY COMMISSION World Trade Centre, Centre No.1, 13th Floor, Cuffe Parade, Mumbai 400005. Tel. 022 22163964/65/69 Fax 22163976 Email: <u>mercindia@merc.gov.in</u> Website: <u>www.mercindia.org.in</u> / <u>www.merc.gov.in</u>

Case No. 136 of 2014

Date: 30 March, 2015

Public Notice

Application of M/s Adani Transmission (India) Limited for Amendment of Transmission Licence under Section 18 of the Electricity Act, 2003.

- M/s. Adani Transmission (India) Limited (ATIL) (formerly in the name of Adani Power Maharashtra Limited) has applied to the Maharashtra Electricity Regulatory Commission (MERC) for the amendment of Transmission Licence for Adani Transmission (India) Limited (Licence No. 2 of 2009) granted u/s 14 of the Electricity Act, 2003 and MERC (Transmission Licence Conditions) Regulations, 2004, as amended in 2006.
- The Applicant had published a Notice of its Application in (i) Indian Express, Nagpur Edition (English); (ii) Lokmat Times, Nagpur Edition (English); (iii) Loksatta, Nagpur Edition (Marathi); (iv) Dainik Deshonnati, Gondia Edition (Marathi) on 16 January, 2015, as required under Section 18(2) (a) of the Act.
- 3. Pursuant to the publication of Notice, no suggestions and objections have been received in respect of Transmission Licence amendment Application.
- 4. On consideration of the material on record, the Commission is prima facie satisfied that Transmission Licence No. 2 of 2009 granted to ATIL may be amended / altered as per the MERC (Transmission Licence Conditions) Regulations, 2004 as amended in 2006 to provide for development and operation of the following Transmission lines inclusive of related infrastructure by modifying the scope as given below:

Existing Area of Transmission	Amended Area of Transmission proposed
• 400 kV Double Circuit Transmission	• 400 kV Double Circuit Transmission
Line with quad conductor from Tiroda	Line with quad conductor from
(Gondia) to 400 kV Warora Switching	Tiroda(Gondia) to 400 kV Warora
Station;	Switching Station;

Existing Area of Transmission	Amended Area of Transmission proposed
 2 Nos. 400 kV bays for above Tiroda- Warora Double Circuit Transmission lines at Tiroda Project switchyard; 2 Nos. 400 kV bays for Tiroda-Warora Double Circuit Transmission Lines at Warora switching station; 	 2 Nos. 400 kV bays for above Tiroda- Warora Double Circuit Transmission lines at Tiroda Project switchyard; 2 Nos. 400 kV bays for Tiroda-Warora Double Circuit Transmission lines at Warora switching station; 2 x 80 MVAR Bus Reactors along with associated bays at Tiroda Substation.

- 5. A copy of ATIL's Application along with its annexures and enclosures can be accessed at the MERC website <u>www.mercindia.org.in / www.merc.gov.in</u> or inspected by any person in the Commission's office in accordance with the laid down procedure.
- 6. Any person may file objections and comments / suggestions in English or Marathi, in (6+1) copies, which should carry the full name, postal address and E- mail address, if any, of the sender and addressed to the Secretary of the Commission. It should be indicated whether the suggestions and/or objections are being filed on behalf of any organisation or of any category of consumers. It should also be mentioned if the sender wants to be heard in person, in which case opportunity would be given by the Commission at the Public Hearing to be held on <u>7 May, 2015 at 11:30</u> hrs in the Office of the Commission at 13th Floor, Centre No. 1, World Trade Centre, Cuffe Parade, Mumbai 400 005, when the ATIL's Application for amendment of its Transmission Licence will be considered. No separate notice will be issued for the purpose.

Date: 30 March, 2015 Place: Mumbai

Secretary, MERC