

**NOTICE**

Subject:- Case of Tata Power Company - Generation Business for Removal of Difficulties in implementation of MOD Guidelines in the case of generating units at its Trombay Thermal Power station.  
- **Case No. 89 of 2019**

The Tata Power Company Limited (Generation Business) has filed on 08.04.2019 the Petition under MERC (State Grid Code) Regulations, 2006 for Removal of Difficulties in implementation of MOD Guidelines in the case of generating units at Trombay Thermal Power Station of Tata Power -G.

The main prayers of the Petitioner are as under-

- A. *To waive the implementation of clause no. 8.1 of the Guidelines, i.e. Technical Minimum load @ 55 % of Installed capacity, in case of Unit 8 and specify the revised Technical Minimum of Unit 8 as 200 MW at Generator Terminals.*
- B. *To consider the fuel oil / gas consumption required to run the Unit 5 at revised Technical minimum load at 55 % of installed capacity as “loss of operational parameters” while defining the compensation mechanism as per Section 8.2 of the MOD Guidelines.*
- C. *Pass such other order(s) as this Hon'ble Commission may deem fit and proper in the facts and circumstances of the case.*
- D. *Condone any inadvertent omissions/ errors / rounding off differences / shortcomings and permit Tata Power-G to add / change / modify / alter this filing and make further submissions as may be required at a future date*

2. I am directed to communicate that the hearing in the above matter will be held on **Wednesday, 24 April, 2019 at 10.00 hrs** in the office of the Commission at 13<sup>th</sup> floor, Centre No.1, World Trade Centre, Cuffe Parade, Mumbai - 400 005.

3. I am directed to communicate that; the Commission has impleaded Maharashtra State Load Despatch Centre (MSLDC), BEST Undertaking and The Tata Power Company Limited (Distribution Business) as Respondent.

4. The Petitioner is directed to immediately serve a copy of its above mentioned Petition (both in soft and hard Copy) to the Respondents before the scheduled date of hearing.

5. The Respondents are directed to submit the say on affidavit in 1+6 copies to the Commission with documents, if any, on the above mentioned Petition immediately, with a copy to the Petitioner.

6. The Parties are directed to file their Petition and submissions in MS -Word file and PDF version as far as possible and to file 1+6 copies of all relevant documents/citations produced during the proceedings.
7. Appended is a copy of Daily Order dated 11.04.2019, in the above matter.

Sd/-  
(R. S. Sonawane)  
Dy. Director (Legal)

Encl. Copy of Daily Order

The Tata Power Company Limited (Generation Business)  
Bombay House,  
24, Homi Mody Street,  
Fort, Mumbai - 400 001  
E-mail: [ameym@tatapower.com](mailto:ameym@tatapower.com)

Petitioner

The Chief Engineer  
Maharashtra State Load Dispatch Centre,  
Kalwa, Thane - Belapur Road,  
Airoli, Navi Mumbai - 400 708  
E-mail: [ceslhc@mahaslhc.in](mailto:ceslhc@mahaslhc.in)

Respondent No. 1

The General Manager,  
The Brihanmumbai Electric Supply & Transport Undertaking,  
BEST Bhavan, BEST Marg,  
Fort, Mumbai - 400 001  
E-mail:- [gm@bestundertaking.com](mailto:gm@bestundertaking.com) / [dgm@bestundertaking.com](mailto:dgm@bestundertaking.com)

Respondent No. 2

The Tata Power Company Limited (Distribution Business)  
Bombay House,  
24, Homi Mody Street,  
Fort, Mumbai - 400 001  
E-mail: [rmranade@tatapower.com](mailto:rmranade@tatapower.com)

Respondent No. 3